



- NOTES:
- CONNECTION FOR FUTURE METHANOL SYSTEM EXPANSION
 - THE MINIMUM OUTBREATHING CAPACITY FOR VALVES CV-725 AND CV-755 IS 100 m³/hr. THE MINIMUM INBREATHING CAPACITY FOR VALVES CV-725 AND CV-755 IS 12 m³/hr.
 - REFER TO DIVISION 16 AREA CLASSIFICATION DRAWING E1.03 FOR HAZARDOUS LOCATIONS. ALL WIRING TO BE PROVIDED AND INSTALLED UNDER DIVISION 17. TERMINATIONS AND CABLES TO BE RATED FOR HAZARDOUS AREAS.
 - REFER TO VENDOR DRAWINGS AND DOCUMENTATION FOR INSTRUMENTATION AND CONTROL DEVICES AND I/O REQUIREMENTS.

<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	<p>A Tyco International Ltd. Company</p>	ENGINEER'S SEAL	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>	
			DESIGNED BY: EM/CD		ORIGINAL SIGNED BY: Q. MENG
			CHECKED BY: SB/PS		DATE: 2006/05/15
			APPROVED BY: JEH		CONSULTANT DRAWING NO. P11.03
	SCALE: NONE	RELEASED FOR CONSTRUCTION BY: K. MARTENS			
	NO. REVISIONS	DATE	DATE	CITY FILE NUMBER	
	00 ISSUED FOR TENDER	06/05/15	2006/01/16	NEWPCC CENTRATE NUTRIENT TREATMENT NITROGEN REMOVAL FACILITY	
		GLG	2006/05/15	SHEET OF	
				CITY DRAWING NUMBER	
				PROCESS METHANOL STORAGE TANK 2 PROCESS & INSTRUMENTATION DIAGRAM	