



**NOTES:**

1. CONCRETE COLUMNS AND PEDESTALS OMITTED FOR CLARITY
2. ALL METAL PARTS BENEATH SBR COVERS USED FOR PIPE SUPPORT INCLUDING ANCHORS, RODS AND CLAMPS TO BE SS316. SUBMERGED METAL PARTS IN EQUALIZATION TANK USED FOR PIPE SUPPORT INCLUDING ANCHORS, RODS AND CLAMPS TO BE SS316.
3. DECANTERS SUPPLIED UNDER SEPARATE CONTRACT. INSTALL DECANTERS AS PART OF THIS CONTRACT. COORDINATE EXACT DIMENSIONS WITH DECANTER SUPPLIER.
4. PROVIDE SS316 300Ø AIR AND 100Ø AIR BELOW COVER.
5. PROVIDE INTERMEDIATE SUPPORT AS REQUIRED FOR GUIDE RAIL AND PIPE.

 <b>Certificate of Authorization</b> Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007	 A Tyco International Ltd. Company		ENGINEER'S SEAL ORIGINAL SIGNED BY J.E. HUTCHISON 2006/05/15	 <b>THE CITY OF WINNIPEG</b> WATER AND WASTE DEPARTMENT ENGINEERING DIVISION NEWPCC CENTRATE NUTRIENT TREATMENT NITROGEN REMOVAL FACILITY PROCESS PROCESS TANK SECTIONS SHEET 2	CITY FILE NUMBER SHEET OF CITY DRAWING NUMBER
	DESIGNED BY: YL CHECKED BY: SB	APPROVED BY: JEH	CONSULTANT DRAWING NO. P14.02		
	DRAWN BY: SRP SCALE: AS NOTED	RELEASED FOR CONSTRUCTION BY: K. MARTENS DATE: 2006/05/15			
	NO. REVISIONS 00 ISSUED FOR TENDER DATE: 06/05/15 BY: GLG	DATE: 2006/01/16	DATE: 2006/05/15		