



NOTES:
 1. REFER TO VENDOR DRAWINGS AND DOCUMENTATION FOR INSTRUMENTATION AND CONTROL DEVICES AND I/O REQUIREMENTS.

EQUIP. NO.: C430-AB
 TYPE: PD BLOWER
 CAPACITY: 127 Nm³/min @ 67 kPa
 PRESSURE: 74 kPa
 POWER: 186 kW

EQUIP. NO.: C440-AB
 TYPE: PD BLOWER
 CAPACITY: 127 Nm³/min @ 67 kPa
 PRESSURE: 74 kPa
 POWER: 186 kW

<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	<p>A Tyco International Ltd. Company</p>	ENGINEER'S SEAL	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>		
			DESIGNED BY: YL/CD		ORIGINAL SIGNED BY: J.E. HUTCHISON	
			DRAWN BY: SRP		CHECKED BY: SB/PS	2006/05/15
			SCALE: NONE		APPROVED BY: JEH	CONSULTANT DRAWING NO. P8.02
	00 ISSUED FOR TENDER 06/05/15 SRP	DATE: 2006/01/16	RELEASED FOR CONSTRUCTION BY: K. MARTENS	NEWPC CENTRATE NUTRIENT TREATMENT NITROGEN REMOVAL FACILITY		
	NO. REVISIONS	DATE	DATE: 2006/05/15	PROCESS AIR BLOWERS PROCESS & INSTRUMENTATION DIAGRAM		