



- 1 SWITCHES FOR GAS SHUT-OFF TO AHU-3, AHU-4 & AHU-5. MOUNT 2200 ABOVE FLOOR WITH RED COVER PLATES LABELED AHU-3, AHU-4 & AHU-5.
- 2 LIGHT SWITCHES FOR APPARATUS ROOM. SEE DWG. E7, CONTROL ROOM ELEVATION.

NOTES :
SEE NOTES ON DRAWING E1.

MEZZANINE FLOOR PLAN - ELECTRICAL LIGHTING
SCALE: 1:100

MAIN FLOOR PLAN - ELECTRICAL LIGHTING
SCALE: 1:100

LIGHT FIXTURE & SMOKE DETECTOR SCHEDULE						
TYPE	QTY.	MANUFACTURER	CATALOGUE No.	LAMP	DESCRIPTION	REMARKS
⊕	2	CANLET	67VMG	A19,1X150W	NON METALLIC VAPOR PROOF FIXTURE, WALL MOUNT W/CLEAR GLOBE & GUARD, 120V	B
⊕	6	STYLOS	3021B-CHR-WH	2X60W	WALL MOUNT SCONCE, STANDARD FINISH, SHADE COLOR WH, ADA COMPLIANT, 120V	C
⊕	3	LITHONIA	KL70M/D/120/ORS/BBR/DBB	70W METAL HALIDE	DOWN LIGHT, DIRECTIONAL LENS, RECESSED SOFFIT MOUNT, 120V.	D
⊕	13	LITHONIA	S1/17/120/ACNP	1X17W, T8	150MMX860MM WALL MOUNTED FLUORESCENT FIXTURE, 120V.	A
⊕	3	LITHONIA	WC/2/32/A/12/120/ACNP	2X32W, T8	120MMX1200MM WALL MOUNTED FLUORESCENT FIXTURE W/12 PATTERN ACRYLIC DIFFUSER, 120V.	A
⊕	1	LITHONIA	UNS/132/120/ACNP	1X32W, T8	120MMX1200MM CEILING MOUNTED FLUORESCENT FIXTURE HEAVY DUTY STRIP, 120V.	A
⊕	28	PEERLITE - CERRA	CRW7/2/32/WHR/R4/120/GEB	2X32W, T8	150MMX1200MM WALL MOUNTED FLUORESCENT FIXTURE, 120V.	B
⊕	4	PEERLITE	CRW7/2/32/WHR/R4/120/GEB	2X32W, T8	180MMX1200MM WALL MOUNTED FLUORESCENT FIXTURE, WIRED AS NIGHT LIGHT, 120V.	B
⊕	24	LITHONIA	LA/2/32/120/ACNP	2X32W, T8	300MMX1200MM CEILING MOUNTED FLUORESCENT FIXTURE, 120V.	A
⊕	1	LITHONIA	LA/2/32/120/ACNP	2X32W, T8	300MMX1200MM CEILING MOUNTED FLUORESCENT FIXTURE, WIRED AS NIGHT LIGHT, 120V.	A
⊕	3	CACHET	891/5/T02/L/08/120/E/W	2X32W, T8	230MMX2400MM SUSPENDED LAMP FLUORESCENT FIXTURE, STANDARD WHITE, 120V.	A
⊕	7	LITHONIA	VRR/50S/120/CSA	50W, HPS	40MM X 40MM WALL MOUNT FIXTURE. MOUNT 1100 FROM UNDERSIDE OF SOFFIT.	A
⊕	20	LITHONIA	UN/2/32/120/ACNP/P48WG	2X32W, T8	110MMX1200MM CEILING MOUNTED FLUORESCENT FIXTURE, HEAVY DUTY STRIP W/ WIRE GUARD, 120V.	A
⊕	2	LITHONIA	UN/2/32/120/ACNP/P48WG	2X32W, T8	110MMX1200MM CEILING MOUNTED FLUORESCENT FIXTURE, HEAVY DUTY STRIP W/ WIRE GUARD, WIRED AS NIGHT LIGHT 120V.	A
⊕	4	LITHONIA	UN/2/32/120/ACNP/P48WG	2X32W, T8	110MMX1200MM CEILING MOUNTED FLUORESCENT FIXTURE, HEAVY DUTY STRIP W/ WIRE GUARD, 120V.	A
⊕	10	CANLET	67VECMG	A19,1X150W	NON METALLIC VAPOR PROOF INCANDESCENT FIXTURE, CEILING MOUNT W/CLEAR GLOBE & GUARD, 120V	A
⊕	3	LITHONIA	51/25/120/GEB101S	1X25W, T8	50MMX900MM UNDER CABINET MOUNTED FLUORESCENT FIXTURE STRIP, STANDARD WHITE, 120V.	VALANCE
⊕	3	LITHONIA	VRR/100M/120/LP1	100W MEDAL HALIDE	34M X 3MM EXTERIOR FIXTURE, CLEAR PRISMATIC LENS. SOFFIT MOUNT, WHITE POWDER COAT FINISH.	
⊕	1	LUMACELL	RG24S350/2MT/9W	24V MICRO TUNGSTEN	EMERGENCY LIGHTING BATTERY PACK WITH 2 LIGHTS, 24V,350W,30 MINUTE SUPPLY.	
⊕	11	LUMACELL	MT2/24V/9W	REMOTE LAMP	TUNGSTEN, DOUBLE 24V, 9WATT, MOUNT FIXTURE 2600MM ABOVE FINISHED FLOOR. (WIRE TO EMERGENCY LIGHTING BATTERY PACK).	
⊕	6	LUMACELL	MT1/24V/9W	REMOTE LAMP	TUNGSTEN, SINGLE 24V, 9WATT, MOUNT FIXTURE 2600MM ABOVE FINISHED FLOOR. (WIRE TO EMERGENCY LIGHTING BATTERY PACK).	
⊕	12	EDWARDS	FIGA-PS-CIGA-SB	1X25W, T8	PHOTO ELECTRIC SMOKE DETECTOR	

REMARKS	
A	BALLAST, ADVANCE DISCRETE ELECTRONIC BALLAST, RAPID START
B	MOUNT 2100 ABOVE FINISH FLOOR, BOTTOM OF FIXTURE
C	DIMMING SWITCH, LUTRON, "ARIADNI" TOGGLE SWITCH PRESET SLIDE
D	LIGHT FIXTURE RECESSED INTO SOFFIT

ALL NEW LIGHTING FIXTURES AND BALLASTS TO BE POWERSMART APPROVED.
LIGHTING FIXTURE QUANTITIES SHOWN ABOVE ARE FOR REFERENCE ONLY. CONTRACTOR IS RESPONSIBLE FOR QUANTITY TAKE-OFF FROM DRAWING.

ORIGINAL STAMPED BY: DOUG PALEY, P.ENG.
DATE: 2006.07.14

NO.	REVISION/DESCRIPTION	BY	DATE
SEALS			

DRAWN BY	RCPI/DTA	CHECKED BY	APPROVED
DATE	2006.07.14	USER APPROVAL	

CITY OF WINNIPEG
PLANNING, PROPERTY & DEVELOPMENT DEPARTMENT
CIVIC ACCOMMODATIONS DIVISION
300 - 65 GARRY ST. R3C 4K4

PROJECT
WEST TRANSCONA
FIRE PARAMEDIC STATION 21

1446 REGENT AVE. WEST
SHEET TITLE

MAIN & MEZZANINE FLOOR PLANS
ELECTRICAL
LIGHTING AND SCHEDULE

METRIC
WHOLE NUMBERS ARE IN MILLIMETRES,
DECIMALIZED NUMBERS ARE IN METRES.

SCALE	PROJECT NO.	SHEET NO.
AS SHOWN	2004-058-01	E5