


NOTES:

- SUSPENDED CEILING HEIGHT IS 108".

EQUIPMENT	DIMENSION
MAIN 4160V SWITCHGEAR	354"L x 58"W x 80"H
600V ACB DISTRIBUTION PANEL	42"L x 60"W x 90"H
DC BATTERY BANK DISTRIBUTION AND BATTERY CHARGER	42"L x 30.5"W x 90"H
GRIT TRANSFORMER T1	100"L x 54"W x 91"H
GRIT TRANSFORMER T2	100"L x 54"W x 91"H
PCU	54"L x 33"W
FDP	71"L x 24"W
MCC 1G	160"L x 20"W
MCC 2G	160"L x 20"W



DRAWING NUMBER	REFERENCE DRAWINGS
----------------	--------------------

B.M. ELEV.	FIELD BOOK #:
POSTED TO LBIS	
DESIGNED BY	EXISTING
CHECKED BY	CJR
DRAWN BY	DS
APPROVED BY	
HOR. SCALE	1:50
VERTICAL	RELEASED FOR CONSTRUCTION
DATE	2006/07/07
DATE	
NO. REVISIONS	DATE BY FILENAME: NEP_SK3_RO.dwg

SNC-LAVALIN
 Engineers & Constructors
 200-1600 Ross Avenue
 Winnipeg, Manitoba
 Canada R3J 3W7

ENGINEER'S SEAL

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

NORTH END WATER POLLUTION CONTROL CENTRE

EQUIPMENT LAYOUT PLAN
 GRIT BUILDING
 MAIN ELECTRICAL ROOM

CITY DRAWING NUMBER: NEP-SK3
 SHEET: 001
 REV: 00
 SIZE: D