



1
-
GENERATOR ROOM COOLING AND VENTILATION FOR GN-E903A
N.T.S.

NOTES:
 ① BAS CONTROLLER #3.
 I/O POINTS WIRED TO GENERATOR DDC(BAS) CONTROL PANEL AS PER SPEC. SECTIONS 15900, 15901, 15902. TYPICAL FOR EACH OF 3 GENERATORS.

APEGM
 Certificate of Authorization
 Earth Tech Canada Inc.
 No. 730 Expiry: April 30, 2007

B.M. ELEV.					
00	ISSUED FOR TENDER	06/08/28	LJW		
NO.	REVISIONS	DATE	BY	DATE	2006/06/15

CH2M HILL
 Frederickson Cooper
 ARCHITECTS

EarthTech
 A Tech International Ltd. Company

ENGINEER'S SEAL
 ORIGINAL
 SIGNED BY
 A. BURACHYNSKY
 2006/08/30
 CONSULTANT DRAWING NO.
 WG-H0504

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 ENGINEERING DIVISION

WATER TREATMENT PLANT
 STANDBY POWER GENERATOR

CITY FILE NUMBER
 SHEET OF
 CITY DRAWING NUMBER
 1-0601G-G-H0504-001-000

MECHANICAL
 GN-E903A
 COOLING AND VENTILATION SCHEMATICS