



**A SECTION**  
WG-H0120.140 1:100




**C SECTION-TYPICAL FOR INLET DAMPERS**  
WG-H0120 1:50



**D SECTION-TYPICAL FOR EXHAUST DAMPERS**  
WG-H0120 1:50

- DRAWING NOTES**
- 13mm SQUARE WIRE MESH WELDED TO END.
  - UNIT HEATER INSTALLATION, SEE DRAWING WG-H0401 DETAIL 4.
  - ROOF EXHAUST FAN MOUNTING, SEE DRAWING WG-H0401 DETAIL 5.
  - WALL EXHAUST FAN MOUNTING, SEE DRAWING WG-H0402 DETAIL 1.
  - 50mm ACOUSTIC LINER.
  - 25mm FOIL FACED INSULATION FOR OUTSIDE & SUPPLY AIR DUCT.
  - 915x1220 RELIEF AIR HOOD ON ROOF c/w BACK DRAFT DAMPER. TERMINATE INTAKE OPENING APPROX. 600mm BELOW ROOF DECK. SEE DRAWING WG-H0402 DETAIL 5.



- GENERAL NOTES**
- COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.
  - ALL DUCTWORK SHALL BE SUPPORTED AND SUSPENDED AS PER SPECIFICATIONS AND LOCAL CODES (SEE DETAILS).

**APEGM**  
Certificate of Authorization  
Earth Tech Canada Inc.  
No. 730 Expiry: April 30, 2007

B.M. ELEV.					
DESIGNED BY	AB/LJW	CHECKED BY	AMA, PVL	ENGINEER'S SEAL	
DRAWN BY	LJW	APPROVED BY	AHL	ORIGINAL SIGNED BY	
SCALE:	AS NOTED	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI	A. BURACHYNSKY	
ISSUED FOR TENDER	06/08/28	DATE	2006/05/29	2006/08/30	
NO. REVISIONS	DATE	BY	DATE	CONSULTANT DRAWING NO. WG-H0202	

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
ENGINEERING DIVISION

Winnipeg

WATER TREATMENT PLANT  
STANDBY POWER GENERATOR

MECHANICAL  
VENTILATION SECTIONS

CITY FILE NUMBER  
SHEET OF  
CITY DRAWING NUMBER  
1-0601G-H0202-001-00D