



DRAWING NOTES

- | | |
|---|--|
| <p>① ENTIRE O/A DUCT FROM THE CEILING TO AHU-H242A SHALL BE THERMALLY INSULATED. PROVIDE INTAKE GRAVITY HOOD W/ ROOF CURB ON TOP OF ROOF.</p> <p>② R/A DUCT.</p> <p>③ ENSURE ADEQUATE CLEARANCE TO ALLOW PULLING OUT COILS. ALSO, ALLOW ADEQUATE CLEARANCE FOR GENERAL UNIT MAINTENANCE.</p> <p>④ PROVIDE THERMOSTAT MOUNTED ON CONCRETE COLUMN, 1500-mm ABOVE INSIDE FLOOR LEVEL. SEE STRUCTURAL FOR COLUMN LOCATION.</p> <p>⑤ FIRE EXTINGUISHER SHALL BE MOUNTED AS PER LOCAL CODES AND REGULATIONS.</p> <p>⑥ 50mm THICK INSULATION FROM LOUVER TO END OF DUCT</p> <p>⑦ MONORAIL PATH. ENSURE DUCT IS ABOVE THE MONORAIL.</p> <p>⑧ VALVE FLOOR BOX. TO CONTROL CLEARWELL WASHDOWN PIPING BELOW.</p> | <p>⑨ 100ϕ SANITARY DRAIN MOUNTED AGAINST AIR SHAFT WALL AND SLOPED MINIMUM 1% TOWARDS EXTERIOR WALL. ALLOW FOR EIGHT (8) INSTRUMENT DRAIN CONNECTIONS.</p> <p>⑩ SEE DRAWING WT-M0002 FOR CONTINUATION. REFER TO STRUCTURAL FOR PENETRATION LOCATION.</p> |
|---|--|

GENERAL NOTES

- COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.
- ALL DUCTS SHALL BE PROPERLY SECURED AND SUPPORTED ACCORDING TO APPLICABLE CODES.

 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007	B.M. ELEV.	 Frederickson Cooper ARCHITECTS	 A Type International Ltd. Company	ENGINEER'S SEAL	 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	CITY FILE NUMBER			
				DESIGNED BY: DC		CHECKED BY: AB	ORIGINAL SIGNED BY: A. BURACHYNSKY	2006/08/30	SHEET OF
				DRAWN BY: DC		APPROVED BY: AHL	SCALE: AS SHOWN	RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	CONSULTANT DRAWING NO. WT-M0003
	00 ISSUED FOR TENDER 06/08/28 DC		DATE: 2005/03/15	DATE: 2006/08/30	WATER TREATMENT PLANT TREATED WATER STORAGE INLET BUILDING MECHANICAL VENTILATION PLAN				