

POINT	POINT DESCRIPTION	ASSOCIATED DEVICE	CONTROLLER ID			
			01	02	03	04
AO-1	PROPORTIONAL GAS VALVE	ADVANCED CONTROL TECH. DRN2-0/135-3	X	X	X	X
AO-2	(SPARE)					
DO-3	BLOWER START/STOP	24VAC 2PDT RELAY	X	X	X	X
DO-4	HEATING ENABLE/DISABLE	24VAC 2PDT RELAY	X	X	X	X
DO-5	UNIT HEATER START/STOP	24VAC 2PDT RELAY	X	X	X	X
DO-6	(SPARE)					
DO-7	(SPARE)					
DO-8	(SPARE)					
AI-1	SPACE TEMPERATURE	TE-6000-4 1000 OHM RTD	X	X	X	X
AI-2	SUPPLY AIR TEMPERATURE	TE-6000-4 1000 OHM RTD	X	X	X	X
AI-3	(SPARE)					
AI-4	NO2 SENSOR	B&W TECHNOLOGIES		X		X
AI-5	(SPARE)					
AI-6	(SPARE)					
AI-7	(SPARE)					
AI-8	(SPARE)					
DI-1	BLOWER STATUS	AIR PROVING SWITCH	X	X	X	X
DI-2	OVERHEAD DOOR STATUS "A"	DRY CONTACT ON OVERHEAD DOOR	X			X
DI-3	OVERHEAD DOOR STATUS "B"	DRY CONTACT ON OVERHEAD DOOR	X			X
DI-4	(SPARE)					
DI-5	LOCAL OCCUPIED MODE OVERRIDE	(USE JUMPER WIRE IF FUNTION REQUIRED)				
DI-6	(SPARE)					
DI-7	FLAME FAILURE	DRY CONTACT ON FLAME FAILURE RELAY	X	X	X	X
DI-8	ALARM DISABLE	(USE JUMPER WIRE IF FUNTION REQUIRED)				

FORT ROUGE GARAGE STORAGE GARAGE MUA-01 TO 04 DDC CNTLR POINT LAYOUT	REVISSION 2
	DRAWING NO. 1501-09C