



COMPONENT IDENTIFICATION

- MTR-1 MAIN SUPPLY FAN MOTOR
- MTR-2 DAMPER MOTOR
- 1LT RED BLOWER LIGHT
- 2LT RED HEATER LIGHT
- SW-1 BLOWER SWITCH
- SW-2 HEATER SWITCH
- M MAGNETIC STARTER COIL FOR 1MTR
- OLs THERMAL OVERLOADS
- DMES DAMPER MOTOR END SWITCH
- TR-1 CONTROL TRANSFORMER
- CB 10 AMP OVERLOAD
- R1 EXHAUST RELAY
- TD-1 BLOWER TIME DELAY
- IHL INLET HIGH LIMIT (SET @ 170°F)
- 1M-2 N.O. AUX. CONTACTS 1M
- 1M-1 N.O. STARTER CONTACTS

LEGEND

- (n) EXISTING TERMINALS AT REMOTE PANEL FOR MUA
- [n] EXISTING TERMINALS AT MUA
- [n] METASYS BASE FRAME TERMINALS

NOTES

1. Notes.

NORTH GARAGE OFFICE AREA MUA-11 WIRING DETAILS	REVISION 1
	DRAWING NO. 1501-20-i