



### LEGEND

Point Desc. DC-9100 DIGITAL CONTROLLER  
Term. Number TERMINATIONS

CO2 - CARBON DIOXIDE SENSOR

CR - 24VAC CONTROL RELAY\*

DPS - DIFFERENTIAL PRESSURE SWITCH

DPT - DIFFERENTIAL PRESSURE TRANSDUCER\*

TE - 1000Ω RESISTIVE TEMPERATURE ELEMENT

VRT - VOLTAGE IN/RESISTIVE OUT TRANSDUCER\*

\* - MOUNTED AT MUA UNIT IN 20" x 20" DDC CONTROL PANEL (REFER DWG. 1501-47)

2 - 18/2 TWISTED & SHIELDED CABLE

4 - 22/4 TWISTED CABLE

DRAWING TITLE  
FT. ROUGE G SECTION  
MUA-1

SALES ENGR	PROJECT MGR	APPL. ENGR	DRAWN	APPROVED	DATE	BY
BH	RG	RG	BT	CV	01/27/92	BY

2	AS BUILT	04/25/92	CM
1	PROP. HTG AO-1	02/09/92	CM
NO.	REVISION-LOCATION	ECN	DATE BY

PROJECT	WINNIPEG TRANSIT ADMINISTRATION AND G SECTION METASTAS FACILITY MANAGEMENT SYSTEM	CONTRACT NUMBER	91098-5006
DRAWING NUMBER	1501-41A	FILE:	MUA1SYS

JOHNSON CONTROLS  
Systems & Services Division  
800 WATSON STREET  
WINNIPEG, MANITOBA  
R3J 3V9  
204-885-9300