



- NOTES**
- PUMP CONTROL UNIT TERMINALS C1, C2, C3 AND C4 SHALL BE CONNECTED TO DISPENSER NOZZLE HANDLE SHUT-OFF.
 - SOLID STATE MOTOR STARTERS AT OUT TERMINALS ARE SUPPLIED WITH PUMP CONTROL UNITS.

DEDICATED SITE CONTROLLER
SCALE: N.T.S.

PROFESSIONAL SEALS

REV	DATE	DESCRIPTION	DRN	CHK	DES	ENG	IDR	APP
D	08/05/23	Issued For Addendum No.3						
C	08/04/21	Issued For Bid	SCK	ALS	LK	BM	BNF	-
B	08/04/07	Issued For Review	SCK	CC	LK	BM	BNF	-
A	08/03/07	Issued For Review	SCK	CC	LK	BM	BNF	-
I/R	YY/MM/DD	ISSUE/REVISION DESCRIPTION	DRN	CHK	DES	ENG	IDR	APP

UMA | AECOM

City of Winnipeg
Construction of a New Fueling Facility
District 6 Public Works Yard, 1539 Waverley St.
Electrical
Control Wiring Diagram

PROJECT NUMBER	DRAWING NUMBER	ISSUE/REVISION
0265-405-00	01-E-0004	D

DO NOT SCALE THIS DOCUMENT.
ALL MEASUREMENTS MUST BE OBTAINED FROM STATED DIMENSIONS.

© 2008 UMA ENGINEERING LTD. ALL RIGHTS RESERVED.
THIS DOCUMENT IS PROTECTED BY COPYRIGHT LAW AND MAY NOT BE REPRODUCED IN ANY MANNER, OR FOR ANY PURPOSE EXCEPT BY THE WRITTEN PERMISSION OF UMA ENGINEERING LTD.