



PROPOSED VENTILATION			
MODE	OCCUPIED	ACH	RECIRC
WINTER	NO	6.0	75%
	YES	6.0	0%
SUMMER	NO	6.0	0%
	YES	6.0	0%

NOTES:

1. ALL INSTRUMENTS SHOWN IN AN AUXILIARY LOCATION ARE IN THE CORRESPONDING VFD / MOTOR STARTER PANEL.
2. THE FACILITY PREFIX FOR ALL INSTRUMENT IDENTIFIERS IS "MON".



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OPP. 907-2011	2012/02/09	BC	CJR

SNC-LAVALIN INC.
 148 Nature Park Way
 Winnipeg, MB, Canada R3P 0X7
 204-786-8080

DESIGNED BY: B. CLEVEN
 CHECKED BY: C. REIMER
 DRAWN BY: S. FUNK
 APPROVED BY: C. REIMER
 SCALE: NTS
 RELEASED FOR CONSTRUCTION BY: K. R. ZUREK
 DATE: 2011/10/04
 DATE: 2012/02/23

CONSULTANT NO.: 508042-0000-49DD-0005

ENGINEER'S SEAL

ORIGINAL DRAWING
 SEALED BY:
 C. J. REIMER
 SNC-LAVALIN
 MEMBER #21968
 2012/02/23
 REV. 00

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

Winnipeg

MONTCALM WASTEWATER PUMPING STATION
 2011 UPGRADES
 PROCESS AND INSTRUMENTATION DIAGRAM
 VENTILATION - AHU-L1

CITY DRAWING NUMBER: 1-0164L-P0005
 SHEET: 001
 REV: 00
 SIZE: A1