

## 907-2011 ADDENDUM 4

### MONTCALM WASTEWATER PUMPING STATION UPGRADES

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: March 21, 2012  
BY: Charles Cong  
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Add E29.2.17	One Way Air Valve
Add E29.2.17 (a)	Material: Stainless Steel
Add E29.2.17 (b)	Connection: Flanged or Threaded
Add E29.2.18	Gate Valve, smaller than 100mm dia
Add E29.2.18 (a)	Material: A182 CF8M Body
Add E29.2.18 (b)	Type: Gate or Ball valve (Ball valve will be accepted)
Add E29.2.18 (c)	Valve to be suitable for wastewater application
Add E29.2.18 (d)	Connection: Flanged or Threaded
Add E29.2.18 (e)	Rating: 150 lb
Add E29.2.19	Check Valve, smaller than 100mm dia
Add E29.2.19 (a)	Material: A182 CF8M Body
Add E29.2.19 (b)	Check valve to be suitable for wastewater application.
Add E29.2.19 (c)	Connection: Flanged or Threaded
Add E29.2.19 (d)	Rating: 150 lb
Add E29.2.20	Pipe smaller than 100mm dia, Sump pump and process piping
Add E29.2.20 (a)	Material: A312 Gr. TP316L, Schedule 10S

## **NMS Format Specifications**

### **Section 26 05 21**

Clarification of: Clause 2.4:

Some concern has been expressed by a Bidder regarding availability of the specified CIC control cables. The Contractor is responsible for supplying the specified cables or approved equal. This may require the Contractor to obtain cables from another City, if stock is not available in Winnipeg. However, in the event that the cable is not available, and the Contractor's only choice would be to order a minimum manufacturer order quantity (1000's of metres), the City and SNC-Lavalin Inc. will be open to reviewing an alternate cable, such as an ACIC cable. This will be addressed on an as required basis during the submittal review stage of the project.

### **DRAWINGS:**

Replace: 907-2011\_Drawing\_1-0164L-E0004-001-00 with 907-2011\_Addendum\_4\_Drawing\_1-0164L-E0004-001-01