



MECHANICAL ROOM SECTION - DEMOLITION

DEMOLITION NOTES /#\

1. DEMOLISH HOUSEKEEPING PAD. PATCH AND REPAIR TO MAKE LEVEL WITH SURROUNDING FLOOR.

N.T.S.

- 2. REMOVE EXISTING PUMP AND MOTOR.
- REMOVE AND DISPOSE OF PIPES, HANGERS, VALVES AND FITTINGS ON POOL SUPPLY AND RETURN BETWEEN NOTED POINTS.
- REMOVE EXISTING FLOW METER AND ASSOCIATED PIPING. REMOVE PRESSURE SENSOR AND RELATED WIRING.
- 5. DISCONNECT CHLORINATION SYSTEM AND STORE FOR RECONNECTION IN RENOVATION
- 6. 1/8" CO2 GAS LINE TO BE DISCONNECTED DURING DEMOLITION.
- 7. DISCONNECT SINK FOR RELOCATION IN RENOVATION PHASE.



epp siepman engineering inc. mechanical engineers

303-100 Osborne St. South Winnipeg, MB R3L 1Y5

f 204.453.1335 ese@eppsiepman.com

CAD CHECKED BY APPROVED DRAWN BY USER APPROVAL 2012.04.04



CITY OF WINNIPEG PLANNING, PROPERTY AND DEVELOPMENT DEPARTMENT
CIVIC ACCOMMODATIONS DIVISION 300 - 65 GARRY ST. R3C 4K4

PROJECT

ULTRAVIOLET SYSTEM

AND PUMP UPGRADES 909 CONCORDIA AVE.

SHEET TITLE

DEMOLITION

SCALE PROJECT NO. SHEET NO. 118-2012 AS SHOWN

