



Date: May 23rd 2012

MOISTURE INSPECTION REPORT

Page 1 of 1

Test type; Residential Commercial Request Date; May 12/12 Test Date: May 15/12
 COMMISSIONER (shaded box)
 CONTRACTOR
 Name; City Of Winnipeg Address; 510 Main Street City; Wpg Phone Number; 470-7881
 Lou Chubenko Project Officer II Municipal Accommodations Division
 Job Site; St. James Centennial Pool (Gym Area) Address; 644 Parkdale Street, Winnipeg

TEST RESULTS

Calcium Chloride Moisture Test

Humidity: not tested pH test: 10 Delmhorst meter reading: not tested
 Start Date: May 15th Time: 12:00 pm Finish Date: May 18th Time 11:00 am

<u>Test unit</u>	<u>Location</u>	<u>Grams difference</u>	<u>results lbs.per 1000 sq. ft per 24 hours</u>
1	Fitness Studio	2.9 grams	6 lbs.

Rapid rH Moisture Test

Start Date: May 15th Time: 11:30am Finish Date: May 18th Time: 11:45 am

<u>Test unit</u>	<u>Location</u>	<u>results</u>
Rapid rH sensor	Main basketball court	99% rH
Rapid rH sensor	Fitness Studio	99% rH

The above Calcium Chloride Moisture Test is based on guidelines set out by the R.M.A. ASTM F1869-98.

The above tests are based on testing guidelines set out by ASTM F-2170-11– Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using In-Situ Probes

The testing was performed using the Rapid rH meter manufactured by Wagner Meters. Sensors & Equipment are calibrated according to ISO/IEC 17025

The sensor hole has been capped and can be used for further testing.

test report by: Paul Plouffe

Signature;