



RFP No.407-2011 ADDENDUM No. 1

FOR PROFESSIONAL CONSULTING SERVICES FOR ENGINEERING SERVICES FOR THE REPLACEMENT OF THE 1200MM BUTTERFLY VALVE AT THE LDV1 LOCATION AT MACLEAN PUMPING STATION

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL

ISSUED: May 18,2012
BY: Doug Berg, C.E.T.
TELEPHONE NO. (204) 986-4452

THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Ar20070420

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

PART E – SCOPE OF SERVICES

- Add: D3.3 (b): Please note that the “LDV1” valve is also referenced as the “V11A” or “V-11A” valve on some of the historical drawings provided in Appendix A.
- Revise: E1.2 (a)(i) to read: Structural engineering services for the removal of the existing valve and installation of the new valve complete with any modifications that have to be made to the existing valve chamber and piping to accommodate the removal and installation.
- Revise: E1.4 (a)(i) to read: Any required modifications to the existing valve chamber and piping to facilitate the removal of the existing valve and installation of the new valve.
- Add: E1.4 (a)(v): Provision for installation of new 100mm drain valve on chamber pipe immediately downstream of the new valve location.