

**Part 1 General**

**1.1 RELATED SECTIONS**

- .1 Section 26 05 01 - Common Work Results - Electrical.

**1.2 REFERENCES**

- .1 Canadian Standards Association (CSA International).
  - .1 CAN/CSA C22.2 No.4-M89 (R2000), Enclosed Switches.
  - .2 CSA C22.2 No.39-M89 (R2003), Fuseholder Assemblies.

**1.3 SUBMITTALS**

- .1 Submit product data in accordance with Section 26 05 01 – Common work Results – Electrical.

**Part 2 Products**

**2.1 DISCONNECT SWITCHES**

- .1 Non-fusible, horsepower rated disconnect switch in CSA Enclosure, to CAN/CSA C22.2 No.4 sized as per drawings.
- .2 Provision for padlocking in off switch position by three locks.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Sprinkler-proof indoors, weatherproof outdoors.
- .5 Quick-make, quick-break action.
- .6 ON-OFF switch position indication on switch enclosure cover.
- .7 Where required (For VFDs) provide an auxilliary contact to break prior to main contacts and interlock with the VFD emergency stop.

**2.2 EQUIPMENT IDENTIFICATION**

- .1 Provide equipment identification in accordance with Section 26 05 01 - Common Work Results - Electrical.
- .2 Indicate name of load controlled on size 4 nameplate.

**Part 3 Execution**

**3.1 INSTALLATION**

- .1 Install disconnect switches.

**END OF SECTION**