

	Equipment Schedule		Document Code	508955-0000-40EL-0001
			Revision	00
Client City of Winnipeg				
Project MacLean Pumping Station Electrical Upgrades				
Package / Area				
Prepared By	Name	Signature	Date	
	B. Cleven		2012-07-25	
Checked By	Name	Signature	Date	
	C. Reimer		2012-07-25	
Approved By	Name	Signature	Date	
	C. Reimer		2012-07-25	
Notes / Comments				

Revisions					
Rev	Description	Date	By	Checked	Approved
00	Issued for Tender	2012-07-25	B. Cleven	C. Reimer	C. Reimer

Original Equipment Tag	New Equipment Tag	Description	Existing Source	New Source
ACU-1	AHU-M605	Electrical Room Air Handling Unit	MCC-A	MCC-M1
AHU-1/AHU-4	AHU-M604	Pump Room Air Handling Unit	CDP-B	MCC-M1
CH-1	CHLR-M630	Chiller	CDP-B	MCC-M1
CHWP-1	P-M631	Chilled Water Pump	CDP-B	MCC-M1
CHWP-2	P-M632	Chilled Water Pump	CDP-B	MCC-M1
CT-1	CT-M635	Cooling Tower	N/A	N/A
CT-1 FAN 1	FN-M635-1	Cooling Tower Fan	CDP-B	MCC-M1
CT-1 FAN 2	FN-M635-2	Cooling Tower Fan	CDP-B	MCC-M1
CTP-1	P-M633	Cooling Tower Pump	CDP-B	MCC-M1
CTP-2	P-M634	Cooling Tower Pump	CDP-B	MCC-M1
D1	OD-M996	Pump Room Overhead Door	MCC-A	DP-M2
D2	OD-M997	CL2 Room Overhead Door	MCC-A	DP-M2
DHV-1	XV-M051	Discharge Header Valve	MCC-E	MCC-M3E
DHV-2	XV-M052	Discharge Header Valve	MCC-A	DP-M2
DHV-3	XV-M053	Discharge Header Valve	MCC-A	DP-M2
DHV-4	XV-M054	Discharge Header Valve	MCC-E	MCC-M3E
E1	HCE-M609	Preheat Electric Heater	MCC-A	MCC-M1
E2	HCE-M601	Electric Heating Coil for AHU-M1	MCC-A	DP-M2
E3	HCE-M603	Electric Heating Coil for AHU-M3	MCC-A	MCC-M1
E4	HCE-M605-1	Electric Heater Control Room	MCC-A	DP-M2
E5	HCE-M605-2	Electric Heater Control Room	MCC-A	DP-M2
E6	HCE-M616	Electric Heater CL2 Equipment Room	MCC-A	DP-M2
E7	UH-M657	Unit Heater CL2 Equipment Room	MCC-E	MCC-M3E
E8	UH-M658	Unit Heater Scale Room	MCC-A	DP-M2
E9	HCE-M619	Electric Heater CL2 Scale Room	MCC-A	DP-M2
E10	HCE-M620	Electric Heater CL2 Storage Room	MCC-A	N/A
E11	UH-M661	Unit Heater CL2 Storage	MCC-A	MCC-M1
E12	UH-M662	Unit Heater CL2 Storage	MCC-A	MCC-M1
E13	UH-M663	Unit Heater Ammonia Room	MCC-A	DP-M2
E14	UH-M664	Unit Heater Ammonia Room	MCC-A	N/A
E15	UH-M665	Unit Heater South Stairwell	PNL-A	PNL-A
E16	UH-M666	Unit Heater North Stairwell	PNL-A	PNL-A
E17	UH-M667	Unit Heater Washroom	PNL-A	PNL-A
E18	UH-M668	Unit Heater Lobby Entrance	PNL-A	PNL-A
E19	UH-M669	Unit Heater Lobby Entrance	PNL-A	PNL-A
F1	EF-M681	Pump Room Exhaust Fan	MCC-E	MCC-M3E
F2	EF-M682	Pump Room Exhaust Fan	MCC-E	MCC-M3E
F3	EF-M683	Pump Room Exhaust Fan	MCC-E	MCC-M1
F4	EF-M684	Pump Room Exhaust Fan	MCC-E	MCC-M1
F5	EF-M685	Washroom Fan	PNL-A	PNL-A
F6	EF-M686	CL2 Equip. Room Exhaust Fan	MCC-E	MCC-M3E
F7	EF-M687	CL2 Equip. Room Exhaust Fan	PNL-A	PNL-A
F8	EF-M688	CL2 Scale Room Exhaust Fan	PNL-A	PNL-A
F9	EF-M689	CL2 Scale Room Exhaust Fan	MCC-E	MCC-M3E
F10	EF-M690	CL2 Storage Room Exhaust Fan	MCC-E	MCC-M3E
F11	EF-M691	CL2 Storage Room Exhaust Fan	PNL-A	PNL-A
F12	EF-M692	CL2 Storage Room Exhaust Fan	MCC-E	MCC-M3E
F13	EF-M693	Ammonia Room Exhaust Fan	PNL-A	PNL-A
F14	EF-M694	Electrical Room Exhaust Fan	PNL-A	PNL-A
FC1	AHU-M601	Pump Room Air Handling Unit	MCC-E	MCC-M3E
FC2	AHU-M602	Pump Room Air Handling Unit	MCC-A	MCC-M1
FC3	AHU-M603	Pump Room Air Handling Unit	MCC-E	MCC-M3E
H1	CRN-M991	Monorail Hoist CL2 Room	MCC-A	MCC-M1
H2	CRN-M992	Pump Room Crane	MCC-A	MCC-M1
LZ-902-AC	AC-M903	Valve Air Compressor	MCC-A	MCC-M3E
P7	P-M941	Sump Pump	MCC-E	MCC-M3E
P8	P-M942	Sump Pump	MCC-E	MCC-M3E
R1	AC-M901	Instrument Air Compressor	MCC-E	MCC-M1
R2	AC-M902	Instrument Air Compressor	MCC-E	MCC-M3E
SHV-1	XV-M041	Suction Header Valve	MCC-E	MCC-M3E
SHV-2	XV-M042	Suction Header Valve	MCC-A	DP-M2
SHV-3	XV-M043	Suction Header Valve	MCC-E	MCC-M3E