



FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATED CURRENT (A)
TB04	0P	5x20mm	0.2
	1P	5x20mm	0.2
	2P	5x20mm	0.2
	3P	5x20mm	0.2
	4P	5x20mm	0.2
	5P	5x20mm	0.2
	6P	5x20mm	0.2
TB05	0P	5x20mm	0.2
	1P	5x20mm	0.2
	2P	5x20mm	0.2
	3P	5x20mm	0.2
	4P	5x20mm	0.2
	5P	5x20mm	0.2
	6P	5x20mm	0.2

G601-FT
WET WELL UPPER LEVEL
SUPPLY AIR FLOW
DRAWING: 1-0102G-A0114

G601-TT-1
OUTDOOR AIR
TEMPERATURE
DRAWING: 1-0102G-A0114

G603-TT-1
WET WELL INTERMEDIATE
AIR TEMPERATURE
DRAWING: 1-0102G-A0116

G603-TT-2
FLUSHING WATER
INLET TEMPERATURE
DRAWING: 1-0102G-A0116

G603-TT-3
FLUSHING WATER
DISCHARGE TEMPERATURE
DRAWING: 1-0102G-A0116

G605-TT
WET WELL UPPER LEVEL
SUPPLY TEMPERATURE
DRAWING: 1-0102G-A0117

SPARE

SPARE

G602-FT
WET WELL LOWER LEVEL
SUPPLY AIR FLOW
DRAWING: 1-0102G-A0115

G608-PDT
WET WELL
DIFFERENTIAL PRESSURE
DRAWING: 1-0102G-A0119

G687-IT
EXHAUST FAN
MOTOR CURRENT
DRAWING: 1-0102G-E0038

SPARE

SPARE

SPARE

SPARE

SPARE



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OPP. 545-2012	2012/08/31	TMC	CJR

		SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	
DESIGNED BY:	T. CHURCH	CHECKED BY:	C. REIMER
DRAWN BY:	S. COATES	APPROVED BY:	C. REIMER
SCALE:	NTS	RELEASED FOR CONSTRUCTION BY:	N. HARRINGTON
DATE:	2010/02/26	DATE:	2012/08/31
CONSULTANT NO.:	112577-0116-480D-0105		

ENGINEER'S SEAL

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE
VENTILATION & MISC. UPGRADES
WIRING DIAGRAM
LCP-G1 ANALOG INPUTS

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0102G-A0104	001	00	A1

DRAWING NUMBER	REFERENCE DRAWINGS