



573-2012 ADDENDUM 3

NORTH END WATER POLLUTION CONTROL CENTRE REHABILITATION OF DIGESTER NO. 11 AND SLUDGE HOLDING TANKS NO. 5 AND 7

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: November 23
BY: Jamie Brewster
TELEPHONE NO. (204) 489-5900

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Replace: Form I (R1) with the attached Form I (R2). The following is a summary of changes incorporated in the replacement form:

Form I (R2): Add new item to breakout the quantity of SHT No. 5 and 7 deep repair and shallow repair.

PART E – SPECIFICATIONS

Replace: Section 01 29 00 – Addendum 1 with Section 01 29 00 – Addendum 3

Revise: Section 02 41 13 Clause 1.1.1 to read: Requirements for demolition and upgrading of existing SHT No. 5 and 7 gas burner and demolition of Digester No. 11 gas sludge mixing equipment.

Add: Section 02 41 13 Clause 3.4 ASBESTOS REMOVAL

.1 Digester gas piping is known to contain asbestos containing material (ACM) in the pipe insulation, which will need to be removed as part of the work. The Contractor shall retain the services of a qualified asbestos abatement contractor to remove the insulation throughout the impacted areas. All abatement work must be completed in accordance to the Workplace Safety and Health Act (W210), Parts 36 and 37 of the Workplace Safety and Health Regulation (M.R. 217/2006) and Workplace Safety and Health Division, Guidelines for Working with Asbestos (March 2008).

.2 For air monitoring of the workplace, The Contractor shall retain the services of a qualified third party environmental consulting firm (Certified Industrial Hygienist or Registered Occupational Hygienist) during the abatement work to ensure that the asbestos fibres are contained within the enclosure during abatement.

Revise: Section 05 50 00 Clause 2.5.1 to read: Stainless steel access ladders shall be as detailed on the drawings.

DRAWINGS

Replace: 573-2012 _Drawing_1-0101D-S0002-001_R3 with 573-2012 _Addendum_3_Drawing_1-0101D-S0002-001_R4

573-2012 _Drawing_1-0101D-S0003-001_R3 with 573-2012 _Addendum_3_Drawing_1-0101D-S0003-001_R4

573-2012 _Drawing_1-0101D-M0004-001_R3 with 573-2012 _Addendum_3_Drawing_1-0101D-M0004-001_R4

573-2012 _Drawing_1-0101D-M0007-001_R3 with 573-2012 _Addendum_3_Drawing_1-0101D-M0007-001_R4

573-2012 _Drawing_1-0101D-M0010-001_R3 with 573-2012 _Addendum_3_Drawing_1-0101D-M0010-001_R4