



- NOTE:
- 1. NOZZLE ANGLES TO BE POSITIONED IN FIELD BY ROTARY MIX SUPPLIER
 - 2. CONTRACTOR TO CONFIRM LOCATION OF EXISTING PIPES PRIOR TO INSTALLATION OF NOZZLES. CONFIRM NOZZLE LOCATION WITH CONTRACT ADMINISTRATOR
 - 3. RUN NEW PIPING OVER EXISTING SLUDGE SUCTION PIPING.

THE MIXING SYSTEM IS BASED ON VAUGHAN'S "ROTAMIX" MIXING SYSTEM. REFER TO SHOP DRAWINGS PROVIDED IN APPENDIX B OF THE SPECIFICATIONS FOR FURTHER DETAILS.

FLOOR PLAN
1:100

APEGM
Certificate of Authorization
Stantec Consulting Ltd.
No. 1301

METRIC
WHOLE NUMBERS INDICATE MILLIMETRES
DECIMALIZED NUMBERS INDICATE METRES

B.M. ELEV.				 Stantec Consulting Ltd. 905 Waverley Street, Winnipeg, Manitoba Tel 204-489-5900 Fax 204-453-9012	ENGINEER'S SEAL	 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT NORTH END WATER POLLUTION CONTROL CENTRE REHABILITATION OF DIGESTER No. II AND SLUDGE HOLDING TANK No. 5 AND 7 DIGESTER No. II- MIXING SYSTEM PLAN ELEV. = 228.920 & 233.820
					DESIGNED BY: S.A.B./R.G. CHECKED BY: A.B./S.A.B. DRAWN BY: K.R. APPROVED BY: S.K.B.	
3. ISSUED FOR TENDER	12.11.01	S.K.B.		HOR. SCALE: 1:100 VERTICAL:	RELEASED FOR CONSTRUCTION:	BID OPPORTUNITY NO. 573-2012
2. ISSUED FOR 95% REVIEW	12.09.12	S.K.B.			DATE: 2011.01.12	
1. ISSUED FOR 60% REVIEW	12.07.27	S.K.B.				CITY DRAWING NUMBER
NO. REVISIONS						I-OI0ID-M0007-001
						SHEET OF
						13 OF 29

V:\1117\w\111712020_MSRPC_Digester_Visuals\02_design\sheet_01.dwg
 2012 October 31, 12:58 pm