

GENERAL SPECIFICATIONS

- THE CONTRACTOR SHALL EXAMINE THE SITE AND THE EXISTING CONDITIONS AFFECTING THE PROJECT. REVIEW THE COMPLETE SET OF CONTRACT DOCUMENTS TO ENSURE THE WORK CAN BE CARRIED OUT WITHOUT SIGNIFICANT CHANGES TO THE INTENT OF THE DOCUMENTS. NO FUTURE ALLOWANCE WILL BE MADE FOR CHANGES UNLESS THE CONTRACT ADMINISTRATOR HAS BEEN NOTIFIED IN ACCORDANCE WITH B6 OF ANY DISCREPANCIES OR INTERFERENCES, PRIOR TO THE CLOSE OF BID OPPORTUNITY. NO ALLOWANCE WILL BE MADE FOR ITEMS THAT SHOULD HAVE BEEN NOTED DURING THE SITE INVESTIGATION.
- THE LOCATION, ROUTING AND ELEVATIONS OF ALL NEW AND EXISTING SERVICES AND UTILITIES AS SHOWN ON THE DRAWINGS ARE TO BE CONSIDERED AS APPROXIMATIONS ONLY. VERIFY THE EXACT LOCATIONS, ROUTINGS AND ELEVATIONS OF ALL SERVICES PRIOR TO COMMENCING WORK, AND ASSUME RESPONSIBILITY FOR LAYING OUT ALL WORK. THE CONTRACTOR SHALL RETAIN RESPONSIBILITY FOR ANY DAMAGE TO EXISTING SERVICES AND UTILITIES.
- ALL ASPECTS OF THE INSTALLATION MUST COMPLY WITH THE MOST STRINGENT OF THE APPLICABLE BUILDING CODES, LOCAL REGULATIONS, AND BY-LAWS. BEFORE PROCEEDING WITH THE WORK, OBTAIN APPROVED DRAWINGS AND SPECIFICATIONS FROM THE AUTHORITIES HAVING JURISDICTION.
- PROVIDE ALL NECESSARY NOTICES, OBTAIN ALL REQUIRED PERMITS, PAY ALL FEES REQUIRED BY LAW, AND ARRANGE FOR ALL INSPECTIONS RELATED TO THE PERFORMANCE OF THE SPECIFIED WORK.
- PROVIDE A COMPLETE AND FUNCTIONING SYSTEM UTILIZING ALL MATERIALS, LABOUR AND EQUIPMENT REQUIRED TO COMPLETE THE WORK AS SHOWN AND AS SPECIFIED.
 - ALL EQUIPMENT AND MATERIALS SHALL BE NEW AND C.S.A. APPROVED, UNLESS SPECIFICALLY NOTED OTHERWISE.
 - ALL SIMILAR EQUIPMENT AND OR MATERIALS SHALL BE BY THE SAME MANUFACTURER.
- REQUEST FOR APPROVAL OF SUBSTITUTE MATERIAL AND/OR EQUIPMENT FOR THAT SPECIFIED, SHALL BE SUBMITTED IN ACCORDANCE WITH B6. REQUESTS SHALL INCLUDE ALL PERFORMANCE SPECIFICATIONS, PHYSICAL DATA AND OTHER PERTINENT INFORMATION REQUIRED FOR THE CONTRACT ADMINISTRATOR TO MAKE A COMPLETE COMPARISON.
 - THE REVIEW OF THE SHOP DRAWINGS IS FOR THE SOLE PURPOSE OF ASCERTAINING CONFORMANCE WITH THE GENERAL DESIGN CONCEPT. THE REVIEW SHALL NOT MEAN APPROVAL OF THE DETAILED DESIGN INHERENT IN THE EQUIPMENT, THE RESPONSIBILITY FOR WHICH SHALL REMAIN WITH THE CONTRACTOR. THE REVIEW SHALL NOT RELIEVE THE CONTRACTOR OF THE RESPONSIBILITY TO MEET THE REQUIREMENTS OF THE CONTRACT DOCUMENTS. THE CONTRACTOR SHALL REMAIN RESPONSIBLE FOR CONFIRMING AND CORRELATING THE DIMENSIONS ON THE JOBSITE, AND FOR INFORMATION THAT PERTAINS TO THE FABRICATION PROCESS, CONSTRUCTION TECHNIQUES, AND INSTALLATION DETAILS, AND FOR COORDINATING ALL WORK OF THE RELATED SUB-TRADES.
- ALL CUTTING AND PATCHING SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR. EXISTING EXPOSED SURFACES SHALL BE RETURNED TO AN "AS-FOUND" CONDITION ACCEPTABLE TO THE CONTRACT ADMINISTRATOR.
- EACH CONTRACTOR SHALL COORDINATE THE WORK WITH OTHER CONTRACTORS IN ORDER TO AVOID CONFLICTS.
- NEATLY STORE ALL MATERIALS, AND CLEAN UP REFUSE ON A REGULAR BASIS. PROTECT AND MAINTAIN ALL WORK UNTIL THE PROJECT HAS BEEN COMPLETED AND TURNED OVER TO THE CONTRACT ADMINISTRATOR.
- THE INSTALLATION SHALL BE COMPLETELY TESTED, DEMONSTRATING THE EQUIPMENT AND SYSTEMS INSTALLED ARE PERFORMING IN THE MANNER INTENDED.
- AT THE COMPLETION OF THE INSTALLATION, PROVIDE TWO MARKED-UP COPIES OF THE BID OPPORTUNITY AND AS-BUILT DRAWINGS FOR RECORD PURPOSES. PROVIDE THREE SETS OF OPERATION AND MAINTENANCE MANUALS. PAY ALL COSTS ASSOCIATED WITH THE PRODUCTION OF THE "RECORD" DRAWINGS AND THE MANUALS. SUBMIT THE DOCUMENTS TO THE CONTRACT ADMINISTRATOR FOR REVIEW, AND MAKE ANY REQUESTED CHANGES BEFORE DELIVERING THEM TO THE CITY.
 - REPLACE AT NO-CHARGE, ALL ITEMS WHICH FAIL OR PROVE DEFECTIVE WITHIN A PERIOD OF ONE YEAR AFTER THE DATE OF FINAL ACCEPTANCE BY THE CITY, PROVIDED THE FAILURE IS NOT DUE TO IMPROPER USAGE. MAKE GOOD ALL DAMAGES INCURRED AS A RESULT OF THE FAILURE AND OF THE REPAIRS.
- PROVIDE TEMPORARY HEATING AS REQUIRED. DO NOT USE NEW EQUIPMENT FOR THIS PURPOSE WITHOUT THE EXPRESS CONSENT OF THE CONTRACT ADMINISTRATOR.
- SCHEDULING OF ALL WORK SHALL BE ARRANGED WITH THE CITY. COORDINATE THE SHUT-DOWN OF EXISTING UTILITIES AND SERVICES AS REQUIRED FOR CONNECTIONS OF NEW WORK. WORK WITHIN THE BUILDING MAY HAVE TO BE PERFORMED DURING NON-REGULAR HOURS, AND MUST CONFORM TO THE WORK RULES OF THE BUILDING, AS DIRECTED BY THE CITY.
- THE DRAWINGS FOR THE MECHANICAL WORK ARE PERFORMANCE DRAWINGS, DIAGRAMATIC AND APPROXIMATELY TO SCALE, INTENDED TO CONVEY THE SCOPE OF WORK AND INDICATE THE GENERAL ARRANGEMENT AND APPROXIMATE LOCATIONS OF APPARATUS, FIXTURES AND PIPE/DUCT RUNS. THESE DRAWINGS DO NOT INTEND TO SHOW ARCHITECTURAL AND STRUCTURAL DETAILS.
- EVEN THOUGH SOME PIPING AND/OR DUCTWORK IS NOT COMPLETELY SHOWN SCHEMATICALLY, AND ALL DETAILS ARE NOT SHOWN OR SPECIFIED, IT IS EXPECTED THAT THE CONTRACTORS BE FAMILIAR ENOUGH WITH THEIR FIELDS OF WORK TO COMPLETE THE PROJECT TO THE STANDARDS GENERALLY ADHERED TO BY THE LOCAL INDUSTRY, INCLUDING GOOD WORKMANSHIP AND COMMON SENSE. THE CONTRACT ADMINISTRATOR RESERVES THE RIGHT TO FURNISH ANY ADDITIONAL DETAIL DRAWINGS, WHICH IN THE JUDGEMENT OF THE CONTRACT ADMINISTRATOR, MAY BE NECESSARY TO CLARIFY THE WORK, AND SUCH DRAWINGS SHALL FORM PART OF THIS CONTRACT. THE WORK FOR SUCH CLARIFICATIONS SHALL BE AT NO COST TO THE CITY.

MECHANICAL SPECIFICATIONS

SECTION 15100 - GENERAL

- PROVIDE ONE SET OF SPECIAL TOOLS REQUIRED TO SERVICE EQUIPMENT, AS RECOMMENDED BY THE MANUFACTURERS/SUPPLIERS.
- PROVIDE DIE-ELECTRIC COUPLINGS WHEREVER PIPES OF DISSIMILAR METALS ARE JOINED.
- HOISTING AND PLACING OF MECHANICAL EQUIPMENT SHALL BE THE RESPONSIBILITY OF THE SUB-CONTRACTOR PROVIDING THE EQUIPMENT.
- PIPE HANGERS SHALL BE GRINNELL FIGURE 65 FOR STEEL PIPE AND FIGURE CP65 FOR COPPER PIPE, WITH FIGURE 140 THREADED ROD. THREADED ROD SHALL BE ATTACHED TO FIGURE 117 EXPANSION CASE SET IN HOLES DRILLED IN CONCRETE, OR ATTACHED TO FIGURE 225 OR FIGURE 227 CLAMP ATTACHED TO ROOF/FLOOR JOISTS. FOR INSULATED PIPING, PROVIDE FIGURE 167 PROTECTION SADDLES. SIZE HANGERS AND SADDLES TO SUIT INDIVIDUAL PIPE SIZES, INCLUDING INSULATION WHERE APPLICABLE.
- USE THE FOLLOWING SCHEDULE FOR MINIMUM HANGING STANDARDS FOR HORIZONTAL PIPING:

STEEL PIPE		
SIZE	ROD DIAMETER	MAXIMUM SPACING
1-1/4" (32 mm) AND SMALLER	3/8" (10mm)	3'-0" (900mm)
1-1/2" (38 mm) AND 2" (50 mm)	3/8" (10mm)	10'-0" (3000mm)
2-1/2" (65 mm) AND 3" (75 mm)	1/2" (12mm)	12'-0" (3600mm)
4" (100 mm) AND 5" (125 mm)	5/8" (16mm)	12'-0" (3600mm)
6" (150 mm)	3/4" (19mm)	12'-0" (3600mm)

COPPER PIPE		
SIZE	ROD DIAMETER	MAXIMUM SPACING
1" (25 mm) AND SMALLER	3/8" (10mm)	6'-0" (1800mm)
1.25" TO 2" (32 mm TO 50 mm)	3/8" (10mm)	10'-0" (3000mm)

- PIPE HANGERS MAY BE PERFORATED GALVANIZED STEEL STRAP HANGERS FOR 2" (50mm) AND SMALLER PIPING IN CONCEALED SPACES.
- PROVIDE ACCESS DOORS AS REQUIRED TO INSTALL, MAINTAIN AND ADJUST EQUIPMENT AND CONTROLS. ACCESS DOORS IN CEILINGS AND WALLS SHALL HAVE PIANO HINGES AND SCREWDRIVER CAM LOCKS.
 - PROVIDE FIRE STOPPING AND/OR INTUMESCENT DONUTS, AS REQUIRED, WHERE PIPING PASSES THROUGH FIRE SEPARATIONS.

SECTION 15180 - INSULATION

- PROVIDE 1/2" (12mm) THICK, FOIL-FACED RIGID PRE-FORMED FIBREGLASS EXTERNAL THERMAL PIPE INSULATION ON ALL NEW DOMESTIC COLD WATER PIPES.
- PROVIDE 1/2" (12mm) THICK, RIGID, PRE-FORMED FIBREGLASS EXTERNAL THERMAL PIPE INSULATION ON ALL NEW DOMESTIC HOT WATER PIPES.
- PROVIDE 1/2" (12mm) THICK, FOIL-FACED RIGID PRE-FORMED FIBREGLASS EXTERNAL THERMAL PIPE INSULATION ON ALL NEW PLUMBING VENTS FOR 10" (3000mm) ON WARM SIDE OF A PENETRATION THROUGH A WALL OR CEILING/ROOF TO A COLD SPACE, AND FOR FULL LENGTH IN COLD ATTIC SPACES.
- PROVIDE 1" (25mm) THICK, FOIL-FACED RIGID (FIBREGLASS OR FIBREBOARD) OR FLEXIBLE FIBREGLASS EXTERNAL THERMAL INSULATION ON ALL NEW EXHAUST OR RELIEF DUCTWORK FOR 10'-0" (3.0M) ON THE WARM SIDE OF A PENETRATION THROUGH A WALL/FLOOR/CEILING/ROOF TO A COLD SPACE, WHERE A BACKDRAFT DAMPER IS PROVIDED AT THE PENETRATION TO THE COLD SPACE. WHERE THE BACKDRAFT DAMPER IS PROVIDED IN THE DUCTWORK, INSULATION SHALL EXTEND FROM THE PENETRATION TO 10'-0" (3.0M) UPSTREAM OF THE BACK DRAFT DAMPER
- PROVIDE MINIMUM R5 CONTINUOUS, INTERNAL DUCT LINER, DUAL DENSITY FIBERGLASS INSULATION FOR ALL EXPOSED (RTU-1) HVAC SUPPLY & RETURN DUCTWORK. FIBERGLASS INSULATION SHALL COMPLY WITH THE FOLLOWING STANDARDS:
 - UL 181 (AIR EROSION)
 - UL 723 (25 / 50) (FLAME & SMOKE)
 - ASTM E84 (25 / 50) (FLAME & SMOKE)
 - ASTM C1071 (PHYSICAL PROPERTIES)
 - UL 181 (MOLD GROWTH & HUMIDITY)
- ALL JOINTS AND ELBOWS SHALL BE COMPLETELY INSULATED EXCEPT JOINTS AND ELBOWS MAY BE LEFT UNCOVERED ON HOT PIPING IN CONCEALED SPACES.
- ALL VALVES AND UNIONS SHALL BE COMPLETELY INSULATED, EXCEPT VALVES AND UNIONS MAY BE LEFT UNCOVERED ON HOT PIPING IN CONCEALED SPACES.
- SEAMS OF FOIL-FACED THERMAL INSULATION SHALL BE SEALED WITH ALUMINUM DUCT TAPE.
- PROVIDE ADDITIONAL LAYER OF CANVAS, FIELD APPLIED, ADHERED, LAP SEALED AND FINISHED WITH A BRUSH COAT OF SIZING.
- PROVIDE PVC FITTING COVERS WHERE CANVAS JACKET IS APPLIED.
- COVER BUTT JOINTS WITH A STRIP OF THE SAME MATERIAL AS THE JACKET.
- FLEXIBLE INSULATION SHALL BE INSTALLED IN A MANNER THAT DOES NOT REDUCE ITS THICKNESS.

SECTION 15400 - PLUMBING

- DOMESTIC WATER PIPING ABOVE GROUND SHALL BE TYPE 'L' HARD COPPER, WITH SOLDERED COPPER JOINTS AND FITTINGS. USE LEAD-FREE SOLDER.
- DRAIN AND VENT PIPING ABOVE GROUND SHALL BE AS ALLOWED BY CODE, INCLUDING DWV COPPER, CAST IRON, AND PVC/ABS PLASTIC. JOINTS SHALL BE SOLDERED FOR COPPER, SOLVENT WELDED FOR PLASTIC, AND MECHANICAL JOINT FOR CAST IRON.
- DRAIN AND VENT PIPING BELOW GROUND SHALL BE AS ALLOWED BY CODE, INCLUDING CAST IRON, AND PVC/ABS PLASTIC. JOINTS SHALL BE SOLVENT WELDED FOR PLASTIC, AND MECHANICAL JOINT FOR CAST IRON.
- NATURAL GAS PIPING SHALL BE SCHEDULE 40 STEEL, WITH SCREWED OR WELDED JOINTS AND FITTINGS AS PER CODE.
- DOMESTIC WATER VALVES SHALL BE BALL TYPE.
- NATURAL GAS VALVES SHALL BE APPROVED PLUG TYPE.
- PROVIDE CHROME PLATED ESCUTCHEONS WHERE VISIBLE RADIANT HEAT & DOMESTIC HOT & COLD PIPING PASSES THROUGH FLOORS, WALLS AND PARTITIONS.
- PROVIDE UNIONS WHERE PIPING CONNECTS TO EQUIPMENT. UNIONS SHALL BE LOCATED SO THAT THE PIPING DOES NOT HAVE TO BE ADJUSTED IN ORDER TO REMOVE THE EQUIPMENT.
- DURING CONSTRUCTION, OPEN ENDED PIPING SHALL BE TEMPORARILY CAPPED TO PREVENT THE ENTRY OF DIRT AND DEBRIS. ON COMPLETION, PIPING SYSTEMS SHALL BE FLUSHED TO REMOVE ANY FOREIGN MATERIAL.
- SLOPE ALL DRAIN LINES AT A MINIMUM OF 1/8" PER FOOT (1%) UNLESS A GREATER SLOPE IS REQUIRED BY CODE, OR A LESSER SLOPE IS NOTED ON THE DRAWINGS.

SECTION 15800 - VENTILATION

- ALL DUCTWORK AND RELATED ACCESSORIES SHALL BE SUPPLIED & INSTALLED AS PER THE LATEST SMACNA STANDARDS.
- DUCTWORK SHALL BE GALVANIZED SHEET METAL UNLESS NOTED OTHERWISE, AND SHALL BE OF THE FOLLOWING GAUGES:
 - RECTANGULAR
 - DUCTS UP TO 12" (300 MM) ON LONGEST DIMENSION = 26 GA.
 - DUCTS 13" TO 28" (325 TO 700 MM) ON LONGEST DIMENSION = 24 GA.
 - DUCTS 29" TO 48" (725 TO 1200 MM) ON LONGEST DIMENSION = 22 GA.
 - DUCTS 49" TO 96" (1225 TO 2400 MM) ON LONGEST DIMENSION = 20 GA.
 - ROUND
 - DUCTS 8" (200 MM) AND SMALLER = 26 GA.
 - DUCTS 9" TO 22" (225 TO 550 MM) = 24 GA.
 - DUCTS 24" TO 36" (600 TO 900 MM) = 22 GA.
- ALL DUCTWORK SHALL BE SEALED WITH DUCT SEALANT.
- PROVIDE DUCT ACCESS DOORS AT ALL LOCATIONS REQUIRED FOR INSTALLATION, MAINTENANCE OR ADJUSTMENT OF EQUIPMENT OR CONTROLS. ACCESS DOORS SHALL HAVE GASKETS, PIANO HINGES AND THUMB LATCHES. DOORS SHALL BE INSTALLED TO ALLOW FOR INSTALLATION OF INTERNAL OR EXTERNAL INSTALLATION AS REQUIRED.
- SUPPORT HORIZONTAL DUCTWORK AT MAXIMUM 8'-0" (2400mm) ON CENTER
 - FOR ROUND DUCTWORK UP TO 36" (900mm) DIAMETER, SUPPORT DUCT USING PERFORATED GALVANIZED STEEL STRAP, SUSPENDED USING THREADED RODS ATTACHED TO THE STRUCTURE. USE 3/8" (10mm) RODS FOR DUCTS 12" (300mm) DIAMETER AND LESS. USE 1/2" (12mm) RODS FOR DUCTS 14" TO 22" (350mm TO 550mm) DIAMETER. USE 5/8" (16mm) RODS FOR DUCTS OVER 24" (600mm) DIAMETER.
 - FOR ROUND DUCTWORK OVER 36" (900mm) DIAMETER, SUPPORT DUCT USING 1" x 1" x 1/8" (25mm x 25mm x 3mm) GALVANIZED ANGLE IRON TRAPEZE, SUSPENDED BY 5/8" (16mm) DIAMETER THREADED RODS ATTACHED TO THE STRUCTURE.
 - FOR RECTANGULAR DUCTWORK 18" (450mm) WIDE OR LESS, SUPPORT DUCT WITH PERFORATED GALVANIZED STEEL STRAP, SUSPENDED USING 1/2" (12mm) THREADED RODS ATTACHED TO THE STRUCTURE.
 - FOR RECTANGULAR DUCTWORK OVER 18" (450mm) WIDE, SUPPORT DUCT WITH 1" x 1" x 1/8" (25mm x 25mm x 3mm) GALVANIZED ANGLE IRON TRAPEZE, SUSPENDED BY 5/8" (16mm) DIAMETER THREADED RODS ATTACHED TO THE STRUCTURE.
 - IN CONCEALED SPACES FOR ROUND AND RECTANGULAR DUCTWORK 12" (300mm) WIDE OR LESS, PERFORATED GALVANIZED STEEL STRAP MAY BE USED IN LIEU OF THREADED ROD SUSPENSION.

SECTION 15950 - TESTING, ADJUSTING AND BALANCING (TAB):

- A. SCOPE**
- TAB MEANS TO TEST, ADJUST AND BALANCE, TO PERFORM IN ACCORDANCE WITH REQUIREMENTS OF THE CONTRACT DOCUMENTS AND TO DO ALL OTHER WORK AS SPECIFIED IN THIS SECTION.
 - TEST TO VERIFY PROPER AND SAFE OPERATION, DETERMINE ACTUAL POINT OF PERFORMANCE, EVALUATE QUALITATIVE AND QUANTITATIVE PERFORMANCE OF EQUIPMENT, SYSTEMS AND CONTROLS AT DESIGN, AVERAGE AND LOW LOADS USING ACTUAL OR SIMULATED LOADS.
 - ADJUST AND REGULATE EQUIPMENT AND SYSTEMS SO AS TO MEET SPECIFIC PERFORMANCE REQUIREMENTS AND TO ACHIEVE SPECIFIC INTERACTION WITH ALL OTHER RELATED SYSTEMS UNDER ALL NORMAL AND EMERGENCY LOADS AND OPERATING CONDITIONS.
 - BALANCE SYSTEMS AND EQUIPMENT AND REGULATE FLOW RATES TO MATCH LOAD REQUIREMENTS OVER FULL OPERATING RANGE.
- B. EQUIPMENT STARTUP**
- FOLLOW STARTUP PROCEDURES AS RECOMMENDED BY EQUIPMENT MANUFACTURER UNLESS SPECIFIC OTHERWISE.
- C. START OF TAB**
- START TAB ONLY WHEN CONSTRUCTION IS ESSENTIALLY COMPLETE
 - STARTUP VERIFICATION FOR PROPER, NORMAL AND SAFE OPERATION OF ALL MECHANICAL AND ASSOCIATED ELECTRICAL CONTROL SYSTEMS AFFECTING TAB INCLUDING BUT NOT LIMITED TO
 - PROPER THERMAL OVERLOAD PROTECTION IN PLACE FOR ELECTRICAL EQUIPMENT
 - AIR SYSTEMS
 - FILTERS IN PLACE, CLEAN
 - DUCT SYSTEM CLEAN
 - DUCTS, AIR SHAFTS, CEILING PLENUMS ARE AIRTIGHT TO WITHIN SPECIFIC TOLERANCES.
 - CORRECT FAN ROTATION
 - FIRE, SMOKE, VOLUME CONTROL DAMPERS INSTALLED AND OPEN
 - COIL FINS COMBED, CLEAN
 - ACCESS DOORS, INSTALLED, CLOSED
 - ALL OUTLETS INSTALLED, VOLUME CONTROL DAMPERS OPEN
 - DO TAB TO PLUS 5%, MINUS 5% OF DESIGN VALUES
 - ACCURACY TOLERANCES: MEASURED VALUES TO BE ACCURATE TO WITHIN PLUS OR MINUS 2% OF ACTUAL VALUES.
- D. INSTRUMENTS:**
- CALIBRATE IN ACCORDANCE WITH REQUIREMENTS OF MOST STRINGENT OF REFERENCED STANDARDS FOR HVAC SYSTEM
- E. TAB REPORT:**
- FORMAT TO BE IN ACCORDANCE WITH REFERENCED STANDARD
 - TAB REPORT TO SHOW ALL RESULTS IN IMPERIAL UNITS AND TO INCLUDE: 1. PROJECT RECORD DRAWINGS 2. SYSTEM SCHEMATICS
 - SUBMIT 6 COPIES OF TAB REPORT TO CONTRACT ADMINISTRATOR FOR VERIFICATION AND APPROVAL APPROVAL IN ENGLISH, COMPLETE WITH INDEX TABS.
- F. VERIFICATION:**
- ALL REPORTED RESULTS SUBJECT TO VERIFICATION BY CONTRACT ADMINISTRATOR.
 - PROVIDE MANPOWER AND INSTRUMENTATION TO VERIFY UP TO 30% OF ALL REPORTED RESULTS.
 - NUMBER AND LOCATION OF VERIFIED RESULTS TO BE AT DISCRETION OF CONTRACT ADMINISTRATOR.
 - BEAR COSTS TO REPEAT TAB AS REQUIRED TO SATISFACTION OF CONTRACT ADMINISTRATOR.
- G. SETTINGS:**
- AFTER TAB IS COMPLETED TO SATISFACTION OF CONTRACT ADMINISTRATOR, REPLACE DRIVE GUARDS, CLOSE ALL ACCESS DOORS, LOCK ALL DEVICES IN SET POSITIONS, ENSURE SENSORS ARE AT REQUIRED SETTINGS.
 - PERMANENTLY MARK ALL SETTINGS TO ALLOW RESTORATION AT ANY TIME DURING LIFE OF FACILITY, MARKINGS NOT TO BE ERADICATED OR COVERED IN ANY WAY.


SECTION 15950 - TESTING, ADJUSTING AND BALANCING (TAB): CONT.

- H. AIR SYSTEMS:**
- STANDARD: TAB TO BE TO MOST STRINGENT OF THIS SECTION OR TAB STANDARDS OF AABC NEBB SMACNA ASHRAE.
 - DO TAB OF ALL SYSTEMS, EQUIPMENT, COMPONENTS, CONTROLS SPECIFIED IN THE MECHANICAL DRAWINGS.
 - QUALIFICATIONS: PERSONNEL PERFORMING TAB TO BE CURRENT MEMBER IN GOOD STANDING OF AABC OR NEBB QUALIFIED TO STANDARDS OF AABC OR NEBB.
 - QUALITY ASSURANCE: PERFORM TAB UNDER DIRECTION OF SUPERVISOR QUALIFIED BY TO STANDARDS OF AABC OR NEBB.
 - MEASUREMENTS: TO INCLUDE, BUT NOT LIMITED TO, FOLLOWING AS APPROPRIATE FOR SYSTEMS, EQUIPMENT, COMPONENTS, CONTROLS: AIR VELOCITY, STATIC PRESSURE, FLOW RATE, PRESSURE DROP (OR LOSS), TEMPERATURES (DRY BULB, WET BULB, DEWPOINT), DUCT CROSS SECTIONAL AREA, RPM, ELECTRICAL POWER, VOLTAGE, NOISE, VIBRATION.
 - LOCATIONS OF EQUIPMENT MEASUREMENTS: TO INCLUDE, BUT NOT BE LIMITED TO, FOLLOWING AS APPROPRIATE:
 - INLET AND OUTLET OF EACH DAMPER, FILTER, COIL, HUMIDIFIER, FAN, OTHER EQUIPMENT CAUSING CHANGES IN CONDITIONS.
 - AT EACH CONTROLLER, CONTROLLED DEVICE
 - LOCATIONS OF SYSTEMS MEASUREMENTS TO INCLUDE, BUT NOT LIMITED TO, FOLLOWING AS APPROPRIATE: EACH MAIN DUCT, MAIN BRANCH, SUB-BRANCH, RUN-OUT (OR GRILLE, REGISTER OR DIFFUSER)

NOTES:

No.	REVISION/DESCRIPTION	BY	DATE
SEAL			

DRAWN	RCP	CHECKED	DTA	DESIGNED	DTA	APPROVED
DATE	2012.08.17	USER	APPROVAL			

 THE CITY OF WINNIPEG
PLANNING, PROPERTY AND
DEVELOPMENT DEPARTMENT
MUNICIPAL ACCOMMODATIONS DIVISION
3-65 GARRY STREET, R3C 4K4

PROJECT
FORT GARRY LIBRARY
INTERIOR & EXTERIOR REFURBISHING

1360 PEMBINA HWY
SHEET TITLE

SPECIFICATIONS
MECHANICAL & PLUMBING

SCALE	PROJECT No:	SHEET No:
AS SHOWN	2011-096	M6