



SCREENING CONVEYOR LOOP G260-CON

**CONSTRUCTION NOTES**

1 RECONFIGURE CONTROL OF G260-CON AS SHOWN ON DRAWING 1-0102G-E0035.

- 1 YS,COMP/OFF/HAND SWITCH INPUT TO DCS
- 2 HS1,LOCK/OFF/STOP PUSHBUTTON
- 3
- 4 HS2,COM/OFF/HAND SELECTOR SWITCH
- 5 MN,START/STOP SIGNAL FROM DCS
- 6
- 7 XA,WARNING HORN PRIOR TO START
- 8 R1,CONVEYOR START RELAY
- 9 XJ,WARNING LIGHT PRIOR TO START
- 10 KY1,CONVEYOR START TIME DELAY RELAY
- 11 KY2,TIME DELAY WARNING RELAY
- 12 ZS1/ZS2,LIMIT SWITCHES
- 13 R3,CONVEYOR FAIL RELAY
- 14 ES1/ES2, EMERGENCY STOP SWITCH VIA PULL CORD
- 15 QF,COMMON FAIL TO DCS
- 16 MM,RUN SIGNAL TO DCS
- 17



**MacLAREN ENGINEERS INC.  
WARDROP ENGINEERING INC.  
ENGINEERING CONSULTANTS**

ORIGINAL DRAWING SEALED BY:  
T. M. CHURCH  
SNC-LAVALIN MEMBER # 32682  
2012/02/27  
REV. 07  
CHANGES ONLY

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT

SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, Manitoba Canada R3P 0X7				
DESIGNED: T. CHURCH	APPROVED: C. REIMER			
CHECKED: C. REIMER	DATE: 2012/02/27			
PROJECT No.	SUBDIV.	SUBJECT	SERIAL	REV.
112577	0113	47 DD	2219	7

7	REPLACED CONTROL WIRING	2012/02/24	T.M.C.	DESIGNED BY: R.H.
6	REVISED	06/04	M.K.	DRAWN BY: R.H.
5	RECORD DRAWING	05/96	B.T.	SCALE: N.T.S.
4	ISSUED FOR CONSTRUCTION	11/95	B.T.	
3	ISSUED FOR CONTRACTOR REVIEW	10/95	B.T.	
	NO REVISIONS	DATE	BY	DATE: 06/92

SOUTH END WATER POLLUTION CONTROL CENTER		CITY DWG. NO.
PUMP & SCREEN BUILDING - I & C		
GRIT REMOVAL SYSTEM		
SCREENING CONVEYOR		
LOOP G260		
		SHEET 1 OF 1
		SEP-2070