



822-2012 ADDENDUM 4

REHABILITATION OF MILLENIUM LIBRARY PARKADE 251 DONALD STREET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: December 5, 2012
BY: Iain Currie
TELEPHONE NO. (204) 986-3874

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20120228

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 7 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 822-2012Bid Submission with 822-2012Addendum 4 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R2): Revise Item 20 to carry cash allowance of \$95,000.

Page numbering on some forms may be changed as a result.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, December 11, 2012.

PART E – SPECIFICATIONS

Revise: Section 01 11 00 clause 1.3.10 to read:

- .10 Upgrade mechanical and electrical systems as indicated on the drawings. This includes:
 - .1 Install fire detection sensors
 - .2 Hydronic boiler combustion air venting
 - .3 NOx detection system

Add: Section 01 11 00 clause 1.3.11.13

- .13 Replace pneumatic controls with digital controls as directed by the contract administrator.

Revise: Section 22 83 16 clause 2.4 to read:

- .1 Supply and install new manifolds as per manufacturer's recommendations.

Add: Section 31 23 33 clause 3.4.17

- .17 P2 Level Grading:
 - .1 Refer to drawing S11 for existing slab elevations.
 - .2 Excavate existing granular fill to accommodate slab elevations indicated on drawing S4.
 - .3 Place existing granular fill along gridlines 2 and 11 to accommodate localized areas of slab settlement. Compact existing granular fill to 98% standard proctor dry density.

DRAWINGS

Add: 822-2012_Addendum_4-Drawing_S11-R4