



VENTILATION ROOM & SECONDARY ELECTRICAL ROOM,
SEE DRAWING 1-0102S-M0001-001

GRIT BUILDING MECHANICAL ROOM ABOVE,
SEE DRAWING 1-0102G-M0007-001

SERVICE BUILDING MECHANICAL ROOM
ABOVE, SEE DRAWING
1-0102B-M0001-001

WORKSHOP, SEE DRAWING
1-0102B-M0002-001

BOILER ROOM BELOW,
SEE DRAWING 1-0102B-M0003-001

MAIN LEVEL

GENERAL NOTES:

1. CONTRACTOR SHALL SUPPLY AND INSTALL FIRE DAMPERS IN LOCATIONS SHOWN ON DRAWINGS WHERE DUCTING PENETRATES A FIRE SEPERATION.
2. FIRE DAMPERS SHALL BE INSTALLED IN ACCORDANCE WITH SMACNA STANDARDS, NATIONAL FIRE CODE AND THE NATIONAL BUILDING CODE.
3. REINSULATE ALL DUCTWORK ONCE ASBESTOS ABATEMENT WORK IS COMPLETE.
4. ACCESS DOORS SHALL BE PROVIDED FOR ALL FIRE DAMPERS IN ACCORDANCE WITH SMACNA AND THE NATIONAL FIRE CODE.



NO.	REVISIONS	DATE	DESIGN	CHECK
01	ASBESTOS ABATEMENT REMOVED, BID OPP 42-2013	2013/03/25	TRS	SN
00	ISSUED FOR TENDER, BID OPP. 545-2012	2012/09/10	TRS	SN

		SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-798-8080	
DESIGNED BY:	S. NORSWORTHY	CHECKED BY:	S. NORSWORTHY
DRAWN BY:	S. COATES	APPROVED BY:	C. REIMER
SCALE:	N.T.S.	RELEASED FOR CONSTRUCTION BY:	NEIL HARRINGTON
DATE:	2012/01/20	DATE:	2012/10/10
CONSULTANT NO.: 112577-0116-45DD-0001			

ENGINEER'S SEAL

ORIGINAL DRAWING
SEALED BY:
S. S. NORSWORTHY
SNC-LAVALIN
MEMBER #20725
2012/10/29
REV. 00

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 SOUTH END WATER POLLUTION CONTROL CENTRE
 VENTILATION & MISC. UPGRADES
 PLAN VIEW
 FIRE DAMPER UPGRADES
 KEY PLAN
 CITY DRAWING NUMBER: **1-0102A-M0008**

SHEET	REV.	SIZE
001	01	A1