



FROM ELECTRICAL ROOM  
 G116 ABOVE RAW SEWAGE  
 PUMP VFDS  
 AIR

G692-EF  
 1.1 kW  
 575V, 3Ø  
 2329 RPM  
 630 L/s

G11  
 G692  
 TT  
 AI  
 0-50°C  
 NEAR  
 ELECTRICAL  
 ROOM VFDS

**NOTES:**

1. THIS DRAWING SUPERSEDES PART OF DRAWING SEP-868.
2. ALL INSTRUMENTS SHOWN IN AN AUXILIARY LOCATION ARE LOCATED IN HVAC CONTROL PANEL GCP-7 UNLESS OTHERWISE DESIGNATED.



NO.	REVISIONS	DATE	DESIGN	CHECK
01	ISSUED FOR TENDER, BID OPP. 42-2013	2013/01/15	TMC	CJR
00	ISSUED FOR TENDER, BID OPP. 545-2012	2012/10/11	TMC	CJR

 SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	
DESIGNED BY: T. CHURCH	CHECKED BY: C. REIMER
DRAWN BY: M.J. PERSSON	APPROVED BY: C. REIMER
SCALE: NTS	RELEASED FOR CONSTRUCTION BY: N. HARRINGTON DATE: 2012/10/11
DATE: 2012/01/24	CONSULTANT NO.: 112577-0116-49DD-0133

ENGINEER'S SEAL

**THE CITY OF WINNIPEG**  
 WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE  
 VENTILATION & MISC. UPGRADES  
 PROCESS & INSTRUMENTATION DIAGRAM  
 ELECTRICAL ROOM EXHAUST FAN  
 G692-EF

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0102G-A0096	001	01	A1

1-0102G-A0026	P & ID, G682-AHU
1-0102A-A0001	PROCESS & INSTRUMENT DIAGRAMS LEGEND & DETAILS
DRAWING NUMBER	REFERENCE DRAWINGS