



PANEL SCHEDULE									
PANEL #	A		PANEL TYPE		24CCT PANELBOARD				
MOUNTING	SURFACE MOUNTED		VOLTAGE		120/240V				
TOTAL LOAD	8.5KW ESTIMATED DEMAND		PHASE:		1 Ø				
FED FROM	OVERHEAD SERVICE		MAIN BREAKER		2P100				
FEEDER	3#2/0 RW90(CU)-2"C + #3(CU) GND								
NOTES									
WATTS	DESCRIPTION	No	C/B	C/B	No	DESCRIPTION	WATTS		
4.0KW	FCP-1	1	2P	20	2	HOT WATER TANK	1.5KW		
4.0KW		3	50	20	4	SPARE			
100W	LIGHTS EXTERIOR	5	15	15	6	OWNER SUPPLIED SECURITY	800W		
300W	INTERIOR LIGHTS/EX. FANS	7	15	20	8	HAND DRYER	1.5KW		
1KW	HEAT TRACE(INCOMING H2O)	9	15	15	10	AUTO SENCOR(TAPS)	100W		
		11	15	15	12	CONV. RECEPTACLE	300W		
		13			14				
		15			16				
		17			18				
		19			20				
		21			22				
		23			12				



REV	DATE	DESCRIPTION	BY	CHK	APP
Ø	JUNE 20/13	ISSUED FOR PERMIT & CONSTRUCTION	PY	RK	



MEG-A-RON ENGINEERING SERVICES
 22 MITCHELL BAY
 ST. ANDREWS, MANITOBA
 R1A 3A3



DRAWN BY:	PY	DATE:	APRIL 10/13
CHECKED BY:	--	DATE:	
APPROVED BY:		DATE:	

CLIENT:	VICTOR SUEN ARCHITECT 23 STORMANT DRIVE WINNIPEG, MANITOBA
PROJECT:	WINNIPEG TRANSIT COMFORT STATION WINNIPEG, MANITOBA

REFERENCE DRAWINGS	
DRAWING TITLE:	PANEL SCHEDULE & SINGLE LINE
DRAWING NO:	E-02
REVISION	Ø

SUMITECH SERVICES LIMITED
 TECHNICAL PROJECT MANAGERS
 168 Argente Street
 R2H 0A6
 Tel: 204 255 0940
 Fax: 204 255 0941
 Email: sumitech@shaw.ca