
## NOTES:

- PROVIDE RELAY CONNECTED TO LIGHT SWITCH CONTROL TO ACTIVATE SF-1 AND EF-1 "OCCUPIED" MODE.
- MOUNT DISCONNECT SWITCH AT 2000mm ABOVE FINISHED FLOOR.
- 3. ALL HVAC CONTROL WIRING BY ELECTRICAL.
- HVAC HIGH SPEED PUSHBUTTON AND DIGITAL TIMER BY ELECTRICAL.



## HOUSEHOLD HAZARDOUS WASTE BUILDING - POWER PLAN 1:50

MOTOR SCHEDULE																	
	MOTOR	STARTER					POWER						DETAIL DWG.	REMARKS			
EQUIP. NUM.	DESCRIPTION	EQUIP. LOAD		TYPE	MAN	MAG	S/S PL		OVERCURRENT DEVICE	LOC.	PANEL	CCT.	FEEDER	CAP. SIZE	DISC. TYPE	WIRE	
SF-1	SUPPLY FAN	0.75 HP	600/3	VFD			Х	Х	15A, 3P		LP-D	25/27/29	#12 VFD DRIVE CABLE		NON-FUSED		PROGRAM AND WIRE C/W DEVICES AS PER MECHANICAL REQUIREMENTS.
EF-1	EXHAUST FAN	0.75 HP	600/3	VFD			X	Х	15A, 3P		LP-D	31/33/35	#12 VFD DRIVE CABLE		NON-FUSED		PROGRAM AND WIRE C/W DEVICES AS PER MECHANICAL REQUIREMENTS.
DH-1	DUCT HEATER	15 KW	600/3						25A, 3P		LP-D	8/10/12	#10-3C		NON-FUSED		SCR CONTROL BY MECHANICAL. CONTROL WIRING BY ELECTRICAL.
UH-1	UNIT HEATER	5 KW	600/3						15A, 3P		LP-D	1/3/5	#10-3C		NON-FUSED		LINE VOLTAGE THERMOSTAT CONTROL BY ELECTRICAL.
UH-2	SUPPLY FAN	5 KW	600/3						15A, 3P		LP-D	7/9/11	#10-3C		NON-FUSED		LINE VOLTAGE THERMOSTAT CONTROL BY ELECTRICAL.
UH-3	SUPPLY FAN	5 KW	600/3						15A, 3P		LP-D	13/15/17	#10-3C		NON-FUSED		LINE VOLTAGE THERMOSTAT CONTROL BY ELECTRICAL.
UH-4	SUPPLY FAN	5 KW	600/3						15A, 3P		LP-D	19/21/23	#10-3C		NON-FUSED		LINE VOLTAGE THERMOSTAT CONTROL BY ELECTRICAL.
MD	MOTORIZED DAMPER (2)	FRAC.	120/1						15A, 1P		LP-E	11	#14-2C				CONTROL WIRING BY ELECTRICAL AS PER MECHANICAL REQUIREMENTS.

**APEGIN** Certificate of Authorization Dillon Consulting Limited (MB) No. 1789 Date: <u>2014/07/08</u>

**METRIC** 

WHOLE NUMBERS INDICATE MILLIMETRES DECIMALIZED NUMBERS INDICATE METRES

B.I EL				DESIGNED BY JAD	'I.	ENGINEER'S SEAL	THE CITY OF W	OF WINNIPEG		
				DRAWN BY MS	"I'I II II III III III III III III III I	ORIGINAL STAMPED BY B. L.	Winnipeg WATER AND WASTE DEPARTMENT			
				CHECKED BY BM	DILLON	MOORE 2014/07/08	4R WINNIPEG DEPOT BRADY ROAD RESOURCE	CITY DRAWING NUMBER		
				APPROVED BY ARR	CONSULTING	PROFESSION	MANAGEMENT FACILITY	SHEET OF 11		
				HOR. SCALE 1:50	RELEASED FOR CONSTRUCTION	CONSULTANT PROJECT NUMBER		CONSULTANT DRAWING NUMBER		
1	ISSUED FOR ADDENDUM #1	14/07/08	ARR	VERTICAL			HHW EWASTE BUILDING POWER PLAN	E11 (AD-1)		
NO.	REVISIONS	DATE	BY	DATE JULY 2014	DATE	13-8224				