



**PARTIAL FLOOR PLAN**  
1:50



**TRANSIT GARAGE FLOOR PLAN**  
1:400

**NOTES**

1. PROVIDE 120V 1Ø POWER FROM NEW TANDEM (DUPLX) 15A CIRCUIT BREAKER IN PANEL LP-RM.
2. EXISTING 40 HP AIR COMPRESSOR ELECTRICAL POWER TO BE DISCONNECT AND REMOVED, ASSOCIATED DISCONNECT SWITCH AND DEVICES TO BE DISCONNECTED AND REMOVE. CABLING FROM MAIN DISTRIBUTION PANEL #1B TO EXISTING 40 HP COMPRESSOR LOCATION TO BE REMOVED FROM CABLE TRAY AND TURNED OVER TO OWNER.
3. PROVIDE AND INSTALL NEW 3Ø AMP 3 POLE 600 VOLT 14KA CIRCUIT BREAKER IN PANEL PP-WW FOR NEW AIR COMPRESSOR AC-01. PROVIDE AND INSTALL NEW 15 AMP 3 POLE 600 VOLT 14KA CIRCUIT BREAKER IN PANEL PP-WW FOR NEW DRYER D-1.
4. PROVIDE AND INSTALL NEW 15 AMP TANDEM (DUPLX) 240 VOLT RATED CIRCUIT BREAKERS IN PANEL LP-RM-B FOR DRYER D-2 AND AC-01 DRAIN VALVE.
5. COORDINATE CABLE SUPPORT STRUCTURES WITH MECHANICAL EQUIPMENT AND PIPING TRADES.



**KEY PLAN**  
NTS

C:\CAD\148749 CITY OF WINNIPEG TRANSIT\04-ELECTRICAL\148749-07-ELEC-DES.DWG



| LOCATION UNDERGROUND           | APPROVED STRUCTURES | B.M. ELEV. | DESIGNED BY      |
|--------------------------------|---------------------|------------|------------------|
| SUPV. U/G STRUCTURES COMMITTEE | DATE                |            | SCK              |
|                                |                     |            | DRAWN BY SCK     |
|                                |                     |            | CHECKED BY BLM   |
|                                |                     |            | APPROVED BY BLM  |
|                                |                     |            | HOR. SCALE NOTED |
|                                |                     |            | VERTICAL         |
| NO. REVISIONS                  | DATE                | BY         | DATE 2015-02-20  |



ENGINEER'S SEAL  
DRAWING ORIGINALLY SIGNED BY B.L. MOORE DATED APR. 10, 2015  
CONSULTANT PROJECT NO. 149749

**THE CITY OF WINNIPEG**  
TRANSIT DEPARTMENT

**Winnipeg**

FORT ROUGE GARAGE COMPRESSED AIR SYSTEM UPGRADE

ELECTRICAL - FLOOR PLANS

CITY DRAWING NUMBER P-XXXX- ----  
SHEET 1 OF 2  
CONSULTANT DRAWING NUMBER E1

NOTE:  
LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE, BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION.