

LUMINAIRE SCHEDULE							
TYPE	DESCRIPTION	VOLTAGE	LAMPS	DESIGN BASICS			
В	1 X 4 INDUSTRIAL 2 LAMP LUMINAIRE WITH REFLECTOR AND RAPID START ELECTRONIC BALLAST.	120V	2-32W T8 4100K	LITHONIA: LA 2 32 MVOLT GEB10RS CSA			
F	SURFACE MOUNTED LED CANOPY LUMINAIRE	120V	53W LED 4000K	LITHONIA: DSXSC LED 30C 530 40K T5E 120 SRM DDBXD			
Н	WALL MOUNTED, DIE-CAST ALUMINUM HOUSING	120V	50W LED 4000K	LITHONIA: TWP LED 30C 700 40K T3M MVOLT WG DDBXD (NOTE 4)			
J	SURFACE MOUNTED LED CANOPY LUMINAIRE	120V	37W LED 4000K	LITHONIA: DSXSC LED 10C 1000 40K T5M 120 SRM DDBXD (NOTE 4)			

EMERGENCY LIGHTING EQUIPMENT SCHEDULE							
TYPE	DESCRIPTION	VOLTAGE	LAMPS	DESIGN BASICS			
E1	BATTERY UNIT, SOLID STATE CHARGER,	120V	LED				
	TEST SWITCH, 250W CAPACITY BATTERY,		5W	LUMACELL: RG12S 250 2 LD9 AT			
	12VDC OUTPUT.		2-MR16				
E2	REMOTE LIGHTING, SURFACE MOUNT,	12V	LED				
	DOUBLE HEAD, ADJUSTABLE POSITION.		5W	LUMACELL: MQM 2 LD9			
			2-MR16				
E3	EXIT LIGHT WITH EXTRUDED ALUMINUM	12V	LED				
	CONSTRUCTION, GREEN PICTOGRAM, LEFT			LUMACELL: LA SERIES			
	RIGHT INDICATION.						

NOTES:

- REMOVE EXISTING THREE (3) OUTDOOR LUMINAIRES ON NORTHWEST WALL AS SHOWN ON ARCHITECTURAL DRAWINGS. CONNECT NEW OUTDOOR LUMINAIRES TO EXISTING CIRCUITS CONTROLLED BY LIGHTING CONTACTOR IN ELECTRICAL ROOM.
- CROSS HATCHING DENOTES UNSWITCHED OR NIGHT-LIGHTING FIXTURE.
- 3. ALL LIGHT SWITCHES SHALL BE LOCATED 1200mm FROM FINISHED FLOOR, UNLESS OTHERWISE NOTED. ALL SWITCHES TO BE WEATHERPROOF.
- 4. REPLACE TWO (2) EXISTING WALL MOUNTED LUMINAIRES ON THE HOSE TOWER WITH NEW TYPE 'H' LUMINAIRES. REPLACE NINE (9) EXISTING RECESSED LUMINAIRES WITH NEW TYPE 'J' LUMINAIRÈS CONNECT NEW LUMINAIRES TO EXISTING CIRCUITS. INSTALL PLYWOOD BACKING AND JUNCTION BOX AND MOUNT SURFACE MOUNT LUMINAIRES. PAINT PLYWOOD TO MATCH SOFFIT AND
- PROVIDE A WEATHERPROOF LIGHT SWITCH, HIGH ABUSE LIGHT FIXTURE, EXIT SIGN AND EMERGENCY LIGHTING HEAD IN CRAWLSPACE.
- 6. PROVIDE NEW WEATHERPROOF LIGHTING CONTACTOR FOR EXTERIOR FIXTURES. TIE BACK TO EXISTING PHOTOCELL.

LEGEND:

4' FLUORESCENT FIXTURE

EMERGENCY LIGHTING BATTERY UNIT c/w 2 LTG. HEADS


REMOTE EMERGENCY LIGHTING HEADS

3 SWITCHES IN GANG

EXIT LIGHT

NOTE FOR OTHER LIGHTS AROUND BUILDING:

REPLACE TWO (2) EXISTING WALL MOUNTED LUMINAIRES ON THE HOSE TOWER WITH NEW TYPE 'H' LUMINAIRES. REPLACE NINE (9) EXISTING RECESSED LUMINAIRES WITH NEW TYPE 'J' LUMINAIRES CONNECT NEW LUMINAIRES TO EXISTING CIRCUITS. INSTALL PLYWOOD BACKING AND JUNCTION BOX AND MOUNT SURFACE MOUNT LUMINAIRES. PAINT PLYWOOD TO MATCH SOFFIT AND







THE CITY OF WINNIPEG
PLANNING, PROPERTY AND
DEVELOPMENT DEPARTMENT
MUNICIPAL ACCOMMODATIONS DIVISION 3-65 GARRY STREET, R3C 4K4

WINNIPEG FIRE PARAMEDIC SERVICES

ADDITIONAL APPARATUS ROOM BAYS



KGS Group

No. 245

603 REDWOOD AVENUE ADDITION LIGHTING

PROJECT No: SHEET No: 2013-0171-02 AS SHOWN