


BASEMENT PLAN

1:100




- NOTES:
1. ALL DRAINS ARE 100 DIAMETER AND ARE INSTALLED AT 1% SLOPE UNLESS NOTED OTHERWISE.
 2. LOCATE EXISTING 50mm SEAL WATER LINE IN THE PIPING RACK OF THE PRIMARY CLARIFIER GALLERY 3, SOUTH SIDE, (EXISTING DRAWING SEP-348) AND CONNECT 50-NPW-CU01 TO IT WHERE APPROPRIATE. FIELD-ROUTE TO HRC BUILDING THROUGH EXISTING SERVICE GALLERY 5.
 3. REFER TO DRAWING NUMBER 1-0102-MISO-K501 THRU 1-0102-MISO-K504 FOR PLUMBING ISOMETRICS.

APEGM
 Certificate of Authorization
 CH2M HILL Canada Ltd.
 No. 1441

NO.	REVISIONS	DATE	DESIGN	CHECK
01	ISSUED FOR ADDENDUM NO. 3	09/2015	S.S.	J.C.
00	ISSUED FOR TENDER	08/2015	S.S.	J.C.

CH2MHILL	
SNC-LAVALIN	
DESIGNED BY: T. TRAN	CHECKED BY: D.LE
DRAWN BY: R. ARCHER	APPROVED BY: T. TRAN
SCALE: 1:100	ISSUED FOR CONSTRUCTION BY: T. TURZAK
DATE: 2015/08/13	DATE: 2015/08/13
CONSULTANT NO.: 474248	



THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE
 SEWPPC UPGRADING/EXPANSION PROJECT
 MECHANICAL
 HIGH RATE CLARIFICATION BUILDING
 PLUMBING - BASEMENT PLAN

CITY DRAWING NUMBER: 1-0102-MGAD-K501
 SHEET: 01
 REV.: 01
 SIZE: A1