



INSPECTION AND TECHNICAL SERVICES MB
500 - 401 YORK AVENUE,
WINNIPEG, MB R3C 0P8
PHONE (204) [REDACTED] FAX (204) [REDACTED]
[HTTP://FIRECOMM.GOV.MB.CA/ITSM_MAIN.HTML](http://FIRECOMM.GOV.MB.CA/ITSM_MAIN.HTML)

CITY OF WINNIPEG CORP FINANCE
4TH FLR.,510 MAIN ST.,
WINNIPEG, MB R3B 1B9

[REDACTED]
MB Elevator # 3676
Elevator Type: CHAIN
Location : CONCOURSE SW CORNER
MAIN ST & PORTAGE AVE
WINNIPEG

The Elevating Device located at : MAIN ST & PORTAGE AVE, in the City of WINNIPEG, was inspected on [REDACTED], by our Inspector [REDACTED].

The following conditions were observed that require attention at this time:

Repair or replace skirt panels as per code - B44-07 6.1.3.3.6 (c)

Steps with broken treads shall be [REDACTED] replaced. CSA B44-07 section 8.6.8.6.1 requirement. Escalator clean down to meet requirement 8.6.8.13 CSA B44-2007

The above instructions must be completed by [REDACTED] and the above Branch notified accordingly.

Please notify our office in writing when the work orders have been completed.

It is the owner's responsibility to inform our Branch of all changes regarding management and ownership and possession date in order that our record may be amended accordingly.

If you have any questions regarding this report, please contact me at (204) [REDACTED]

Report Submitted by:

[REDACTED]
Inspection and Technical Services MB
Phone number : (204) [REDACTED]
Fax number : [REDACTED]
Email : [REDACTED]