



## 824-2015 ADDENDUM 3

### OLIVE WASTEWATER PUMPING STATION UPGRADES

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: October 9, 2015  
BY: Ian Parkinson  
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Revise Clause E16.2 to read:

If any new pumping equipment (pump, pump controller, motor or drive shaft) fails to operate or perform properly and has to be removed for service as determined by the Contract Administrator, the Contractor shall provide a quote for removal of the equipment and make arrangements with the pump supplier to have the equipment taken to the Supplier's shop. If the quotation is accepted by the Contract Administrator, the City will pay the Contractor the price indicated in the quotation for this work. If remaining funds are available under Form B, item 15, the additional labour will be reimbursed as per section E31.

Revise Clause E20.3.1 (a) to read:

The Contractor is eligible for payment when the Contract Administrator is satisfied that the Contractor has met all the requirements as specified in E20.

Revise Clause E21.3 (d) to read:

The Contractor will be allowed to temporarily shut-down the pumping station to install the tee-junction in the new bypass manhole as indicated in Section E14. This Bid Opportunity will not dictate how the Contractor chooses to install the bypass tee-junction, however, in order to evaluate competing proposals, all proponents should include the components shown in drawing 1-0169L-M0005.

Add Clause E22.3.4 (l):

The Contractor may choose to connect the bypass pump discharge hose directly to the Ø300 (12 inch) flange on the bypass tee. Once bypass operations are complete, the bypass tee should be left with the 8" x 12" reducer and 8" gate valve.

Revise Clause E22.4.1 (a) to read:

The Contractor is eligible for payment when the Contract Administrator is satisfied that the Contractor has met all the requirements as specified in E22.

Revise Clause E24.8.1 (a) to read:

The Contractor is eligible for payment when the Contract Administrator is satisfied that the Contractor has met all the requirements as specified in E24.

Add Clause E 29.3 (a):

The costs for the Manitoba Hydro service upgrade will be billed directly to the City and not to the Contractor. The Contractor therefore shall not incorporate the fee from Manitoba Hydro for the service upgrade into their bid price. However, the Contractor is still fully responsible for all coordination with Manitoba Hydro.

### **DRAWINGS**

Replace 824-2015\_Addendum\_2\_Drawing\_1-0169L-M0005-001-01 with  
824-2015\_Addendum\_3\_Drawing\_1-0169L-M0005-001-02.

Replace 824-2015\_Addendum\_1\_Drawing\_1-1069L-S0009-001-01 with  
824-2015\_Addendum\_3\_Drawing\_1-1069L-S0009-001-02

Replace 824-2015\_Addendum\_2\_Drawing\_1-0169L-S0010-001-01 with  
824-2015\_Addendum\_3\_Drawing\_1-0169L-S0010-001-02.