

**Manitoba**

Labour and Immigration



INSPECTION AND TECHNICAL SERVICES MB  
500 - 401 YORK AVENUE,  
WINNIPEG, MB R3C 0P8  
PHONE (204) [REDACTED] FAX (204) [REDACTED]  
[HTTP://FIRECOMM.GOV.MB.CA/ITSM\\_MAIN.HTML](http://firecomm.gov.mb.ca/itsm_main.html)

[REDACTED]  
MB Elevator # 3972  
Elevator Type: OGA  
Location : CONFEDERATION BLDG  
457 MAIN ST  
WINNIPEG

The Elevating Device located at : 457 MAIN ST, in the City of WINNIPEG, was inspected on [REDACTED] by our Inspector [REDACTED].

The following conditions were observed that require attention at this time:

Elevator pits shall be kept clean and free of debris at all times -8.6.4.7.1 B44 07

The elevator overspeed governor shall be tested and sealed in the presence of an inspector from this department - 8.11.2.3.2 B44 07.

The above instructions must be completed by [REDACTED] and the above Branch notified accordingly.

**Please notify our office in writing when the work orders have been completed.**

It is the owner's responsibility to inform our Branch of all changes regarding management and ownership and possession date in order that our record may be amended accordingly.

If you have any questions regarding this report, please contact me at (204) [REDACTED]

Report Submitted by:

[REDACTED]  
Inspection and Technical Services MB  
Phone number : (204) [REDACTED]  
Fax number : [REDACTED]  
Email : [REDACTED]