Pumps

NO.	SERVICE	LOCATION	MODEL / SIZE	CAP. (gpm) (l/s)	HEAD (ft) (m)	MTR. (HP) (kW)	SPD. (rpm)	REMARKS
P-5	Glycol Heating Secondary Loop	Mech Room	Armstrong 4300 0206-010.0	**170** 10.71	**100** 30.49	**10** 7.46	3076	IVS Sensorless Duty / Standby (w/ P-6) FTV-3FA Angle Flo-trex SG-32 Suction Guide
P-6	Glycol Heating Secondary Loop	Mech Room	Armstrong 4300 0206-010.0	**170** 10.71	**100** 30.49	**10** 7.46	3076	IVS Sensorless Duty / Standby (w/ P-5) FTV-3FA Angle Flo-trex SG-32 Suction Guide

Fluid: 55% Ethylene Glycol

SMS ENGINEERING

Pump Schedule

Project: **City of Winnipeg Fort Rouge Transit Storage Track 1-12 Ventilation Upgrade**

File: 16-149-01 Designer: JTRH

Date: Dec-16 Sheet: **MS-3R1**