



1018-2016 ADDENDUM 2

CONSTRUCTION OF TRANSCONA LIBRARY – 1500 PLESSIS ROAD

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: March 14th 2017
BY: Steff Beernaerts
TELEPHONE NO. 204 989-8925

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Add: D2.3 The City will apply for the permit and pay for the permit fees. Upon award, the permit will be transferred to the Contractor.

PART E – SPECIFICATIONS

Division 07

Section 07 42 43 Composite Metal Panels

Add: 2.3.1.2 Iso Clip ; Thermal Insulation Clip
Add: 2.3.1.3 ACS Clip ; ACS Composite Systems Inc.

Section 07 52 00 Modified Bituminous Membrane Roofing

Revise: 2.7.2.1: Acceptable Product: Soprema Sopra-Iso.

Division 08

Section 08 06 70 Door Hardware Schedule:

Delete:	Hardware Set : 05	1 EA	POWER TRANSFER	EPT2 CON	689	VON
Add:	Hardware Set : 05	1 EA	ELECTRIC STRIKE	6111-FSE	630	VON

Section 08 71 43 Automatic Door Operators:

Add: 2.3.1.1.4: LCN; 9500 Series
Add: 2.3.1.1.5: Nabco(GyroTech); GT8500
Add: 2.3.1.2.4: LCN; 9100 Series
Add: 2.3.1.2.5: Nabco(GyroTech); GT710

Add: 2.3.3: Manufacturer / Product for Curtainwall Doors (Interior and Exterior)
.1 LCN; 4600 Series
.2 Dorma ; ED200
.3 BESAM ; Power Swing

Division 09

Section 09 65 10 Resilient Flooring:

Revise: 2.3.1.1 Height: **100 to 103mm**
Revise: 2.3.1.2 Thickness: **3.2 to 4.5 mm** thick.

Section 09 68 13 Tile Carpeting:

Revise: 2.3.1.1 Shaw Contract, Collection Places, Style Sea Tile 5T172, or subject to compliance with specified requirements, or approved equal by one of the following manufacturers, in accordance with B6.
Revise: 2.5.1.1 Height: **100 to 103mm**
Revise: 2.5.1.2 Thickness: **3.2 to 4.5 mm** thick.

Division 22

Section 22 10 10 - Plumbing Pumps

Add: 2.2 Manufacturer
.1 Zoeller,
.2 Liberty Pumps

Section 22 42 03 – Commercial Washroom Fixtures:

Revise: 1.6.1 Fixtures: American Standard, Crane, TOTO, Kohler, **Contrac**
Revise: 2.2.2 WC-1: American Standard Maderna Flowise Elongated floor mount toilet for flush valve, 4.8 litres/flush.
Add: 2.2.1.3.1 Alternate: Contrac Model 4762BOX
Add: 2.2.2.1.1.1 Alternate: Delta Model 81T201
Add: 2.3.1.1.1 Alternate: Carlton model 4810BFX
Add: 2.3.1.1.2 Alternate: Kohler High Efficiency Urinal (HEU) K-5244-ET
Add: 2.3.2.2.1 Alternate: Alternate: Delta Model 81T231
Add: 2.4.1.1.1 Alternate: Contrac Model 4610CHZ
Add: 2.4.2.1.1 Alternate: Contrac Model 4220 CFY

Section 22 47 00 – Drinking Fountains and Water Coolers:

Add: 2.2.1.14 Alternate: Franke KEM8WR-EBF-STN 2030029814

Division 23

Section 23 34 00 – HVAC Fans:

Revise: 2.4.3 Acceptable Product: Trane, Sheldons, Barry Blower, Cook, Penn, Woods, Greenheck, **Twin City**.

Section 23 54 16 - Fuel-Fired Furnaces

Add: 2.11 Manufacturer
 .1 Trane
 .2 Daikin

Section 23 74 00 – Outdoor HVAC Fans:

Add: 2.9 Manufacturer
 .1 Trane
 .2 Daikin
 .3 Aeon

DRAWINGS

Replace: 1018-2016_Addendum_1_Drawing_L-100-R2 with 1018-2016_Addendum_2_Drawing_L-100-R3

Replace: 1018-2016_Addendum_1_Drawing_L-401-R2 with 1018-2016_Addendum_2_Drawing_L-401-R3

Replace: 1018-2016_Drawing_E-100-R1 with 1018-2016_Addendum_2-Drawing_E-100-R2.

Replace: 1018-2016_Drawing_E-101-R1 with 1018-2016_Addendum_2-Drawing_E-101-R2.

Replace: 1018-2016_Drawing_E-102-R1 with 1018-2016_Addendum_2-Drawing_E-102-R2.

Replace: 1018-2016_Addendum_1_Drawing_E-103-R2 with 1018-2016_Addendum_2-Drawing_E-103-R3.

Replace: 1018-2016_Addendum_1_Drawing_E-104-R2 with 1018-2016_Addendum_2-Drawing_E-104-R3.

Replace: 1018-2016_Drawing_E-105-R1 with 1018-2016_Addendum_2-Drawing_E-105-R2.

Add: 1018-2016_Addendum_2-Drawing_E-106-R1.