

Certificate of Authorization

Dillon Consulting Limited (MB)

No. 1789 Date: 2017/01/09

BRIDGE NORTH SOUTH 1000 DEEP STEEL PLATE GIRDER (TYP.) 3400 3400 425 | 425 9 SPACES @ 850 = 7650

S-|CS-27|027 | SCALE: 1:30

STEEL GIRDER NOTES:

- 1. FOR GENERAL NOTES SEE C2-CS-001.
- 2. DESIGN AND WORKMANSHIP SHALL BE IN ACCORDANCE WITH AREMA MANUAL, CHAPTER 15.
- 3. MATERIAL SHALL BE IN ACCORDANCE WITH THE FOLLOWING SPECIFICATIONS:

STRUCTURAL STEEL: CSA G40.21 GRADE 350WT, CATEGORY 5: IN GIRDER WEBS, FLANGES, BEARING STIFFENER PLATES

GRADE 350W: TEMPORARY BRACING, INTERMEDIATE STIFFENER ANGLES AND ALL REMAINING MEMBERS.

GRADE 300W: FOR BEARING PLATES.

WELDING: CSA W59 (R2008) AND AWS D1.5 ANCHOR RODS: STAINLESS STEEL S316L GRADE 75 HIGH STRENGTH BOLTS: ASTM A325, TYPE 1

METALIZING: ASTM B833 AND CSA G189 GALVANIZING: ASTM A123 / A123M AND CAN/CSA G164

- 4. ALL BOLTS TO BE M22 UNLESS NOTED OTHERWISE.
- 5. ALL BOLT HOLES TO BE 24 DIA. UNLESS NOTED OTHERWISE.
- 6. ALL HOLES SHALL BE DRILLED OR SUB-PUNCHED AND REAMED.
- 7. ALL HIGH STRENGTH BOLTS SHALL BE TIGHTENED BY THE TURN-OF-NUT METHOD.
- 8. BOTTOM FLANGES OF GIRDERS OVER BEARINGS SHALL BE TRUE AND SQUARE; MAXIMUM MEASURED DEVIATION AT OUTSIDE OF EDGE OF BEARING PLATES SHALL NOT EXCEED 1 mm.
- 9. DEVIATION RESULTING IN NEGATIVE CAMBER SHALL NOT BE PERMITTED.
- 10. DEVIATION FROM STRAIGHTNESS OF MAIN GIRDERS SHALL NOT EXCEED 3 mm.
- 11. ALL NON-SLIDING SURFACES OF BEARINGS SHALL BE ZINC-METALLIZED IN ACCORDANCE WITH CSA G189. ZINC COATING SHALL NOT BE LESS THAN 0.25 mm.
- 12. REFER TO CN STANDARD DRAWINGS FOR ADDITIONAL INFORMATION NOT SHOWN ON THIS
- 13. ERECTION PROCEDURE SHALL BE SUBMITTED TO CONTRACT ADMINISTRATOR FOR REVIEW.
- 14. STEEL BEAMS ARE DESIGNED TO CARRY 1100 mm CONCRETE DECK, BALLAST (410 mm PRESENT
- 15. ALL STEEL GIRDERS AND CROSS BRACINGS SHALL BE ZINC-METALLIZED IN ACCORDANCE WITH CSA G189. ZINC COATING SHALL NOT BE LESS THAN 0.25 mm.

FABRICATION:

- 1. FABRICATION SHALL BE IN ACCORDANCE WITH THE CURRENT CN SPECIFICATION FOR STRUCTURAL STEEL FABRICATION FOR RAILWAY BRIDGES AND AREMA REQUIREMENTS.
- 2. ALL DIMENSIONS ARE CORRECT AT 20° C AND GIRDER LENGTHS ARE MEASURED ALONG THE BOTTOM FLANGE.
- GIRDERS SHALL BE CAMBERED TO THE VALUES SHOWN IN THE CAMBER DIAGRAMS. THE CAMBER ORDINATES INCLUDE AN ALLOWANCE FOR DEFLECTION DUE TO GIRDER SELF-WEIGHT CONCRETE DECK AND SUPERIMPOSED DEAD LOADS AND CURVATURE OF THE RAILWAY. THE CONTRACTOR SHALL PROVIDE SHOP DRAWINGS SHOWING ADJUSTMENTS REQUIRED TO THE CAMBER DIAGRAM RESULTING FROM THE FABRICATION AND ERECTION METHODS USED.
- 4. ALL BEARING STIFFENERS AND END OF GIRDER WEB SHALL BE VERTICAL AFTER COMPLETE DEAD LOAD DEFLECTION HAS OCCURRED.
- 5. ALL FLANGE AND WEB BUTT SPLICES AND ALL STIFFENER TO WEB FILLET WELDS SHALL BE MADE BY AN APPROVED SEMI OR FULLY SUBMERGED ARC WELD PROCESS.

ERECTION:

- 1. GIRDERS SHALL BE ADEQUATELY SUPPORTED BY TEMPORARY BRACES TO ENSURE THAT NO DAMAGE IS CAUSED BY HANDLING AT ANY TIME.
- 2. CONTRACTOR IS RESPONSIBLE FOR THE MEANS OF MAINTAINING GIRDERS IN CORRECT ALIGNMENT UNTIL DECK HAS BEEN CAST AND HAS OBTAINED ITS SPECIFIED STRENGTH.

AND 710 mm FUTURE).

ENGINEER'S SEAL THE CITY OF WINNIPEG PUBLIC WORKS DEPARTMENT Winnipeg **DILLON** CONSULTING **ERIC** DESIGNED CHECKED CITY DRAWING NUMBER RE SSR WAVERLEY STREET UNDERPASS AT CN MILE 3.89 RIVERS SUB U-239-2016-C2-CS-027 CONTRACT 2: UNDERPASS STRUCTURE, RAILWORKS, Member DRAWN APPROVED ROADWORKS, LAND DRAINAGE SEWER, PUMPING STATION SHEET OF DBW AND LANDSCAPING WORKS 085 027 ADDENDUM #5 | 17/03/01| RE RELEASED FOR AS SHOWN HOR. SCALE CONSULTANT DRAWING NUMBER 17/02/24 RE ADDENDUM #4 CONSTRUCTION CONSULTANT PROJECT NUMBER VERTICAL AS SHOWN STEEL GIRDER LAYOUT ISSUED FOR TENDER 17/01/09 RE C2-CS-027 16-3353 DATE BY IO. REVISIONS DATE