



**1 NEW MAIN FLOOR POWER PLAN**  
3/16" = 1'-0"

- NOTES:
- EXISTING WIRING TO BE CONCEALED BEHIND WALL/CEILING.
  - REPLACE ALL EXISTING RECEPTACLES TO TEMPER RESISTANCE DECORA TYPE.
  - RELOCATE RECEPTACLES. EXTEND RE-ROUTE, RE WIRE AND RECONNECT TO EXISTING ON SITE. FINAL LOCATION TO BE COORDINATED ON SITE. REFER TO ARCHITECTURAL DRAWINGS FOR DETAILS.
  - REFER TO ARCHITECTURAL DRAWINGS FOR DOOR ACTUATOR LOCATION.
  - PROVIDE AND INSTALL SEPARATE EMERGENCY CALL ALARM AND SIGNAL DEVICES FOR BASEMENT AND MAIN FLOOR UNIVERSAL TOILET ROOM. MANUFACTURED BY FEDERAL SIGNAL, MODEL #USIS C'W BUILT-IN SOUNDER.



**APEGM**  
Certificate of Authorization  
HDK Consulting Incorporated  
No. 5539 Date: 04/30/2017



Project:  
St. Vital Library

Project Number: 10254  
Bid Opportunity Number: 788-2016

Drawing Title:  
NEW MAIN FLOOR POWER PLAN

# Issue/Revision Date

1 ISSUED FOR CONSTRUCTION SEPT 09, 2016

Sheet No: E-11

This drawing is property of the Architect and cannot be reproduced or used without the consent of the Architect. The contractor is responsible for checking and verifying all levels and dimensions and shall report all discrepancies to the Architect and obtain clarification prior to commencing work.