A1 SIZE – 594mm x 841mm





GENERAL NOTES:

1. REFER TO DWG. 1-0102-ECTR-K002-001 FOR GENERAL NOTES.

SPECIFIC NOTES:

(1) PROVIDE FIRE RATED ASSEMBLY AND SEAL ALL CABLES PENETRATING THE WALL TO SEPARATE THE AREAS. WALL OPENINGS PROVIDED UNDER CONTRACT C2. VERIFY LOCATIONS AND DIMENSIONS ON CONTRACT C2 DRAWINGS AND BASED ON AS-BUILT CONDITIONS. PROVIDE ADDITIONAL OPENINGS AS REQUIRED.

GROUND FLOOR PLAN

1 : 50

1:50 500 0 1000 2000

REFERENCE DRAWINGS	DESCRIPTION
1-0102-ECTR-K003	CABLE TRAY DETAILS

APEGM Certificate of Authorization
SNC-Lavalin Inc.
No. 4489

NO.	REVISIONS	DATE	DESIGN	CHECK
02	ISSUED FOR CONSTRUCTION – 976-2016	2017/04/05	SLJ	DEB
01	ISSUED FOR CONSTRUCTION	10/2015	SLJ	DEB
00	ISSUED FOR TENDER	08/2015	SLJ	DEB

CH2MHILL. KGS GROUP SNC·LAVALIN

DESIGNED BY: S. JUGANAS	CHECKED BY: E. RYCZKOWSKI
DRAWN BY: MJ. PERSSON	APPROVED BY: D. BECKER
SCALE: 1:50	ISSUED FOR CONSTRUCTION BY: J. SHUMKA
DATE: 2015/01/27	DATE: 2017/04/05
CONSULTANT NO.: 474248	

ENGINEER'S SEAL
PROVINCE OF MANITOBA
D. E. BECKER
Member
23646
REGISTERED PROFESSIONAL ENGINEER
April 5/2017

Winnipeg
THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE
SEWPCC UPGRADING/EXPANSION PROJECT
ELECTRICAL – CABLE TRAY LAYOUT
HIGH RATE CLARIFICATION BUILDING
GROUND FLOOR PLAN

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0102-ECTR-K002	002	02	A1

LAST SAVE: 2017/03/24 – 9:40am
PATH: C:\DWG\1-0102-ECTR-K002-002.dwg

PLOT DATE: Mar 24, 2017 – 9:40am

FILE NAME: 1-0102-ECTR-K002-002.dwg