

LIGHT FIXTURE SCHEDULE		
LABEL	FIXTURE	SPECIFICATION
TYPE A	INDUSTRIAL LED	PHILIPS VAPORLUME LED DW, #D-W-P-E-51LH-840-4-UNV. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
ТҮРЕ В	LINEAR LED	LITHONIA BLT 1x4, 6000 NOMINAL LUMENS, CURVED LINEAR PRISMATIC LENS, 4000K CCT. # BLT4 60L ADP LP840. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
TYPE C	LINEAR LED	PHILIPS FLUXSTREAM LED LINEAR, #LF-4-FR-31-35-U-LAG, C/W WIREGUARD #LF4WGW, AIRCRAFT CABLE KIT #SVCC60-UNV. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
TYPE D	LINEAR LED	LITHONIA BLT 1x4, 4000 NOMINAL LUMENS, CURVED LINEAR PRISMATIC LENS W/ TRIM RINGS, 4000K CCT. # BLT4 40L ADPT LP840. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
TYPE WS	EXTERIOR WALL MOUNT	PHILIPS WALL MOUNT LYTEPRO LED SCONCE, #LPW32-79DGY. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
EL	EMERGENCY LIGHTING	EMERGI-LITE ESL SERIES EMERGENCY DUAL REMOTE HEADS W/BATTERY BANK. #12ESL144/2; FACTORY WHITE. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
\$	LIGHT SWITCH	SINGLE POLE COMMERCIAL DECORATOR PADDLE TYPE, C/W STAINLESS STEEL FACE PLATE. SWITCHES OF ONE MANUFACTURER TO BE USED THROUGHOUT PROJECT. OR APPROVED EQUAL IN ACCORDANCE WITH B7.

678 Annet Statest Vandatted, left non 194 204 486 3857 tal. 204 488 0218 fee. hridomancollaborative PARKS STORAGE SHED

bridgmencollaborative | Project:

Fraser's Grove Park

Project Drawing Title:
Number: LIGHTING LAYOUT 1630

# Issue/Revision Date Sheet No: ISSUED FOR CONSTRUCTION

17 06 08 **E102** 

This drawing is property of the Architect and cannot be reproduced or used without the consent of the Architect. The contractor is responsible for checking and verifying all levels and dimensions and shall report all discrepancies to the Architect and obtain clarification prior to commencing work.