

SUPPLY AND DELIVERY OF SODIUM HYDROXIDE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: October 16, 2017
BY: Dave Carr
TELEPHONE NO. 204 986-2091

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Replace: E2.2 to read:

The fifty (50%) percent sodium hydroxide furnished under this specification shall be suitable for addition to treated water for pH adjustment. The sodium hydroxide supplied is to be used in the treatment of drinking water and shall contain no soluble materials or organic substances in quantities capable of producing deleterious or injurious effect upon the health of those consuming the water.

Replace: E2.6 to read:

E 2.6 A Certificate of Analysis shall be submitted by the Contractor for each sodium hydroxide delivery to the City. The certificate shall be e-mailed to the Contract Administrator stated in D3.1 before unloading begins. The certificate shall contain the following:

(i) certificate of analysis issue date;	(Report)
(ii) production lot number;	(Report)
(iii) date of manufacture;	(Report)
(iv) percent of weight sodium hydroxide	(49.0 -51.0 wt%)
(v) specific gravity;	(Report)
(vi) alkalinity (Na ₂ O);	(38.0-39.5 wt%)
(vii) sodium chloride (NaCl);	(≤ 100 ppm)
(viii) sodium carbonate (Na ₂ CO ₃);	(≤ 0.1% wt%)
(ix) sodium sulfate (Na ₂ SO ₄);	(≤ 100 ppm)
(x) sodium chlorate (NaClO ₃);	(≤ 65 ppm)
(xi) iron (Fe);	(≤ 5.0 ppm)
(xii) nickel (Ni);	(Report)
(xiii) documentation of ANSI/NSF 60 certification .	(Report)