


B SIZE - 279mm x 432mm

General DWG\1-0179F-A0004-001.dwg

LAST SAVE: 2018/12/13 - 4:47pm  
PATH: M:\657381\4ENG\48IC\DD -

FIELD  
(ELECTRICAL ROOM)

RTU PANEL  
(ELECTRICAL ROOM)



ALARM SETPOINTS	TEMP (°C)
HIGH TEMPERATURE	30°C
LOW TEMPERATURE	4°C

**NOTES:**

- PROVIDE AND INSTALL NEW TEMPERATURE SWITCH.
- HIGH TEMPERATURE SWITCH CONTACT TO BE CLOSED WHEN TEMPERATURE IS NORMAL AND OPEN WHEN TEMPERATURE IS ABOVE SETPOINT.
- LOW TEMPERATURE SWITCH CONTACT TO BE CLOSED WHEN TEMPERATURE IS NORMAL AND OPEN WHEN TEMPERATURE IS BELOW SETPOINT.



**SNC-LAVALIN INC.**  
148 Nature Park Way  
Winnipeg, MB, Canada R3P 0X7  
204-786-8080



**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT

ROLAND FLOOD PUMPING STATION  
2019 UPGRADES  
LOOP DIAGRAM  
ELECTRICAL ROOM HIGH/LOW TEMPERATURE  
TS-F621

NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER AND CONSTRUCTION	2018/12/14	KS	BC

DESIGNED BY: K. SAPIAK  
CHECKED BY: B. CLEVEN  
DRAWN BY: K. SAPIAK  
APPROVED BY: B. CLEVEN  
SCALE: NTS  
DATE: 2018/08/23  
ISSUED FOR CONSTRUCTION  
BY: K. ZUREK  
DATE: 2018/12/14  
CONSULTANT NO.:

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0179F-A0004	001	00	B