



247-2018 ADDENDUM 1

PAN AM POOL PUMP AND MOTOR CONTROL CENTRE UPGRADE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 4, 2018
BY: Blair Moore
TELEPHONE NO. (204) 453-2301

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

NMS Format Specifications

Section 26 29 10 Motor Starters to 600 V

Revise: 2.2.2.10.1 Schneider Electric ATS22, Allen Bradley SMC-Flex 150, or approved equal in accordance with B7.

Add: 2.5 Power factor correction capacitors, 10 kVAR, complete with isolation contactor.

DRAWINGS

Replace: 247-2018_Drawing_E-102-RB with 247-2018_Drawing_E-102-RC.

Replace: 247-2018_Drawing_E-103-RB with 247-2018_Drawing_E-103-RC.