



		VDC Y	
24 VDC POWER FROM TS2-F15, 0.5 AMP QUICK BLC	DW FUSE		TS2-1, 0 VDC
DRAWING: 1-0145L-A0003-001 J 57	-10057	TS3 8 10057	SCADAPAK 5606 P-F01 RUN
J	-10058	TS3	SCADAPAK 5606
58		9 10058	P-F01 FAIL
J	-10059	TS3	SCADAPAK 5606
59			P-F02 RUN
J	-10060	TS3	SCADAPAK 5606
60			P-F02 FAIL
J	-10061	TS3	SCADAPAK 5606
61		12 10061	WEIR OVERFLOW
U	-10062	TS3	SCADAPAK 5606
62		13_10062	OVERFLOW FLOW METER FAIL
U	-10063	TS3	SCADAPAK 5606
63		14_10063	INFLOW FLOW METER FAIL
U	-10064	TS3	SCADAPAK 5606
64		15_10064	SPARE
	Image: Signed By BkB CHECKED BLM		Winnipeg THE CITY OF WINNIPEG Water and Waste Department
Dillon Consulting Limited (MB) 0 No. 1789 Date: 06/29/18 0	DESIGNED BKB CHECKED BLM DRAWN BY SCK APPROVED MH HOR. SCALE NONE RELEASED FOR CONSTRUCTION MH	CONSULTANT PROJECT NUMBER	HAWTHORNE WASTEWATER PUMPING STATION UPGRADESCIT DRAWING NOMBER 1-0145L- A0013-001BI 57-64CONSULTANT DRAWING NUMBER

			0 VDC TS2	2-1, 0 VDC	
4 VDC POWER FROM TS2-F15, 0.5 AMP QUICK BLC DRAWING: 1-0145L-A0003-001	DW FUSE -10057	TS3	8 10057	SCADAPAK 5606 P-F01 RUN	
	-10058	TS3	9 10058	SCADAPAK 5606 P-F01 FAIL	
	—10059———	TS3	10 10059	SCADAPAK 5606 P-F02 RUN	
	—10060	TS3	11 10060	SCADAPAK 5606 P-F02 FAIL	
	—10061———	TS3	12 10061	SCADAPAK 5606 WEIR OVERFLOW	
	—10062———	TS3	13 10062	SCADAPAK 5606 OVERFLOW FLOW METER FAIL	
	—10063———	TS3	14 10063	SCADAPAK 5606 INFLOW FLOW METER FAIL	
	—10064————	TS3	15 10064	SCADAPAK 5606 SPARE	
		[P8 RTU COM		
Certificate of Authorization	DRAWN BY SCK BY	ENGINEER'S S	Ŵ	THE CITY OF WINNIPER water and waste department water and waste department water and waste department water and waste department city drawing number 1-0145L- A0013-00 SHEET of 13 25	т 01
Dillon Consulting Limited (MB) No. 1789 Date: 06/29/18 0 ISSUED FOR TENDER No. REVISIONS	HOR. SCALE NONE RE CO 06/29/18 BLM VERTICAL CO DATE BY DATE JUNE 2018 DATE	CONSULTANT	project number -6936	DI 57-64 FLOOD PUMPS AND CSO PANEL 13	ЗER