



586-2018 ADDENDUM 1

NEWPCC – UPGRADE SITE PREPARATION WORKS – PARCEL B ROAD AND ASSOCIATED WORK

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: July 10, 2018
BY: Ryan Cunningham, P. Eng.
TELEPHONE NO. 204 928-8377

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Revise: D10.1 (a) to read: commercial general liability insurance, in the amount of at least ten million dollars (\$10,000,000.00) inclusive, with The City of Winnipeg and Canadian Pacific Railway added as an additional insured, with a cross-liability clause, such liability policy to also contain contractual liability, unlicensed motor vehicle liability, non-owned automobile liability, broad form property damage coverage and products and completed operations, to remain in place at all times during the performance of the Work and throughout the warranty period;
- Add: D10.1 (d): Contractor's pollution liability insurance in the amount of at least two million dollar (\$2,000,000) per occurrence and five million dollars (\$5,000,000) in the aggregate insuring against claims covering third party property damage claims and including clean-up costs as a result of pollution conditions arising suddenly or gradually from the Contractor's operations and completed operations. Such policy shall include The City of Winnipeg and Canadian Pacific Railway, their employees, servants, and agents, as additional insureds and include a cross liability clause and remain in place for a minimum of twelve (12) months following Total Performance.

PART E – SPECIFICATIONS

- Revise: E12.11.2 to read: All reinforcing steel shall conform to the requirements of CSA Standard G30.18, Grade 400 W, Billet-Steel Bars for Concrete Reinforcement. All reinforcing steel shall be new deformed billet steel bars.
- Revise: E12.12.1 to read: Anchor bolts, nuts and washers shall be stainless steel full length. The threaded portion of the anchor bolts shall be sufficient to install the lower gate rollers. Anchor bolt supply and installation will be incidental to construction of concrete pile foundations and no separate payment will be made.

DRAWINGS

Replace: 586-2018 _Drawing_1-0101-CRSW-Y007-R0.pdf with 586-2018 _Addendum_1 Drawing 1-0101-CRSW-Y007-R1.pdf