




ELEMENTARY DIAGRAM:



FIELD CONNECTION DIAGRAM:



GENERAL NOTES:

1. AT 29 °C, EXHAUST FAN EF-G4 STARTS.
2. EXHAUST FAN EF-G4 CONTROL SCHEME IS PER EXISTING SCHEME BASED ON EXISTING DOCUMENTATION.

CONSTRUCTION NOTES:

- ① THERMOSTAT IS EXISTING. WIRE TO THERMOSTAT SIMILAR TO EXISTING.


1-0640M-E0008	EQUIPMENT PLAN, GENERATOR RM. & LOAD BANK LLD-G767
1-0640B-E0006	MCC ELEVATION & SINGLE LINE, GENERATOR ROOM MCC-G766
DRAWING NUMBER	REFERENCE DRAWINGS



00	ISSUED FOR TENDER AND CONSTRUCTION	2019/10/18	VE	KS
NO.	REVISIONS	DATE	DESIGN	CHECK

SNC-LAVALIN INC.
 148 Nature Park Way
 Winnipeg, MB, Canada R3P 0X7
 204-786-8000

DESIGNED BY: V. ELIMBAN
 CHECKED BY: K. SAPIAK
 DRAWN BY: J. GRAGASIN
 APPROVED BY: D. BECKER
 SCALE: NTS
 ISSUED FOR CONSTRUCTION
 DATE: 2019/06/20
 BY: A. WEISS
 DATE: 2019/10/18



THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

MCPHILLIPS PUMPING STATION
 ELECTRICAL AND HVAC UPGRADES, MCC REPLACEMENT
 MOTOR STARTER SCHEMATIC
 GENERATOR ROOM
 EF-G4 EXHAUST FAN

CITY DRAWING NUMBER: 1-0640B-E0012
 SHEET: 001
 REV: 00
 SIZE: A1