

NOTES:

THESE DRAWINGS SHALL NOT BE SCALED. CONSULT WITH THE CITY OF WINNIPEG & CONTRACT ADMINISTRATOR ON ANY CONCERNS.

CONTRACTOR RESPONSIBLE FOR RETAINING FUNCTION OF EXISTING FIRE PREVENTION SYSTEM.

SUBMISSION OF SITE MARK-UPS, AS-BUILTS, OPERATING & MAINTENANCE MANUALS & OTHER SUPPORTING DOCUMENTS TO THE CITY OF WINNIPEG ARE MANDATORY AT THE COMPLETION OF THIS PROJECT.

THE CONTRACTOR SHALL VISIT THE SITE AND SATISFY ONESELF ALL DIMENSIONS, DATUM, AND DETAILED INFORMATION SHOWN ARE CORRECT.

THE CONTRACTOR IS TO REVIEW & COORDINATE ALL ARCHITECTURAL, MECHANICAL & ELECTRICAL DRAWINGS FOR ADDITIONAL OPENINGS THROUGH FLOORS, WALLS & CEILINGS FOR DUCT, PIPE & ELECTRICAL RISERS & ALL OPENINGS NOT SHOWN ON DRAWINGS.

ALL OPENINGS THROUGH FIRE ASSEMBLIES INCLUDING FLOORS & CEILINGS SHALL BE FIRE STOPPED & SEALED WITH UL/C APPROVED FIRE STOPPING TO MAINTAIN THE INTEGRITY OF THE FIRE SEPARATION & PROVIDE A SMOKE-TIGHT BARRIER.

ALL PRODUCTS & MATERIALS TO BE USED & INSTALLED SHALL CONFORM TO MANUFACTURER'S SPECIFICATIONS, APPLICABLE CODES TO AUTHORITY HAVING JURISDICTION.

THE CONTRACTOR SHALL BE RESPONSIBLE TO PATCH & MAKE GOOD ALL EXISTING CONSTRUCTION AFFECTED BY THE REMOVAL OF ALL ITEMS FORMING PART OF THE RENOVATION WORK.

UNLESS OTHERWISE NOTED, ALL DEMOLISH & ABANDONED ELECTRICAL FIXTURES, COMPONENTS, RECEPTACLE & DATA WIRING SHALL BE REMOVED BACK TO SOURCE & TERMINATED AS PER APPLICABLE CODES. THIS INCLUDES WIRING CONTAINED IN HEADER DUCTS IN-FLOOR.

RECONNECT & TEST ALL FIRE PREVENTION EQUIPMENT.

WARNING: ASBESTOS IS PRESENT IN THE EAST & WEST AIR SHAFTS & ENCLOSED COLUMNS.

KEY PLAN
 SCALE: N.T.S.

ABBREVIATIONS	
	DESCRIPTION
A	AMPERE, AMPACITY
AC	ABOVE COUNTER
ACT	ACOUSTIC CEILING TILE
AFF	ABOVE FINISH FLOOR
CCT	CIRCUIT, CCT: C= PANEL "T"; CT= CIRCUIT "1" (T1)
CLNG	CEILING
D	DEMOLITION, REMOVE BACK TO SOURCE
DA	DOOR ACTUATOR
DED	DEDICATED CIRCUIT
DSW	DISCONNECT SWITCH
DWG	DRAWING
E	EXISTING OR 'NO DESIGNATION'
ES	ELECTRIC STRIKE
GFCI	GROUND FAULT CIRCUIT INTERRUPTER
HZ	HERTZ
JB	JUNCTION BOX
N	NEW
N.I.C.	NOT IN CONTRACT
NTS	NOT TO SCALE
O/C	ON CENTER
OS	OCCUPANCY SENSOR
PNL	PANEL
R	RELOCATED LOCATION
RECP.T.	RECEPTACLE
SW	SWITCH
TBD	TO BE DETERMINED
TYP.	TYPICAL

ELECTRICAL LEGEND	
TYPE	DESCRIPTION
⊕	DUPLEX RECEPTACLE
⊕#	FLOOR RECEPTACLE PEDESTAL WITH DUPLEX OR QUAD RECEPTACLES
⊕#	HEIGHT IN INCHES ABOVE FINISH FLOOR TO CENTERLINE OF DEVICE
⊕#	2-GANG DUPLEX RECEPTACLE
⊕#	GROUND FAULT CIRCUIT INTERRUPTER DUPLEX RECEPTACLE
⊕	LIGHT SWITCH, SINGLE POLE
+DGS	DURESS CALL BUTTON, AMSECO MODEL HUB-M, CONVERT TO LATCHING OPERATION
ES	ELECTRIC STRIKE
CA	CARD ACCESS, MULTICLASS SE READER, MINI MILLION SIZE, HID PART # RP10, BLACK
CA	CARD ACCESS, MULTICLASS SE READER, LARGE WALL MOUNT, HID PART # RP40, BLACK
EX	DOOR CONTACT - FLUSH MOUNT, GE MODEL # 10760W
⊕	JUNCTION BOX
FP	FIRE ALARM MANUAL PULL STATION
⊕	FIRE ALARM STROBE SIREN
⊕	HEAT DETECTOR, CEILING RECESSED
⊕	SPEAKER
▷	DATA PORT
⊕	FLOOR DATA PEDESTAL WITH DATA PORT(S)
◀	VOICE (PHONE) PORT: CENTREX LAND LINE
⊕	FLOOR PHONE PEDESTAL WITH PHONE PORT(S)
⊕	HORN - SECURITY
⊕	MOTION DETECTOR-SECURITY
PNL	ELECTRICAL PANEL
⊕	NETWORK ACCESS POINT
⊕	THERMOSTAT
◀CAM	SAMSUNG CAMERA/IR ACTIVITY, SNV6085R, INCLUDE GENETEC LICENCE.

ELECTRICAL DEMOLITION NOTES: "X"


ALSO SEE NOTES & SPECIFICATIONS.
 ABANDONING PARTIAL DEMOLISH CABLES, WIRES, COMPONENTS & SUPPORTS IS NOT ALLOW IN AREA OF WORK.
 DO NOT DISTURB OR DISCONNECT ANY ACTIVE WIRING & CABLING IN AREA OF WORK REQUIRED FOR OTHER AREAS. CONSULT WITH CONTRACT ADMINISTRATOR WHEN IN DOUBT.
 ALL DISCARDED COMPONENTS SHALL BE DISPOSED OFF IN ENVIRONMENTAL COMPLIANCE WITH BY-LAWS & INDUSTRY STANDARDS.
 ALL ELECTRICAL WORK TO BE PERFORMED BY QUALIFIED ELECTRICIAN.

- DISCONNECT, REMOVE & DISCARD ALL CEILING LUMINARIES INCLUDING ASSOCIATED CONDUITS, SUPPORTS & (JB) IN AREA OF WORK BACK TO EXISTING CEILING-MOUNTED CABLE TRAY. REWIRE CIRCUIT WHEN SERVING OTHER AREAS OUTSIDE BOUNDARY SHOWN.
- LUMINARIES ALONG THE WEST EXTERIOR WALL BULKHEAD TO REMAIN.
- EXISTING COMMUNICATION CABLES, FIRE PREVENTION CABLES, FIRE ALARM CABLES TO REMAIN - DO NOT CUT. RE-SUPPORT SECURELY FOR REUSE IN RENOVATION.
- EXISTING FLOOR RECEPTACLE PEDESTALS & FLOOR DATA PEDESTALS TO REMAIN. REMOVE FLOOR TELEPHONE PEDESTALS & CAT 3 CABLES BACK TO SOURCE. CAP PEDESTAL OPENINGS WITH SCREW FASTEN STEEL COVER BLANKS TO ALLOW FOR A SMOOTH LEVEL FINISH FOR NEW CARPET TILE, SEE ARCHITECTURAL DRAWINGS.
- EXISTING STAINLESS STEEL FLOOR PEDESTAL BLANK COVERS TO REMAIN. REWORK LOOSE BLANK COVERS TO MAKE TIGHT AGAINST FLOOR.

PARTIAL MAIN FLOOR REFLECTED CEILING AND FLOOR PLAN - DEMOLITION
 SCALE: 1/4"=1'-0"

DRAWING LIST - ELECTRICAL	
SHEET No:	SHEET TITLE
E1	PARTIAL MAIN FLOOR REFLECTED CEILING AND FLOOR PLAN: DEMOLITION; POWER, LIGHTING AND COMMUNICATION
E2	PARTIAL MAIN FLOOR PLAN: RENOVATION; POWER AND SYSTEMS
E3	PARTIAL MAIN FLOOR REFLECTED CEILING AND FLOOR PLAN: RENOVATION; LIGHTING AND LIFE SAFETY
E4	ELECTRICAL SPECIFICATIONS

No.	REVISION/DESCRIPTION	BY	DATE
0	ISSUED FOR CONSTRUCTION	DTA	2019.11.12



DRAWN	CHECKED	DESIGNED	APPROVED
DATE: 2019.10.28	USER		

THE CITY OF WINNIPEG
 PLANNING, PROPERTY AND
 DEVELOPMENT DEPARTMENT
 MUNICIPAL ACCOMMODATIONS DIVISION
 3-65 GARRY STREET, R3C 4K4

PROJECT
 ADMINISTRATION BUILDING
 PARTIAL MAIN FLOOR NORTH-WEST
 WING ABATEMENT AND RENOVATIONS
 510 MAIN STREET
 BID OPPORTUNITY: 1202-2019

SHEET TITLE
 PARTIAL MAIN FLOOR REFLECTED CEILING
 AND FLOOR PLAN - DEMOLITION
 POWER, LIGHTING AND COMMUNICATIONS

SCALE	PROJECT No:	SHEET No:
AS SHOWN	2019-123-01	E1