Appendix A

Repair Requirements

2018 Sewer Renewals by CIPP Lining, Contract 6, Bid Opportunity 183-2019

Appendix A - Repair Requirements

	Sewer Details														Pre-Lining Inspection																		
						Manholes					Size					Lump Sum Anulus Grouting per Location		Patching		Removal of Intruding Connections		Removal Roots and Grease		Solid Debris Cutting / Other					Sewer Service Grouting - Man Entry for Sewers >750mm		External Point Repair (EPR) by Others	
	DWG	Sheet	Sewer Asset	Street Name	Location	Upstream	Depth	Downstream	Depth	Length	Height	Width	Shape	Flow Type	Material	Sewer Services	Anulus Grouting	Description	Patch Tender <=1m	Patch Tender >=1m	Description	Intrud Conn Tender	Description	Root Tender	Description	Tender 1st 3m	Tender >3m (m)	Tender at Joints	Description	Service Grouting	Description	Distance	Description
1	12071	1	S-MAS0004238	DUBUC ST	MH AT CHAMPLAIN ST TO MH AT GENTHON ST (W PL)	S-MH70063574	5.90	S-MH70063591	5.75	99.3	450		CIRCULAR	COMBINED	VC-VITRIFIED CLAY	15						9	2.1M CNI @ 11 DS; 2.4M CNI @ 11 DS; 16.5 CNI @ 11 DS; 20.3M CNI @ 2 DS; 32.1 CNI @ 12 DS; 46.6M CNI @ 12 DS; 51.4 CNI @ 2 DS; 66.3M CNI @ 2 DS; 18.2M CNI @ 11 US;			1		17	9.8M ELI @ 8-3 DS; 11.3M ELI @ 8-4 DS; 12.1M EMJ @ 8-4 DS; 14.4 ELI @ 9-11 DS; 15.3 ELI @ 8 DS; 16.4M EM(CN) @8-12 DS; 18.8M EL(CN) @ 8-9 DS; 20.1M EM(CN) @ 2-4 DS; 32.1 EM(CN) @9-11 DS; 46.8 EL(CN) @ 8-12 DS; 73.0 ELI @ 2-4 DS; 75.2 ELI @ 1-4 DS; 77.3 EM(CN) @ 8-11 DS; 3.0M ELI @ 8-10 US; 13.2M ELI @ 8-2 US; 14.2 EL @ 9, 3 US; 18.2M EM(CN) @ 8-3 US; 20.1M EM (CN) @ 3 US;				
2	12072	2	S-CLS0004370	EASEMENT (N OF NIVERVILLE AV)	1ST CB W OF TRAVERE AV TO NODE AT TRAVERSE AV	S-CBS0003732	1.00	S-MH70069675	2.46	43.3	250		CIRCULAR	STORM	CO-CONCRETE	0								1.0	0.0M RFJ @ 4-6 DS; 2.5M RFJ @ 7 DS; 13.5M RFJ @ 5 DS; 14.3M RFJ @ 7 DS; 15.1M RFJ @ 5, 8 DS; 23.5M RF @ 1-3 DS;			1		3	16.6M ELI @ 6-7 DS; 17.4M ELI @ 3-6 DS; 38.2M ELI @ 8 DS;				
3	12073	3	S-MAS0004037	CRAWFORD AV (CL)	1ST MH N OF LYNDALE DR TO 2ND MH N OF LYNDALE DR	S-MH50003503	3.11	S-MH50003504	3.21	80.4	300		CIRCULAR	COMBINED	VC-VITRIFIED CLAY	7						1.0	20.4M RMC(N) @ 3 DS; 23.0M RFJ @ 3 DS; 23.8M RMJ @ 4-8 DS; 24.6M RFJ @ 4 DS; 44.3M RFJ @ 5-7 DS; 49.9M EFJ @ 5 DS; 53.0M RFJ @ 4 DS; 53.8M RFJ @ 10 DS; 55.4M RFJ @ 10 DS; 56.3M RM(CN) @ 3 DS; 57.6M RFJ @ 1-3 DS; 59.0M RFJ @ 10 DS; 59.9M RMJ @ 8-10 DS; 60.7M RMJ @ 2-5, 8-10 DS; 61.5M RMJ @ 8-12, 3-5 DS; 62.2M RMJ @ 10, 3 DS; 63.0M RMJ @ 2-4, 9-11 DS; 63.9M RMJ @ 2-4, 8-10 DS; 65.3M RMJ @ 2-4, 9-11 DS; 66.1 RFJ @ 10-3 DS; 66.9M RMJ @ 2-5, 9 DS; 67.6M RFJ @ 3, 8 DS; 68.5M RMJ @ 2-5 DS; 69.3M RFJ @ 9 DS; 70.7M RFJ @ 4, 11 DS; 71.8M RM(CN) @ 3 DS; 72.4M RFJ @ 10 DS; 73.1M RMJ @ 7-10 DS; 73.9M RMJ @ 4 DS; 74.4M RF @ 10 DS; 74.7M RFJ @ 8-3 DS; 75.4M RMJ @ 7-10 DS; 76.3M RMJ @ 7-11 DS; 77.0M RFJ @ 1-5, 8-10 DS; 77.9M RFJ @ 2-4 DS; 78.6M RFJ @ 2-4 DS;79.3M RFJ @ 2,4, 9 DS;			1		27	4.7M ELI @ 4-8 DS; 7.1M ELI @ 5-8 DS; 8.6M ELI @ 7 DS; 10.2M ELI @ 5 DS; 11.0M ELI @ 5-8 DS; 11.8M ELI @ 3 DS; 13.4M ELI @ 9 DS; 14.2M ELI @ 4 DS; 14.9 ELI @ 4, 9 DS; 16.4M ELI @ 9-10 DS; 17.2M ELI @ 4, 7-9 DS; 18.0M ELI @ 4, 7-9 DS; 18.8M ELI @ 3 DS; 18.8M ELI @ 9 DS; 20.2M ELI @ 3, 9 DS; 20.9M ELI @ 4 DS; 22.3M ELI @ 2-4 DS; 23.0M ELI @ 3-5, 8 DS; 25.4M ELI @ 4 DS; 26.2M ELI @ 9 DS; 39.9M ELI @ 8 DS; 41.2M ELI @ 7 DS; 43.5M ELI @ 5 DS; 45.2 ELI @ 4, 8 DS; 48.3M ELI @ 9 DS; 53.0 ELI @ 9 DS; 68.5M ELI @ 9 DS; 73.1M ELI @ 11 DS;				
4	12074	4	S-MAS0007290	HAIG AVE	1ST MH W OF EGERTON RD - MH @ EGERTON RD	S-MH50006243	2.52	S-MH50006244	3.11	22.7	300		CIRCULAR	COMBINED	CO-CONCRETE	0								1.0	8.2M RFJ @ 8 DS;			1		4	5.7M ELI @ 6 DS; 9.1M EL @ 7-9 DS; 12.2M EL @ 4 DS; 14.2M EL @ 6 DS; 16.7M ELI @ 7 DS; 18.0M ELI @ 7 DS; 18.8M ELI @ 6-9 DS;				
5	12075	5	S-MAS0013419	VIVIAN AV	1ST MH WOF DES MEURONS ST TO MH@ DES MEURONS ST	S-MH50006249	4.38	S-MH50010781	4.63	112.6	450		CIRCULAR	COMBINED	PVC-POLYVINYL CHLORIDE	20					2 34.0M CNI @ 11 DS; 34.7M CNI @ 2 DS;	1.0	0.2M RFJ @ 9 DS; 12.8M RTJ @ 3 DS; 65.7M RF (CN) @ 2 DS; 111.2M RF(CN) @ 2 DS;			1		11	23.7M ELI @ 3-4 DS; 33.8M EL (CN) @ 8-10 DS; 42.6M EL @ 11-4 DS; 43.8M ELI @ 2-6 DS; 48.3M ELI @ 4, 9 DS; 50.8M EL(CN) @ 3 DS; 54.9M EL @ 8-4 DS; 55.8M ELI @ 9-12 DS; 57.3M ELI @ 2-5 DS; 57.0M ELI @ 9 DS; 62.2M ELI @ 1-3 DS; 69.2M EL @ 3 DS; 70.1M ELI @ 1-4 DS;				
6	12076	6	S-MAS0013162	IMPERIAL AV	MH AT DES MEURONS ST-1ST MH W OF DES MEURONS ST	S-MH50010577	4.54	S-MH50010578	4.81	142.5	375		CIRCULAR	SANITARY	VC-VITRIFIED CLAY	22					7 11.7M CNI @ 1 DS; 14.3M CNI @ 11 DS; 15.6M CNI @ 1 DS; 48.6M CNI @ 1 DS; 121.6M CNI @ 11 DS; 122.3M CNI @ 1 DS; 141.7M CNI @ 2 DS;			1		47	1.2M EL @ 5 DS; 2.1M ELI @ 4, 8 DS; 3.0M ELI @ 4 DS; 3.7M ELI @ 8-11, 2-3 DS; 4.6M ELI @ 10 DS; 5.2M ELI @ 8 DS; 9.1M ELI @ 7-11, 1-5 DS; 10.0M ELI @ 2-4 DS; 10.8M ELI @ 12 DS; 21.7M ELI @ 3-4, 8-9 DS; 23.2M ELI @ 9 DS; 29.9M EL(CN) @ 8-11 DS; 34.8M ELI @ 12-4 DS; 41.1M ELI @ 4, 7 DS; 43.6M ELI @ 8 DS; 44.2M ELI @ 7-10 DS; 46.6M ELI @ 3-10 DS; 49.8M ELI @ 1-4 DS; 50.4M ELI @ 8 DS; 52.0M ELI @ 9 DS; 55.3M ELI @ 1-4, 8-11 DS; 56.0M ELI @ 1-3, 8-10 DS; 56.7M ELI @ 2-4 DS; 58.9M ELI @ 1-4, 8 DS; 66.2M ELI @ 2-3, 9 DS; 66.0M ELI @ 1-3 DS; 66.8M ELI @ 8-3 DS; 67.5M ELI @ 8 DS; 68.4M ELI @ 9-11 DS; 69.0M ELI @ 8 DS;70.1M EL(CN) @ 7-10 DS; 72.3M ELI @ 8-11 DS; 73.7M ELI @ 12-4, 8-10 DS; 74.5M ELI @ 4, 8-10 DS; 81.6M ELI @ 7 DS; 86.2M ELI @ 8-2 DS; 87.0M ELI @ 8 DS; 90.9M ELI @ 3-5 DS; 97.2M ELI @ 2-4, 8 DS; 97.9M ELI @ 1-4 DS; 103.4 ELI @ 2-4 DS; 105.0M ELI @ 5 DS; 120.6M ELI @ 1-3, 8-11 DS; 121.3M ELI @ 1-4, 9-11 DS; 122.3M EL(CN) @ 10-3 DS; 132.4M EL(CN) @ 8-10 DS; 137.6M ELI @ 3 DS; 138.5M ELI @ 2-5 DS;				
7	12077	7	S-MAS0015663	ST MARK'S PL	1ST MH E OF MAGER DR W TO 2ND MH E OF MAGER DR W	S-MH50012527	3.75	S-MH50012528	4.47	82.5	300		CIRCULAR	COMBINED	VC-VITRIFIED CLAY	11					3 24.8M CNI @ 2 DS; 65.9M CNI @ 10 DS; 71.7M CNI @ 1 DS;	1.0	17.2M RFJ @ 11 DS; 24.8M RF(CN) @ 3 DS; 41.4M RF(CN) @ 2 DS; 79.9M RFJ @ 9 DS; 80.8M RFJ @ 12 DS; 81.5M RFJ @ 4, 8 DS;			1		13	7.6M ELI @ 1-5 DS; 14.1M ELI @ 8 DS; 16.7M EL(CN) @ 2 DS; 20.2M ELI @ 4 DS; 21.0M ELI @ 4, 7-9 DS; 21.7M ELI @ 7-9 DS; 24.1M EL(CN) @ 8 DS; 27.0M ELI @ 8 DS; 29.0M EL @ 1-2 DS; 29.6M ELI @ 8-4 DS; 41.4M ELI @ 4 DS; 58.6M OBJ (PLASTIC) @ 5 DS; 73.8M ELI @ 3 DS; 75.4M ELI @ 4, 8 DS;				
8	12078	8	S-MAS0014352	ELM PARK RD	2ND MH E OF KILLARNEY ST-3RDMH E OF KILLARNEY ST	S-MH50011473	4.30	S-MH50011474	4.77	112.4	300		CIRCULAR	COMBINED	VC-VITRIFIED CLAY	17					2 20.1M CNI @ 2 DS; 21.0M CNI @ 11 DS;	1.0	8.4M RFJ @ 12 DS; 10.8M RFJ @ 4 DS; 12.3M RFJ @ 12 DS; 13.1M RFJ @ 11-1 DS; 13.9M RFJ @ 12-3 DS; 14.7M RFJ @ 11 DS; 15.4M RFJ @ 11-1 DS; 16.2M RFJ @ 9 DS; 17.8M RFJ @ 9 DS; 18.6M RFJ @ 10, 3 DS; 21.7M RFJ @ 4 DS; 23.3M RFJ @ 3 DS; 23.6M RF (CN) @ 1 DS; 27.9, 9 RF @ 12 DS; 28.8M RFJ @ 12 DS; 30.3M RFJ @ 11 DS; 31.1M RFJ @ 10, 2 DS; 32.6M RFJ @ 11 DS; 34.9M RFJ @ 2 DS; 35.7M RFJ @ 9 DS; 37.2M RFJ @ 9 DS; 38.0M RFJ @ 9 DS; 39.8M DEG @ 10 DS; 45.7M RFJ @ 4 DS; 54.3M RFJ @ 2 DS; 56.5M RFJ @ 12 DS; 58.4M RF(CN) @ 9 DS; 58.8M RFJ @ 9-3 DS; 59.6M RFJ @ 2-4 DS; 60.1M DEG @ 2 DS; 60.4M RFJ @ 10-2 DS; 61.2M RFJ @ 9-3 DS; 61.9M RFJ @ 9, 12 DS; 62.8M RFJ @ 10-12 DS; 63.5M RFJ @ 1 DS; 64.3M RFJ @ 9-3 DS; 65.1M RFJ @ 9-2 DS; 65.9M RFJ @ 12, 3 DS; 66.7M RFJ @ 3 DS; 67.5M RFJ @ 9-4 DS; 68.3M RFJ @ 8-12, 1 DS; 69.0M RFJ @ 11-1 DS; 69.4M RF(CN) @ 2 DS; 69.7M RFJ @ 10, 2 DS; 72.1M RFJ @ 2-4 DS; 72.9M RFJ @ 1-3 DS; 73.7M RFJ @ 10-12, 3 DS; 74.7M RFJ @ 2 DS; 76.8M RFJ @ 9-2 DS; 77.6M RFJ @ 10, 2 DS; 78.4M RFJ @ 10, 4 RD; 79.3M RFJ @ 10-3 DS; 81.0M RFJ @ 8-10 DS; 82.8M RFJ @ 3 DS; 84.3M RFJ @ 8-10 DS; 86.0M RFJ @ 9 DS; 89.6M RFJ @ 9 DS; 90.5M RFJ @ 12 DS; 91.0 M RF(CN) @ 10 DS; 97.6M RFJ @ 11 DS; 105.1M RF(CN) @ 10 DS;			1		4	32.6M DE @ 6 DS; 51.4M DE @ 6 DS; 57.3M ELI @ 12 DS; 61.0M EL @ 3 DS; 71.4M ELI @ 5 DS;			0.7	EPR FROM 90.5-91.2m DS
9	12079	9	S-MAS0014340	SPRINGSIDE DR	1ST MH E OF KILLARNEY S TO 2ND MH E OF KILLARNEY	S-MH50011462	3.97	S-MH50011464	4.25	109.6	375		CIRCULAR	COMBINED	VC-VITRIFIED CLAY	15					2 19.2M CNI @ 11 DS; 36.1M CNI @ 10 DS;	1.0	53.7M RF(CN) @ 9 DS; 73.4M DEG @ 10, 2 DS; 74.9-76.1M DEG @ 10, 2 DS; 76.2-79.3M DEG @ 2 DS; 79.7M DEG @ 1 DS; 99.7M DEG @ 9, 3 DS; 101.4M DEG @ 3 DS; 103.5M DEG @ 9 DS; 105.1-106.7M DEG @ 3 DS; 107.3M DEG @ 3 DS;			1		1	36.1M EL(CN) @ 7-10 DS;				
10	12080	10	S-MA60013612	CHURCHILL DR	2ND MH W OF MONTGOMERY TO 1ST MH W OF MONTGOMERY	S-MH60011704	2.83	S-MH60011709	3.50	98.4	300		CIRCULAR	COMBINED	VC-VITRIFIED CLAY	7					1 76.3M CNI @ 10 DS;					1	0.4	10	1.5M ELI @ 5-7 DS; 2.4M ELI @ 7 DS; 3.2M ELI @ 8 DS; 3.9M ELI @ 7-8 DS; 7.0-10.4M EL @ 6 DS; 14.0M ELI @ 14 DS; 26.5M ELI @ 7 DS; 27.3M ELI @ 4 DS; 49.8M ELI @ 5, 7 DS; 59.0M ELI @12 DS; 69.1M ELI @ 4 DS;				
11	12081	11	S-MAS0001855	KINGSTON CR (SLEG)	1ST MH E OF RIVERDALE AVE- 2NDMHE OF RIVERDALE	S-MH50001622	2.55	S-MH50001623	2.91	121.4	300		CIRCULAR	COMBINED	VC-VITRIFIED CLAY	18					2 53.3M CNI @ 3 DS; 100.0M CNI @ 3 DS;	1.0	24.0M RF(CN) @ 3-4 DS; 26.7M RFJ @ 2 DS; 29.1M RFJ @ 8 DS; 30.6M RFJ @ 4, 8 DS; 31.4M RFJ @ 3, 8 DS; 32.1M RFJ @4, 8 DS; 32.9M RFJ @ 4, 8 DS; 33.7M RFJ @ 4 DS; 34.5M RFJ @ 4, 8 DS; 35.3M RFJ @ 8 DS; 36.1M RFJ @ 8 DS; 36.8M RFJ @ 3 DS; 37.0M RF(CN) @ 3 DS; 47.1M DEG @ 12 DS; 60.7M RFJ @ 12, 4 DS; 62.3M RFJ @ 2-4, 8-10 DS; 63.1M RFJ @ 9-11, 3 DS; 63.8M RFJ @ 11, 3 DS; 64.7M RFJ @ 8-11, 4 DS; 65.4M RFJ @ 9-3 DS; 66.2M RFJ @ 9-1 DS; 66.9M RFJ @ 9, 1 DS; 67.7M RFJ @ 10 DS; 68.5M RFJ @ 9-11; 2-4 DS; 68.7M RF(CN) @ 10 DS; 69.3M RMJ @ 8-11, 2-4 DS; 70.1M RFJ @ 10, 2 DS; 71.6M RFJ @ 11-1 DS; 72.4M RFJ @ 10-2 DS; 73.2M RFJ @ 9-10, 1-3 DS; 73.9M RMJ @ 7-12 DS; 74.7M RFJ @ 10, 2-3 DS; 75.5M RMJ @ 10-4 DS; 76.3M RFJ @ 8-3 DS; 76.5M RF(CN) @ 7-10 DS; 77.8M RFJ @ 8-2 DS; 78.7M RMJ @ 6-4 DS; 79.4M RMJ @ 6-5 DS; 80.2M RMJ @ 8-4 DS; 81.0M RMJ @ 8-10, 2-5 DS; 81.7M RFJ @ 8-10, 3 DS; 82.5M RFJ @ 8 DS; 83.2M RFJ @ 4, 9 DS; 84.1M RFJ @ 1-4 DS; 84.8M RFJ @ 3, 9 DS; 85.6M RFJ @ 10 DS; 86.3M RFJ @ 8-11 DS; 87.1M RFJ @ 10-3 DS; 87.8M RFJ @ 12 DS; 89.4M RFJ @ 10, 2-4 DS; 90.2M RFJ @ 9-3 DS; 91.0M RFJ @ 8-11, 1-5 DS; 91.4M RF(CN) @ 8-10 DS; 91.8M RMJ @ 2-4, 7-11 DS; 92.5M RFJ @ 9-12 DS; 93.3M RFJ @ 9-3 DS; 94.1M RFJ @ 9-3 DS; 94.8M RMJ @ 9-5 DS; 95.6M RFJ @ 8-5 DS; 96.4M RFJ @ 8-3 DS; 96.5M DEG @ 12 DS; 97.1M RFJ @ 8-3 DS; 98.0M RFJ @ 9-4 DS; 98.7M RFJ @ 8-4 DS; 99.5M RMJ @ 11, 1-5 DS; 100.3M RFJ @ 8-11, 2-4 DS; 100.7M DEG @ 12 DS; 101.0M RFJ @ 11-4 DS; 101.7M RMJ @ 9-5 DS; 102.5M RFJ @ 8-4 DS; 103.4M RMJ @ 7-4 DS; 104.9M RFJ @ 8-4 DS; 105.6M RFJ @ 8-2 DS; 106.4M RMJ @ 8-2 DS; 107.2M RMJ @ 8-2 DS; 107.6M RM(CN) @ 2-4 DS; 108.0M RFJ @ 9-4 DS; 108.7M RFJ @ 9-3 DS; 109.5M RFJ @ 8-3 DS; 110.2M RF @ 9-3 DS; 111.0M RFJ @ 9 DS; 111.8M RFJ @ 9 DS; 112.6M RFJ @ 8-3 DS; 113.4M RFJ @ 8-3 DS; 114.2M RFJ @ 8-11, 2 DS; 114.4M RF(CN) @ 10 DS; 115.0M RFJ @ 11-4 DS; 115.7M RFJ @ 11-3 DS; 116.6M RFJ @ 10-4 DS; 117.2M RFJ @10, 12-4 DS; 118.0M RFJ @ 8-4 DS; 118.8M RFJ @ 2-4 DS; 119.6M RFJ @ 9, 2-4 DS; 120.4M RFJ @ 9, 3 DS;			1		2	26.7M ELI @ 8 DS; 53.3M EL(CN) @ 4 DS;				
12	12082	12	S-MAS0014823	ARDEN AVE(N CURB)	1ST MH E OF DARWIN ST-2ND MH E OF DARWIN ST.	S-MH50011920	1.70	S-MH50011921	2.15	86.5	375*		CIRCULAR	STORM	CO-CONCRETE	2					1 85.8M CNI @ 2 US;	1.0	69.2M RFJ @ 8 US; 71.0M RFJ @ 8 US; 72.9M RFJ @ 3 US; 74.6M RFJ @ 4, 9 US; 76.5M RFJ @ 3-5 US; 78.3M RFJ @ 3-5 US; 80.2M RFJ @ 9 US; 81.9M RFJ @ 5 US;			1			87.2-88.5m DE @ 6.00 US;				
13	12083	13	S-MAS0006015	ARGONNE BAY (N LEG)	MH @ DRAKE BV- 1ST MH W DRAKE BV	S-MH50005111	1.76	S-MH50005112	2.66	39.1	375		CIRCULAR	STORM	CO-CONCRETE	0						1.0	0.0M RMJ @ 5-8 DS; 4.4M RFJ @ 4 DS; 8.3M RFJ @ 4 DS; 9.1M RFJ @ 4 DS; 9.8M RMJ @ 3-6 DS; 10.6M RFJ @ 4-8 DS; 12.1M RFJ @5 DS; 13.6M RFJ @ 4-6 DS; 30.0M RTJ @ 4 DS;									3.2	EPR FROM 0.0-3.2m DS
14	12084	14	S-MAS0005811	AUTUMNWOOD DR	1ST MH E OF BARBERRY RD (E LEG) TO MH AT DE BOURMONT BY (W LEG)	S-MH50004932	3.60	S-MH50004889	4.96	121.6	200		CIRCULAR	SANITARY	CO-CONCRETE	6					5 11.8M CNI @ 12 DS; 27.0M CNI @ 12 DS; 41.3M CNI @ 12 DS; 59.0M CNI @ 2 DS; 109.5M CNI @ 11 DS;	1.0	11.3M RFJ @ 8 DS; 11.8M RM(CN) @ 8-1 DS; 12.8M RFJ @ 8 DS; 17.9M RFJ @ 4 DS; 23.0 RFJ @ 12, 4 DS; 23.7M RFJ @ 4, 7 DS; 23.9M RF @ 8, 12 DS; 24.5M RFJ @ 7-12, 5 DS; 24.9M RF @ 9 DS; 26.0 RFJ @ 9 DS; 27.0M RM(CN) @ 7-5 DS; 27.6M RFJ @ 8, 1 DS; 28.3M RF @ 12 DS; 28.4M RFJ @ 8-2 DS; 29.1M RFJ @ 7-1 DS; 30.0 RFJ @ 12 DS; 30.7M RFJ @ 8 DS; 32.3M RFJ @ 8, 3 DS; 33.0 RFJ @ 8-3 DS; 33.8M RFJ @ 10-3 DS; 34.6M RFJ @ 2-4 DS; 35.4M RFJ @ 12, 4 DS; 37.8M RFJ @ 9 DS; 38.5M RFJ @ 9 3 DS; 39.3M RFJ @ 9-2 DS; 40.1M RFJ @ 9-12 DS; 41.3M RM(CN) @ 8-3 DS; 43.1M RFJ @ 9-3 DS; 43.9M RFJ @ 2 DS; 44.7M RFJ @ 1-3 DS; 45.5M RFJ @ 9-11 DS; 46.3M RFJ @ 9, 2-3 DS; 46.4M RF(CN) @ 8 DS; 47.8M RFJ @ 10-4 DS; 48.6M RFJ @ 8-10, 2-4 DS; 49.4M RMJ @ 1-5 DS; 50.2M RFJ @ 2-4 DS; 50.9M RFJ @ 9-12 DS; 51.7M RFJ @ 9-12 DS; 52.5M RFJ @ 9, 3 DS; 53.3M RFJ @ 10-3 DS; 54.1M RFJ @ 8-10, 4 DS; 54.8M @ 9-4 DS; 55.6M RMJ @ 7-10, 2-5 DS; 55.9M RF @ 8 DS; 56.4M RFJ @ 8-10, 12 DS; 56.6M RF @ 3 DS; 57.2M RTJ @ 2 DS; 57.3M RM(CN) @ 10-4 DS; 57.9M RFJ @ 4 DS; 58.7M RFJ @ 8-3 DS; 59.0M RM(CN) @ 2 DS; 59.0M RF @ 8-10 DS; 59.5M RFJ @ 8, 2 DS; 60.2M RFJ @ 8, 4 DS; 61.0M RFJ @ 8-10, 2-4 DS; 61.8M RFJ @ 7-9, 2-4 DS; 63.4M RFJ @ 3-5 DS; 64.3M RF @ 9 DS;			1	11.5	57	4.5M EL(CN) @ 8 DS; 5.1M ELI @ 2-4 DS; 5.4M EL @ 8-11 DS; 6.6M ELI @ 4 DS; 7.3M ELI @ 8 DS; 9.9M ELI @ 8 DS; 10.1M ELI @ 4 DS; 11.8M ELI @ 3-4 DS; 13.6M ELI @ 3-5, 8-10 DS; 15.1M ELI @ 7-10 DS; 16.7 ELI @ 1-4, 8-9 DS; 17.5M ELI @ 4, 8 DS; 17.9M ELI @ 4 DS; 18.3M ELI @ 2-4 DS; 19.0 ELI @ 7-5 DS; 19.8M ELI @ 7-8, 4 DS; 20.3M EMJ @ 7-5 DS; 21.4M ELI @ 7-10 DS; 22.2M ELI @ 8-12 DS; 23.7M EMJ @ 7-5 DS; 24.9M EL @ 8-10 DS; 25.3M ELI @ 8-11 DS; 26.0M ELI @ 7-5 DS; 26.5M EL @ 9 DS; 27.0M EL(CN) @ 2-5 DS; 27.6M ELI @ 12-4 DS; 28.4M ELI @ 8-4 DS; 29.3M ELI @ 7-11 DS; 30.7M ELI @ 1 DS; 32.5M EL(CN) @ 8 DS; 33.0 ELI @ 2-4 DS; 34.6M ELI @ 8-11 DS; 37.4-39.7M ELI @ 4, 8 DS; 39.8-41.3M ELM @ 8, 4 DS; 42.5M EL @ 9, 3 DS; 43.6M EL @ 4, 9 DS; 43.9M ELI @ 9-12 DS; 50.2M ELI @ 2 DS; 50.8-52.4M EL @ 4, 8 DS; 52.5M ELI @ 9-4 DS; 54.1M ELI @ 9-11 DS; 57.3M ELI(CN) @ 2-4 DS; 61.2M ELI @ 7-9 DS; 64.1M ELI @ 8 DS; 65.7M ELI @ 8-4 DS; 68.1M ELI @ 2-4 DS; 70.4M ELI @ 8-3 DS; 71.9M ELI @ 5-7 DS; 77.6M EL(CN) @ 7-9 DS; 82.9M EMJ @ 4-5, 7-10 DS; 84.1M EL @ 8-10 DS; 84.4M ELI @ 8-4 DS; 85.2M ELI @ 12-5 DS; 86.7M ELI @ 8-4 DS; 89.9M ELI @ 8-4 DS; 90.9M EL @ 12 DS; 91.0M EL @ 1-3 DS; 91.4M ELI @ 8-4 DS; 92.2M ELI @ 8-11 DS; 92.7M EL @ 12-3 DS; 94.6M ELI @ 2-4 DS; 101.4M ELI @ 8-12 DS; 109.5M EL(CN) @ 9 DS; 112.5M ELI @ 8-10, 2 DS; 114.1M ELI @ 8-4 DS; 114.8M ELI @ 4, 9-11 DS; 115.6M ELI @ 8-2 DS; 116.4M ELI @ 2 DS; 117.6M ELI @ 8-4 DS;				
15	12085	15	S-MAS0005817	AUTUMNWOOD DR (S OF CL)	1ST MH W OF BARBERRY RD (E LEG) TO MH AT FRONTENAC BY (W LEG)	S-MH50004937	2.65	S-MH50004936	3.95	49.8	250*		CIRCULAR	SANITARY	CO-CONCRETE	5					1 47.1M CNI @ 9 DS;	1.0	9.6M RFJ @ 4 DS; 11.2M RFJ @ 4, 8 DS; 11.9, RFJ @ 4, 8 DS; 17.4M RFJ @ 9-3 DS; 17.5M RM(CN) @ 7-11 DS; 46.8M RF @ 8 DS; 47.5M RM(CN) @ 9 DS; 2.2M RM @ 1-5 DS;									1.2	EPR FROM 47.0-48.2m DS
16	12086	16	S-MAS0005818	AUTUMNWOOD DR (S OF CL)	MH AT FRONTENAC BY (W LEG) TO 1ST MH W OF FRONTENAC BY (W LEG)	S-MH50004936	3.95	S-MH50004938	4.45	90.5	250		CIRCULAR	SANITARY	CO-CONCRETE	8					2 13.4M CNI @ 10 DS; 88.0M CNI @ 10 DS;	1.0	1.5M RFJ @ 11 DS; 2.0-3.2M EM @ 10, 2 DS; 1.3-4.8M EM @ 9-3 DS; 4.9M ELI @ 8, 12-2 DS; 7.1M EL @ 12 DS; 29.5M RM(CN) @ 10 DS; 36.5M RF(CN) @ 10 DS; 53.8M RF(CN) @ 11 DS; 68.5M RF(CN) @ 10 DS; 68.9M RFJ @ 2 DS;			1		4	36.5M EL(CN) @ 12-3 DS; 53.8M EL(CN) @ 12-4 DS; 68.5M EL(CN) @ 8-10 DS; 89.3M EMJ @ 8-4 DS;				
17	12087	17	S-MAS0005852	AUTUMNWOOD DR	1ST MH W OF FRONTENAC BY (W LEG) TO MH AT DRAKE BV	S-MH50004938	4.45	S-MH50004958	4.64	89.6	250		CIRCULAR	SANITARY	CO-CONCRETE	12					1 25.7M CNI @ 2 DS;					1		13	0.5M EL @ 9-1 DS; 11.4M ELI @ 11 DS; 18.5M ELI @ 11 DS; 20.9M ELI @ 11 DS; 25.7M EM(CN) @ 3-6 DS; 38.8M ELI @ 3 DS; 39.5M ELI @ 8-12, 4 DS; 52.1M ELI @ 9 DS; 54.4M ELI @ 8-12 DS; 58.4-60.0M ELI @ 9-1 DS; 60.7M ELI @ 10 DS; 61.5M ELI @ 8 DS; 64.6M ELI @9-3 DS; 65.3M EL @ 10, 2 DS; 77.8M ELI @ 8-11 DS;			1.6	EPR FROM 58.4-60.0m DS
18	12088	18	S-MAS0005850	AUTUMNWOOD DR	2ND MH W OF DRAKE BV TO 1ST MH W OF DRAKE BV	S-MH50004963	2.62	S-MH50004964	2.95	88.8	200		CIRCULAR	SANITARY	CO-CONCRETE	11					2 48.2M CNI @ 2 DS; 60.5M CNI @ 10 DS;	1.0	39.9M RFJ @ 8-4 DS; 40.6M RFJ @ 1-4 DS; 41.0M RF(CN) @ 9-12 DS; 42.2M RFJ @ 1-4, 8 DS; 43.0M RFJ @ 11-1 DS; 43.8M RFJ @ 3 DS; 48.2M RF(CN) @ 1 DS; 49.2M RFJ @ 8, 1-4 DS;			1		48	2.9M ELI @ 9-11 DS; 3.6M ELI @ 8 DS; 4.4M ELI @ 9-3 DS; 5.9M ELI @ 7-11 DS; 6.7M ELI @ 7-5 DS; 7.6M ELI @ 8-11 DS; 8.4M EM(CN) @ 7-10 DS; 11.4M ELI @ 8 DS; 12.2M ELI @ 8-11 DS; 13.0M ELI @ 8 DS; 16.9M ELI @ 8 DS; 17.7 ELI @ 8-11 DS; 18.5M ELI @ 7-10 DS; 19.3M ELI @ 8-10 DS; 20.8M ELI @ 4 DS; 21.6M ELI @ 7-5 DS; 22.1M ELI @ 3-4 DS; 22.9M ELI @ 8-11 DS; 23.7M ELI @ 12-4 DS; 24.5M ELI @ 2-4, 8 DS; 25.2M ELI @ 4, 8 DS; 26.0M ELI @ 3-4, 9 DS; 26.8M ELI @ 2-3, 7-10 DS; 29.3M EL @ 8-3 DS; 30.5M ELI @ 4, 8 DS; 31.2M ELI @ 8-4 DS; 36.7M ELI @ 8 DS; 37.5M ELI @ 4, 8 DS; 38.3M ELI @ 1-5, 7-10 DS; 39.1M ELI @ 7-9 DS; 40.6M ELI @7 DS; 41.0 ELI(CN) @ 2-5, 7-9 DS; 41.4M ELI @ 4 DS; 42.2M ELI @ 4 DS; 42.9M ELI @ 8 DS; 43.6M EL @ 1-4 DS; 43.8M ELI @ 5, 7 DS; 44.6M ELI @ 4, 8 DS; 44.8M EL(CN) @ 8 DS; 45.3M ELI @ 5, 7-9 DS; 46.1M ELI @ 5, 7-9 DS; 46.8M ELI @ 8 DS; 52.3M ELI @ 8 DS; 53.1M ELI @ 5, 7-9 DS; 53.9M ELI @ 4 DS; 59.6M EL(CN) @ 8 DS; 60.6M EL(CN) @ 12-5 DS; 60.9M ELI @ 8-4 DS; 63.2M ELI @ 8 DS; 85.3M EL(CN) @ 7-9 DS;				1.5	EPR FROM 0.5-2.0m DS
19	12089	19	S-MAS0005849	BARBERRY RD (S LEG)	1ST MH W OF BARBERRY RD (E LEG) TO MH AT DRAKE BV	S-MH50004962	6.05	S-MH50004959	4.43	106.9	250		CIRCULAR	SANITARY	CO-CONCRETE	13					3 20.7M CNI @ 12 DS; 43.5M CNI @ 11 DS; 45.7M CNI @ 2 DS;	1.0	88.3M RFJ @ 9-3 DS; 93.0M RFJ @ 1-4 DS; 93.8M RFJ @ 2-3 DS; 98.7M RF(CN) @ 9 DS; 105.5M RFJ @ 8-10 DS; 106.3M RFJ @ 3 DS;

2018 Sewer Renewals by CIPP Lining, Contract 6, Bid Opportunity 183-2019

Appendix A - Repair Requirements

	Sewer Details																Pre-Lining Inspection																	
	DWG	Sheet	Sewer Asset	Street Name	Location	Manholes				Length	Size		Shape	Flow Type	Material	Sewer Services	Lump Sum Anulus Grouting per Location		Patching			Removal of Intruding Connections		Removal Roots and Grease		Solid Debris Cutting / Other				Sewer Service Grouting - Man Entry for Sewers >750mm		External Point Repair (EPR) by Others	
						Upstream	Depth	Downstream	Depth		Height	Width					Anulus Grouting	Description	Patch Tender <=1m	Patch Tender >=1m	Description	Intrud Conn Tender	Description	Root Tender	Description	Tender 1st 3m	Tender >3m (m)	Tender at Joints	Description	Service Grouting	Description	Distance	Description
24	12094	24	S-MAS0005717	WINAKWA RD	MH AT HEATHER RD TO 1ST MH W OF HEATHER RD	S-MH50004857	5.10	S-MH50004858	5.15	121.6	200		CIRCULAR	SANITARY	CO-CONCRETE	2						2	21.5M CNI @ 10 DS; 49.9M CNI @ 11 DS;	1.0	17.4M DEG @ 8, 4 DS; 18.1M DEG @ 9, 3 DS; 19.6-21.0M DEG @ 10, 2 DS; 26.2M DEG @ 10, 2 DS; 27.3M DEG @ 11-1 DS; 48.2-49.8M DEG @ 8 DS; 78.3M DEG @ 11 DS; 78.9M DEG @ 10-2 DS; 79.8-81.0M DEG @ 8-4 DS; 81.5-81.1M DEG @ 8-1, 2-4 DS; 83.1-85.8M @ 8-4 DS; 86.4-90.8M DEG @ 8-4 DS; 91.3M DEG @ 9, 3 DS; 91.8-95.8M DEG @ 10-2 DS; 95.8M DEG @ 11-1 DS;	1		3	42.4M EL @ 2-4 DS; 44.6M EL @ 8-11 DS; 65.1M ELJ @ 12-5 DS;				
25	12095	25	S-MAS0006265	BETOURNAY ST	MH AT JUBINVILLE BY (W LEG) TO MH AT SPEERS RD	S-MH50005341	5.61	S-MH50004881	5.50	90.9	300		CIRCULAR	SANITARY	CO-CONCRETE	6						1	14.2M CNI @ 12 DS;	1.0	12.5M RFJ @ 8 DS; 48.9M RF(CN) @ 12 DS; 52.4M RFJ @ 8 DS; 53.2M EFJ @ 4, 8 DS; 60.7-62.2M DEG @ 1-2 DS; 67.9-67.3M DEG @ 11-1 DS; 78.7M DEG @ 1 DS; 84.3-85.7M DEG @ 11, 1 DS; 86.7M DEG @ 11, 1 DS;	1		8	21.6M ELJ @ 1-4 DS; 40.1M ELJ @ 8-11 DS; 41.7M ELJ @ 8 DS; 44.8M EL(CN) @ 3-4 DS; 46.3M ELJ @ 2, 4 DS; 48.9M EL(CN) @ 3-8 DS; 57.5M EL(CN) @ 2-4 DS; 65.7M ELJ @ 4 DS;				
26	12096	26	S-MAS0006268	JUBINVILLE BY (W LEG)	1ST MH N OF JUBINVILLE BY (S LEG) TO MH AT BETOURNAY ST	S-MH50005344	4.08	S-MH50005341	5.61	64.0	200		CIRCULAR	SANITARY	CO-CONCRETE	9						5	3.0M CNI @ 2 DS; 4.2M CNI @ 2 DS; 4.4M CNI @ 11 DS; 56.3M CNI @ 2 DS; 59.9M CNI @ 11 DS;	1.0	41.9M RF(CN) @ 12 DS;	1		16	11.0M ELJ @ 4, 8 DS; 15.0M ELJ @ 12-4 DS; 17.3M ELJ @ 3-4 DS; 18.4M EL(CN) @ 4 DS; 29.8M ELJ @ 2-4, 8-10 DS; 30.6M ELJ @ 2-5 DS; 31.5M ELJ @ 5, 7-10 DS; 32.0M EL @ 8-10 DS; 33.7M ELJ @ 7-10, 12-5 DS; 34.5M ELJ @ 8-4 DS; 35.4M EMJ @ 8-4 DS; 36.1M ELJ @ 2-4 DS; 37.7M ELJ @ 4, 8 DS; 41.5M EL @ 12-2 DS; 41.9M EL(CN) @ 9-3 DS; 43.2M ELJ @ 10 DS; 51.1M ELJ @ 10 DS; 56.3M EL(CN) @ 2-4 DS;				
27	12097	27	S-MAS0006335	NORTHUMBRIA BY (N LEG)	1ST MH W OF NORTHUMBRIA BY (E LEG) TO MH AT NORTHUMBRIA BY (E LEG)	S-MH50005400	3.00	S-MH50005401	3.20	41.8	250		CIRCULAR	SANITARY	CO-CONCRETE	6								1.0	17.6M RFJ @ 3 DS; 25.9M RFJ @ 8-3 DS;	1		6	4.1M EL(CN) @ 3-5 DS; 17.2M EL @ 1-3 DS; 17.3M EL(CN) @ 2-5 DS; 28.6M EL(CN) @ 8 DS; 29.0M ELJ @ 4, 8 DS; 32.8M EMJ @ 7-5 DS; 39.0M ELJ @ 8-10 DS;				
28	12098	28	S-MAS0006393	NEWARK RD	1ST MH N OF COTTONWOOD RD TO MH AT COTTONWOOD RD	S-MH50005451	1.81	S-MH50005452	2.05	75.9	375		CIRCULAR	STORM	CO-CONCRETE	0										1		3	27.1M ELJ @ 5 DS; 28.4M ELJ @ 6 DS; 49.0M ELJ @ 6-7 DS;				
29	12099	29	S-MAS0006058	CANBERRA RD (S LEG)	1ST MH W OF CANBERRA RD (E LEG) TO 2ND MH W OF CANBERRA RD (E LEG)	S-MH50004824	3.40	S-MH50004832	3.93	87.2	250		CIRCULAR	SANITARY	CO-CONCRETE	15								1.0	22.5-25.4M DEG @ 8, 4 DS; 25.5-27.0M DEG @ 10, 2 DS; 27.1-29.6M DEG @ 9-3 DS; 30.2M DEG @ 10-2 DS; 32.5M DEG @ 11-1 DS; 81.0M RF(CN) @ 2 DS;	1		25	2.1M ELJ @ 10-3 DS; 4.0M ELJ @ 8-4 DS; 7.6M ELJ @ 4 DS; 11.3M ELJ @ 1-5, 8 DS; 15.0M ELJ @ 7-11 DS; 16.8M ELJ @ 8-4 DS; 18.8M ELJ @ 8-12 DS; 20.5M ELJ @ 1-5 DS; 22.3M ELJ @ 12-4 DS; 26.0M ELJ @ 12-3 DS; 51.8M ELJ @ 10-2 DS; 53.7M ELJ @ 1-4 DS; 55.5M ELJ @ 12-5 DS; 59.1M ELJ @ 4 DS; 61.1M ELJ @ 7-11, 2-5 DS; 62.8M ELJ @ 2-4 DS; 64.6M EMJ @ 7-4 DS; 71.9M ELJ @ 1-4 DS; 72.3M EL(CN) @ 6-9 DS; 73.7M ELJ @ 1-4, 8 DS; 76.3M ELJ @ 7-5 DS; 77.5M ELJ @ 4 DS; 80.6M ELJ @ 2-4 DS; 83.5M ELJ @ 2-4 DS; 84.8M ELJ @ 8-11, 1-4 DS;				
30	12100	30	S-MAS0005602	CONIFER CR (W LEG)	1ST MH N OF CONIFER CR (S LEG) TO 2ND MH N OF CONIFER CR (S LEG)	S-MH50004779	4.15	S-MH50004780	4.70	110.1	200		CIRCULAR	SANITARY	CO-CONCRETE	14						1	9.2M CNI @ 11 DS;	1.0	1.8M DEG @ 12 DS; 3.6M DEG @ 12 DS; 6.9M DEG @ 12 DS; 8.3M DEG @ 12 DS; 17.2M DEG @ 11-1 DS; 19.1M DEG @ 12 DS; 57.9M DEG @ 10, 2 DS; 58.9-61.6M DEG @ 9-3 DS; 65.3M DEG @ 10, 2 DS; 67.0M DEG @ 11-1 DS; 73.4M DEG @ 1-3 DS; 74.7M DEG @ 11-1 DS; 74.7M DEG @ 10, 2 DS; 76.6M DEG @ 12-2 DS; 98.2, DEG @ 2 DS; 99.4M DEG @ 11, 1-2 DS;	1		10	6.6M ELJ @ 1-4 DS; 9.2M EL(CN) @ 7-3 DS; 12.9M ELJ @ 7-10 DS; 43.0M ELJ @ 8-10 DS; 43.5M ELJ @ 8-3 DS; 45.3M ELJ @ 1-4 DS; 50.7M ELJ @ 8-2 DS; 94.9M ELJ @ 8-4 DS; 95.8M ELJ @ 10-12 DS; 109.2M ELJ @ 8-4 DS;				
31	12101	31	S-MAS0005185	CRESTWOOD CR (W LEG)	2ND MH N OF CRESTWOOD CR (S LEG) TO 3RD MH N OF CRESTWOOD CR (S LEG)	S-MH50004417	4.10	S-MH50004419	4.15	62.9	250		CIRCULAR	SANITARY	CO-CONCRETE	8						2	4.9M CNI @ 2 DS;7.0M CNI @ 10 DS;	1.0	7.0M RF(CN) @ 9 DS; 16.7M RFJ @ 8 DS;	1		24	4.9M EL(CN) @ 4 DS; 7.0M EL(CN) @ 4 DS; 7.4M EL @ 8 DS; 11.3M ELJ @ 8-9 DS; 12.0M ELJ @ 3-5, 7-9 DS; 13.7M ELJ @ 8-11 DS; 14.4M ELJ @ 7-10 DS; 16.0M ELJ @ 2-4 DS; 16.7M ELJ @ 2-5 DS; 17.5M ELJ @ 8-5 DS; 19.9M ELJ @ 4 DS; 20.5M ELJ @ 2-4 DS; 23.6M ELJ @ 2-4, 8 DS; 24.3M ELJ @ 5 DS; 26.8M ELJ @ 7-9, 4 DS; 28.3M ELJ @ 3 DS; 31.4M ELJ @ 10 DS; 39.2M ELJ @ 4 DS; 44.6M ELJ @ 3-4 DS; 46.9M ELJ @ 9, 1-4 DS; 50.0M ELJ @ 1-3 DS; 53.2M ELJ @ 8-3 DS; 54.8M ELJ @ 8-4 DS; 56.3M ELJ @ 8-10, 1 DS;				
32	12102	32	S-MAS0005170	CRESTWOOD CR (S LEG)	4TH MH E OF CRESTWOOD CR (W LEG) TO MH AT AUTUMNWOOD DR	S-MH50004407	4.85	S-MH50004379	4.90	83.3	250		CIRCULAR	SANITARY	CO-CONCRETE	9						5	1.3M CNI @ 2 DS; 14.9M CNI @ 10 DS; 16.3M CNI @ 2 DS; 47.8M CNI @ 10 DS; 49.1M CNI @ 12 DS;	1.0	46.0-47.3M DEG @ 11-1 DS;	1		28	0.7M EL @ 4 DS; 1.3M EL(CN) @ 4 DS; 3.1M ELJ @ 10 DS; 4.8M ELJ @ 8-10 DS; 5.4M ELJ @ 2-4 DS; 6.2M ELJ @ 11-3 DS; 7.0M ELJ @ 11 DS; 7.7M ELJ @ 8-12, 3 DS; 8.5M ELJ @ 11, 1-3 DS; 9.3M ELJ @ 8-10, 1-3 DS; 10.1M ELJ @ 8-4 DS; 10.8M ELJ @ 8-10, 2-4 DS; 12.3M ELJ @ 2-3 DS; 13.1M ELJ @ 10 DS; 16.3M ELJ @ 7 DS; 17.9M ELJ @ 1-4 DS; 18.6M ELJ @ 8-4 DS; 20.3M ELJ @ 11-4 DS; 37.2M ELJ @ 12-3 DS; 38.8M ELJ @ 2-4 DS; 40.4M ELJ @ 4 DS; 43.4M ELJ @ 2 DS; 44.2M ELJ @1 DS; 45.0M ELJ @ 2-4 DS; 51.8M ELJ @ 2 DS; 57.8M EL(CN) @ 10 DS; 62.8M ELJ @ 9-2 DS; 65.2M ELJ @ 9-2 DS;				
33	12103	33	S-MAS0005151	CRESTWOOD CR	1ST MH W OF SPEERS RD TO MH AT DURHAM BY (E LEG)	S-MH50004380	3.75	S-MH50004394	4.08	75.1	250		CIRCULAR	SANITARY	CO-CONCRETE	6						1	23.5M CNI @ 11 DS;	1.0	43.9M DEG @ 10 DS;	1		8	3.1M OB(GASKET) @ 9-1 DS; 3.4M EM(CN) @ 3-4 DS; 8.5M ELJ @ 5, 7 DS; 12.2M ELJ @ 7-5 DS; 14.0M EMJ @ 9-4 DS; 15.9M ELJ @ 8-4 DS; 21.4M ELJ @ 10-2 DS; 23.5M OB(CN) @ 6-9 DS;				
34	12104	34	S-MAS0002232	EVERGLADE PL	1ST MH N BEAVERHILLE LEG)TO BEAVERHILLE LEG)	S-MH50001872	3.45	S-MH50001871	4.75	42.7	250		CIRCULAR	SANITARY	CO-CONCRETE	2								1.0	35.0M RFJ @ 6 DS;	1		3	18.1M ELJ @ 8 DS; 26.7M EL @ 7-5 DS; 33.5M OBJ (TOY) @ 4-6 DS; 42.1M EMJ @ 7-5 DS;				
35	12105	35	S-MAS0002194	ROCKCLIFFE RD(E LEG)	2ND S ROCKCLIFFE(N LEG)3RD S ROCKCLIFFE(N LEG)	S-MH50001841	2.70	S-MH50001842	2.83	46.3	250		CIRCULAR	SANITARY	CO-CONCRETE	4										1		4	17.7M EL(CN) @ 8-10 DS; 34.0M EL(CN) @ 4 DS; 34.6M EL(CN) @ 8 DS; 45.5M ELJ @ 8-4 DS;				
36	12106	36	S-MA4000553	CORDITE RD (NPL)	1ST MH W OF LANIGAN ST TO 2ND MH W OF LANIGAN ST	S-MH40005044	3.75	S-MH40005045	4.02	104.5	250		CIRCULAR	SANITARY	CO-CONCRETE	3						1	100.8M CNI @ 2 DS;			1	43.8	14	0.0-13.4M EL @ 4, 8 DS; 13.5M ELJ @ 9-3 DS; 13.6M EL @ 4, 8 DS; 14.7M ELJ @ 8-4 DS; 14.9-30.7M ELJ @ 4, 8-9 DS; 31.5M EL @ 4, 8 DS; 32.4M ELJ @ 7-5 DS; 33.2M ELJ @ 3-5, 7-8 DS; 34.5M ELJ @ 4, 8 DS; 35.6M ELJ @ 8-2 DS; 35.8-37.9M EL @ 4, 8 DS; 38.2-45.4M EL @ 4, 8 DS; 45.4M ELJ @ 8-4 DS; 45.7M EL @ 4, 8 DS; 46.5M EL @ 1-5 DS; 46.8-48.1M EL @ 4, 8 DS; 48.2M EL(CN) @ 4 DS; 48.9M EL @ 4, 8 DS; 52.0M EL @ 8 DS; 59.8M ELJ @ 8-4 DS; 59.9M ELJ @ 8-4 DS; 69.5M ELJ @ 8-10 DS; 71.9M EL @ 1 DS; 75.8M ELJ @ 9-4 DS; 103.8M ELJ @ 8-4 DS;				
37	12107	37	S-MA4000584	VULCAN AV	6TH MH E OF GATEWAY RD TO MH AT BRUNSWICK ST	S-MH40005075	5.50	S-MH40005074	6.62	121.9	250		CIRCULAR	SANITARY	CO-CONCRETE	1										1		6	1.9M ELJ @ 9 DS; 63.5M ELJ @ 8-10 DS; 68.4M ELJ @ 8, 4 DS; 78.9M ELJ @ 8-11, 2-4 DS; 92.9M EL(CN) @ 10-3 DS; 94.1M ELJ @ 9-12 DS; 117.4M EL @ 5, 7 DS;				
38	12108	38	S-MA4002620	IAN PL	MH AT EDISON AV TO 1ST MH S OF EDISION AV	S-MH40002368	2.56	S-MH40005566	2.34	79.1	375		CIRCULAR	COMBINED	CO-CONCRETE	7						1	13.0M RFJ @ 2 DS; 14.4M RFJ @ 10-4 DS; 16.8M RFJ @ 4 DS; 20.5M RFJ @ 8 DS; 21.1M RM @ 7-9 DS; 21.7M RFJ @ 9, 2-4 DS; 22.9M RFJ @ 8-3 DS; 24.2M RFJ @ 2 DS; 25.5M RFJ @ 2-4 DS; 26.1M RF @ 12 DS; 26.7M RFJ @ 10-2 DS; 27.9M RFJ @ 11, 2 DS; 29.1M RFJ @ 4 DS; 29.7M RF @ 12 DS; 30.4M RFJ @ 10-2 DS; 31.5M RFJ @ 9-3 DS; 32.8M RFJ @ 11-7 DS; 34.0M RFJ @ 7-2, 5 DS;34.8M RFJ @ 12 DS; 35.3M RFJ @ 9-3 DS; 36.5M RFJ @ 2-4, 8 DS; 37.8M RFJ @ 2 DS; 38.4M RF @ 12 DS; 39.0M RFJ @10-2 DS; 40.2M RFJ @ 11-2 DS; 41.4M RFJ @ 2-4, 8 DS; 45.1M RFJ @ 2-4, 10 DS; 46.0M RFJ @ 4, 9 DS;47.1M RF @ 1 DS; 47.6M RFJ @ 9-3 DS; 48.2M RF @ 1 DS; 48.8M RFJ @ 4, 8 DS; 51.3M RFJ @ 9 DS; 52.9M RFJ @ 1, 10 DS; 52.8M RF(CN) @ 10 DS; 71.1M RFJ @ 8 DS; 72.2M RFJ @ 4, 8 DS; 73.5M RFJ @ 9 DS; 74.7M RFJ @ 3, 9 DS; 77.2M RFJ @ 9 DS; 77.6M RF(CN) @ 10 DS;	1.0	39																																
39	12109	39	S-MA4000614	EDISON AV	MH AT IAN PL TO 1ST MH W OF IAN PL	S-MH40002368	2.56	S-MH40002367	2.58	112.2	300		CIRCULAR	COMBINED	CI-CAST IRON	14								1	14.5M CNI @ 2 DS;	1.0	20.1M RF @ 9 DS; 20.9M RFJ @ 9 DS; 25.2M EL(CN) @ 2 DS; 52.0M RFJ @ 9 DS;	1		6	19.8M ELJ @ 3 DS; 23.5M EL @ 4 DS; 55.7M ELJ @ 8 DS; 74.6M ELJ @ 3-5 DS; 88.2M EL(CN) @9 DS; 108.0M ELJ @ 4 DS;				
40	12110	40	S-MA4002973	SOUTHWELL RD	MH AT GROUSE PL TO MH AT SOUTHWELL RD NW LEG	S-MH40002686	3.42	S-MH40002685	4.32	88.4	250		CIRCULAR	SANITARY	CO-CONCRETE	11										1		7	20.3M EL(CN) @ 9 DS; 30.2M ELJ @ 8-11 DS; 31.7M ELJ @ 9-11 DS; 33.6M EL(CN) @ 4 DS; 65.6M EL(CN) @ 8 DS; 79.6M EL(CN) @ 3-5, 7-9 DS; 87.9M EL @ 8-4 DS;				
41	12111	41	S-MA4002976	SOUTHWELL RD NW LEG	MH AT SOUTHWELL RD SW LEG TO MH AT MANTHORNE AV	S-MH40002685	4.32	S-MH40002760	4.10	117.1	250		CIRCULAR	SANITARY	CO-CONCRETE	9						4	27.1M CNI @ 10 DS; 60.4M CNI @ 10 DS; 75.6M CNI @ 2 DS; 76.4M CNI @ 10 DS;	1.0	52.9M DEG @ 4, 8 DS;	1		10	12.1M EL(CN) @ 8-11 DS; 49.3M ELJ @ 4 DS; 56.1-58.7M EL @ 4, 8 DS; 60.3M EL(CN) @ 8 DS; 67.9M ELJ @ 8-11 DS; 75.6M EL(CN) @ 4, 9 DS; 76.4M EL(CN) @ 9 DS; 80.7M ELJ @ 4, 8 DS; 101.5M ELJ @ 9-3 DS; 109.5M ELJ @ 8-3 DS; 113.4M ELJ @ 8-4 DS;				
42	12112	42	S-MA4003038	MANTHORNE AV	MH AT WYNYARD BY TO MH AT SUNNY HILLS RD	S-MH40002760	4.05	S-MH40002759	4.09	76.3	250		CIRCULAR	SANITARY	CO-CONCRETE	0										1		7	29.7M ELJ @ 8-4 DS; 31.2M ELJ @ 8-4 DS; 32.8M ELJ @ 9-3 DS; 35.2M EL @ 8-11 DS; 41.5M EL @ 11 DS; 42.0M ELJ @ 10 DS; 43.7M ELJ @ 4 DS; 54.4M ELJ @ 10-3 DS; 57.5M ELJ @ 10-4 DS;				
43	12113	43	S-MA4003040	SUNNY HILLS RD NE LEG	MH @ SUNNY HILLS RD SELEG-MH@ SUNNY HILLS NWLEG	S-MH40002766	5.85	S-MH40002764	5.50	96.2	250		CIRCULAR	SANITARY	CO-CONCRETE	6										1		10	3.4M ELJ @ 8-10, 4 DS; 14.2M ELJ @ 9 DS; 15.8M ELJ @ 4 DS; 20.4M ELJ @ 8-4 DS; 21.9M ELJ @ 9 DS; 23.8M EL(CN) @ 9-11 DS; 39.0M EL(CN) @ 9-3 DS; 46.4M OBJ @ 5 DS; 58.6M ELJ @ 9-12 DS; 96.1M ELJ @ 8-4 DS;				
44	12114	44	S-MA4003242	SUN VALLEY DR	MH AT CAPRICORN PL TO 1ST MH NW OF CAPRICORN PL	S-MH40002943	5.60	S-MH40002951	5.65	61.8	250		CIRCULAR	SANITARY	CO-CONCRETE	10								1.0	17.0-20.9M DEG @ 3, 9 DS; 30.2M RF(CN) @ 10 DS;	1		5	3.0M EL(CN) @ 7-10 DS; 12.3M EL(CN) @ 2-4 DS; 25.8M ELJ @ 2-4 DS; 59.9M EL(CN) @ 3 DS; 61.3M ELJ @ 8-10, 2 DS;				
45	12115	45	S-MA4003120	ARBOR GR W LEG	1ST MH S OF ARBOR GR N LEG TO MH AT SUN VALLEY D	S-MH40002830	4.75	S-MH40002840	6.60	75.9	250		CIRCULAR	SANITARY	CO-CONCRETE	12								1.0	11.2M RF(CN) @ 9 DS; 75.1M RFJ @ 4 DS;	1		4	8.0M EL(CN) @ 8-10 DS; 11.2M EL(CN) @ 8-10 DS; 35.3M EL(CN) @ 9 DS; 63.9M ELJ @ 1-4 DS; 68.0M EL @ 9-1 DS;				
46	12116	46	S-MA4001405	RALEIGH ST.	MH AT MCIVOR AV TO MH AT ALGONQUIN AV	S-MH40001281	4.15	S-MH40001280	3.87	79.3	250		CIRCULAR	SANITARY	CO-CONCRETE	0										1	44.0	16	4.5M EL @ 7-5 DS; 6.1M ELJ @ 8-4 DS; 7.5M ELJ @ 8-4 DS; 8.7M EL @ 8-10 DS; 9.1M ELJ @ 8-4 DS; 9.5M EL @ 8-11, 1-4 DS; 11.3M EL @ 8-4 DS; 13.1M EL @ 8-11 DS; 13.7 M ELJ @ 1-5 DS; 14.1M EL @ 2-5 DS; 14.7M EL @ 8-4 DS; 16.2M ELJ @ 8-1 DS; 17.4M EL @ 8-4 DS; 18.5-19.9M EL @ 8-10 DS; 20.5M EL @ 8-4 DS; 22.8M EL @ 8-12 DS; 23.8M EL @ 8-4 DS; 25.0M EL @ 11-4 DS; 25.7M EL @ 8-4 DS; 26.5M EL @ 8-11 DS; 29.0M ELJ @ 7-11 DS; 29.7M EL @ 7-1 DS; 30.4M ELJ @ 8-4 DS; 32.0M ELJ @ 2 DS; 32.6M ELJ @ 8-4 DS; 34.4M EL @ 11-4 DS; 35.1M ELJ @ 8-4 DS; 36.6M ELJ @ 8-4 DS; 37.7-47.2M EL @ 8-4 DS; 47.4-49.0M EL @ 10-2 DS; 49.4-61.3M EL @ 9-3 DS; 62.9-64.4M EL @ 9-3 DS; 66.6-69.7M EL @ 8-10, 3 DS; 71.8M ELJ @ 9-3 DS; 73.5M ELJ @ 1-4 DS; 74.0M EL @ 3 DS; 75.0M ELJ @ 8-4 DS; 76.5M ELJ @ 8-5 DS; 77.1M EL @ 8-10 DS; 78.1M ELJ @ 8-4 DS;				
47	12117	47	S-MA4001158	MORNINGMEAD W(W LEG)	MH AT MORNINGMEAD(S LEG)MH AT MORNINGMEAD(N LEG)	S-MH40001047	3.66	S-MH40001055	3.79	114.0	250		CIRCULAR	SANITARY	CO-CONCRETE	13								1.0	80.8M DEG @ 1 DS; 81.1-87.7M DEG @ 11-1 DS; 98.5M DEG @ 3 DS; 110.0M DEG @ 12 DS;	1		7	6.8M EL(CN) @ 7-9 DS; 12.9M EL(CN) @ 4 DS; 24.7M ELJ @ 2-4 DS; 40.1M EL(CN) @ 8-11 DS; 44.6M EL(CN) @ 1-5 DS; 53.3M EL @7-10 DS; 67.3M ELJ @ 2-3 DS; 77.1M EL @ 2-4 DS; 77.5M EL @ 8-4 DS; 112.6M ELJ @ 8-4 DS;				
48	12118	48	S-MA4001567	BONNIER AV.	4TH MH W OF RALEIGH ST TO MH AT BONNER AV AND JODANNDRA BY	S-MH40001426	4.34	S-MH40001413	5.23	105.3	250		CIRCULAR	SANITARY	CO-CONCRETE	11						5	7.8M CNI @ 11 DS; 15.7M CNI @ 12 DS; 30.2M CNI @ 2 DS; 46.7M CNI @ 2 DS; 87.4M CNI @ 11 DS;	1.0	87.8M DEG @ 10, 2-3 DS; 91.4M DEG @ 11 DS; 92.6M DEG @ 11-1 DS; 95.3M DEG @ 2, 10 DS; 96.5-98.6M DEG @ 11, 1 DS; 102.8M DEG @ 11-1 DS;	1		31	1.0M ELJ @ 8-4 DS; 4.5M ELJ @ 4 DS; 5.8M ELJ @ 8-4 DS; 6.2M ELJ @ 4 DS; 7.8M EL(CN) @ 9 DS; 9.2M ELJ @ 2-4 DS; 10.6M ELJ @ 8-4 DS; 11.2M EL @ 8-4 DS; 12.2M ELJ @ 8-3 DS; 13.8M ELJ @ 8-4 DS; 15.8M EL (CN) @ 10 DS; 20.0M ELJ @ 4 DS; 26.4M EL(CN) @ 8-10 DS; 27.6M ELJ @ 4 DS; 29.3M ELJ @ 4, 8 DS; 30.2M EL(CN) @ 3 DS; 30.8M OB(J) @ 3-4 DS; 36.9M ELJ @ 5 DS; 44.5M ELJ @ 1-3 DS; 46.7M ELJ @ 8-4 DS; 58.4M ELJ @ 8 DS; 58.7M EL @ 4 DS; 64.5M ELJ @ 4 DS; 66.4M EL(CN) @ 7-5 DS; 67.7M ELJ @ 8-4 DS; 70.1M EL(CN) @ 9-11 DS; 73.8M ELJ @ 8-4 DS; 78.3M ELJ @ 1-4 DS; 83.1M ELJ @ 2-5 DS; 86.0M ELJ @ 8-3 DS; 87.3M EL(CN) @ 7-5 DS; 93.7M ELJ @ 9-11 DS; 104.6M ELJ @ 8-4 DS;			1.7	EPR FROM 29.1-30.8m DS
49	12119	49	S-MA4000549	EMERSON AV.	4TH MH W OF MONSON ST TO MH AT DUNDOON ST	S-MH40000492	3.96	S-MH40000493	5.99	17.1	250		CIRCULAR	SANITARY	CO-CONCRETE	0								1.0	14.9-16.6M DEG @ 9-3 DS;	1		3	1.2M EL @ 2-5, 7-10 DS; 2.0M ELJ @ 3-9 DS; 2.9M ELJ @ 3-5, 7-9 DS; 4.7M ELJ @ 3-5 DS;				

* Denotes assumed asset diameter based on discrepencies between GIS and inspection video. Contractor to verify.