









METRIC WHOLE NUMBERS INDICATE MILLIMETRES DECIMALIZED NUMBERS INDICATE METRES



These design documents are prepared solely for the use by the party with whom the design professional has entered into a contract and there are no representations of any kind made by the design professional to any party with whom the design professional has not entered into a contract. Any use of the drawing, disk or electronic data without the expressed written permission of Tower Engineering inc. is strictly prohibited. The contractor is responsible to verify all dimensions with conditions on the site and report discrepancies to Tower Engineering for adjustment. All prints to be returned.

## WARNING

IF POWER EQUIPMENT OR EXPLOSIVES ARE TO BE USED FOR EXCAVATION ON THIS PROJECT THE CONTRACTOR MUST:

1) NOTIFY THE GAS COMPANY OF THE PROPOSED LOCATION OF EXCAVATION.

2) TAKE PRECAUTION TO AVOID DAMAGE TO GAS COMPANY INSTALLATIONS.

LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION. SEE PROVINCIAL REGULATION 210/72 FOR DETAILS

SUPV. U/G STRUCTURES COMMITTEE

NOTE:

## LOCATION APPROVED ELEV. UNDERGROUND STRUCTURES CONSTRUCTION COMPLETION DATE: YYYY MM DD DATE ISSUED FOR TENDER 2019 05 27 DKG | SCALE: ISSUED FOR 99% REVIEW 2019 05 09 | DKG | HORIZONTAL 2019 04 17 DKG VERTICAL ISSUED FOR 66% REVIEW DATE BY DATE REVISIONS PLOT DATE: 2019-05-27

## Neegan Burnside Limited 307 Commerce Drive NEEGANBURNSIDE Winnipeg, Manitoba, R3P 1B3 telephone (204) 949-7110 fax (204) 949-7111 web www.neeganburnside.com CHECKED BY DESIGNED DKG APPROVED BY DRAWN VRR AS NOTED RELEASED FOR CONSTRUCTION

2019 04 15 DATE

ENGINEER'S SEAL DKG DKG CONSULTANT DRAWING NUMBER E-02

TENDER NO. 269-2019 CONTRACT NUMBER: X

Winnipeg

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION

GENERAL NOTE

A. PROVIDE DEDICATED AND SEPARATED NEUTRAL CONDUCTOR FOR EACH LIGHTING CIRCUIT. SHARING OF NEUTRAL CONDUCTORS AMONG LIGHTING CIRCUITS ARE NOT ACCEPTABLE. TYPICAL.

B. GATE CHAMBER, WET WELL AND WET WELL ROOM IS CLASSIFIED AS ZONE 1 HAZARDOUS LOCATION AND CATEGORY 2 WET LOCATION. ALL EQUIPMENT AND INSTALLATION METHODS IN THESE AREAS SHALL

. DRY WELL IS CLASSIFIED AS A CATEGORY 1 WET LOCATION. ALL EQUIPMENT AND INSTALLATION METHODS IN THE DRY WELL SHALL COMPLY WITH

E. ENSURE ALL ELECTRICAL PENETRATIONS ARE SEALED TO PREVENT PASSAGE OF HAZARDOUS AND

DRAWING NOTES:

PROVIDE EIGHT (8) TYPE A LIGHTS FOR DRYWELL.
MOUNT FOUR (4), 2.4m A.F.F. AND FOUR (4) 4.8m A.F.F. TO PROVIDE EVEN ILLUMINATIONS AT ALL ELEVATIONS IN THE DRYWELL. POSITION LIGHTS AS SHOWN TO AVOID INTERFERENCE WITH PUMP AND WALKWAY REMOVAL WHILE MAINTAINING ACCESS FOR MAINTENANCE. COORDINATE EXACT LOCATION WITH

CONTRACT ADMINISTRATOR ON SITE.

COMPLY WITH CEC SECTION 18 AND 12.

D. PUMP ROOM IS CLASSIFIED AS AN ORDINARY

CORROSIVE LIQUIDS AND VAPOURS.

1 SWITCH FOR DRYWELL LIGHTS.

CEC SECTION 22.

LOCATION.

MISSION FPS UPGRADES

OF CITY DRAWING NUMBER

l-0163F-E0003-001|

LIGHTING LAYOUT

FILE PATH: T: \181000\181654 C Of W Mission Flood Pumping Station\16000 Electrical\11 Drawings\Working Drawings
FILE NAME: 181654 — E-02 Electrical Lighting Layout